

Def

MISSISSIPPI ASBESTOS DEMOLITION/RENOVATION NOTIFICATION FORM

Mail notification to: MDEQ Asbestos and Lead Branch, 515 E. Amite Street, Jackson, MS 39201

MDEQ Use Only: <input checked="" type="checkbox"/> Email <input type="checkbox"/> Mail <input type="checkbox"/> Hand Delivery		Postmark (mail only)	Date Received 11-30-22	AI Number
I. Type of Notification (O=Original R=Revised C=Canceled A= Annual): <u>O</u>				
II. TYPE OF OPERATION (D=Demo O= Ordered Demo R=Renovation E=Emer. Renovation): <u>R</u>				
III. FACILITY DESCRIPTION (Include building name, number and floor or room number):				
Bldg. Name: <u>Alliance Health Center, 5th Floor</u>				
Address: <u>5000 MS-39 W</u>				
City: <u>Meridian</u>	State: <u>MS</u>	Zip: <u>39301</u>		
Site Location: <u>same</u>		Tel: <u>601 483-6211</u>		
Building Size: <u>107,000 sq</u>	# of Floors: <u>7</u>	Age in Years: <u>60/1962</u>		
Present Use: <u>Hospital</u>	Prior Use: <u>Hospital</u>			
IV. FACILITY INFORMATION (Identify owner, asbestos removal contractor, and other operator)				
OWNER NAME: <u>United Health System of Delaware Inc</u>				
Address: <u>500 MS-39 W</u>				
City: <u>Meridian</u>	State: <u>MS</u>	Zip: <u>39301</u>		
Contact: <u>Jay Giesler</u>		Tel: <u>634-383-8328</u>		
ASBESTOS REMOVAL CONTRACTOR: <u>Forrest Construction LLC</u>				
Address: <u>591 Raymond Rd</u>				
City: <u>Jackson</u>	State: <u>MS</u>	Zip: <u>39204</u>		
Contact: <u>Richard or Darius Forrest</u>		Tel: <u>601 720-7281 or 769 216-8741</u>		
Certification Number: <u>ABC-00008477</u>	Expiration Date: <u>7/4/23</u>			
OTHER OPERATOR: <u>N/A</u>				
Address:				
City:	State:	Zip:		
Contact:	Tel:			
V. WAS SITE INSPECTED TO DETERMINE PRESENCE OF ASBESTOS? (Yes/No): <u>Yes</u>				
WAS ASBESTOS PRESENT? (Yes/No): <u>Yes</u>			Inspection Date: <u>11/10/22</u>	
Inspector: <u>Performance Environmental</u>	Certification Number:	Expiration Date:		
VI. SUSPECT MATERIALS SAMPLED AND PROCEDURES USED TO DETECT THE PRESENCE OF ASBESTOS MATERIAL: <u>Services / Jonathan Muirhead / Test method PLM, Lab tests</u>				
VII. QUANTITY OF RACM TO BE REMOVED:				
Pipes (LN FT):	Surface Area (SQ FT): <u>pipe elbow insulation 1,500 sq ft</u>	Volume of Facility Components (CU FT):		
VIII. QUANTITY OF NONFRIABLE ASBESTOS NOT REMOVED:				
Category I: <u>V</u>	Category II:			
IX. SCHEDULED DATES ASBESTOS REMOVAL (MM/DD/YY) Start: <u>12/7/22</u>			Complete: <u>1/7/22</u>	
X. SCHEDULED DATES DEMO/RENOVATION (MM/DD/YY) Start: <u>N/A</u>			Complete: <u>N/A</u>	

XI. DESCRIPTION OF PLANNED DEMOLITION OR RENOVATION WORK, AND METHOD(S) TO BE USED:

utility knife, razor strips, spray bottle, water, polythene sheeting, waste bags
personal protective equipment, negative air machine

XII. DESCRIPTION OF WORK PRACTICES AND ENGINEERING CONTROLS TO BE USED TO PREVENT EMISSIONS OF ASBESTOS AT THE DEMOLITION OR RENOVATION SITE:

poly doors, and window, build on containment

XIII. WASTE TRANSPORTER #1

Name: Forest construction LLC

Address: 591 Raymond rd

City: Jackson

State: MS

Zip: 39204

Contact Person:

Tel:

WASTE TRANSPORTER #2

Name:

Address:

City:

State:

Zip:

Contact Person:

Tel:

XIV. WASTE DISPOSAL SITE

Name: Clearview Landfill

Address: 2253 Mudline rd

City: Meridian

State: MS

Zip: 39092

Contact Person: No name specific

Tel: 661 483-0715

XV. IF DEMOLITION ORDERED BY A GOVERNMENT AGENCY, PLEASE IDENTIFY THE AGENCY BELOW:

Name:

Title:

Authority:

Date of Order (MM/DD/YY):

Date Ordered to Begin (MM/DD/YY):

XVI. FOR EMERGENCY RENOVATIONS:

Date and Hour of Emergency (MM/DD/YY):

Description of the sudden unexpected event:

Call MDEU

Explanation of how the event caused unsafe conditions or would cause equipment damage or an unreasonable financial burden:

XVII. DESCRIPTION OF PROCEDURES TO BE FOLLOWED IN THE EVENT THAT UNEXPECTED ASBESTOS IS FOUND OR PREVIOUSLY NONFRIABLE ASBESTOS MATERIAL BECOMES CRUMBLED, PULVERIZED, OR REDUCED TO POWDER:

Call MDEU

XVIII. I CERTIFY THAT AN INDIVIDUAL TRAINED IN THE PROVISIONS OF THIS REGULATION (40 CFR PART 61, SUBPART M) WILL BE ONSITE DURING THE DEMOLITION OR RENOVATION, AND EVIDENCE THAT THE REQUIRED TRAINING HAS BEEN ACCOMPLISHED BY THIS PERSON WILL BE AVAILABLE FOR INSPECTION DURING NORMAL BUSINESS HOURS.

Darius Forest
Type or Print Name

[Signature]
(Signature of Owner/Operator)

11/23/22
(Date)

XIX. I CERTIFY THAT THE ABOVE INFORMATION IS CORRECT:

Darius Forest
Type or Print Name

[Signature]
(Signature of Owner/Operator)

11/23/22
(Date)



3130 Old Farm Lane, Suite 1
Commerce Twp., MI 48390

877-665-3373

Asbestos Laboratory Report

Prepared Exclusively For:

Performance Environmental Services
Jonathan Muirhead
28054 Center Oaks Court Suite B
Wixom, MI 48393
248-926-3800
labdata@perform-env.com



Project: Alliance Health Ctr - 5000 Mississippi 39

Report Date: 11/11/22

Sampled: 11/10/22

Project # 2210886

Lab # A25654

Received: 11/11/22

Analyzed: 11/11/22



Report Prepared For: Performance Environmental Services
Project Name: Alliance Health Ctr - 5000 Mississippi 39
Project Number: 2210886
Report Date: 11/11/22
Lab Number: A25654

Asbestos Report Summary

Test Method: Polarized Light Microscopy (PLM)

3 Samples Analyzed
3 Samples Containing >1% Asbestos

Greater than 1% Asbestos

Client ID	Lab Number	Description	Asbestos
5-518-517-001	A25654 - 1	Pipe Elbow Insulation Material / 5th Fl Hallway Between Rooms 518 & 517	Chrysotile 4%
5-130-001	A25654 - 2	Pipe Elbow Insulation Material / 5th Floor, Room 5-130	Chrysotile 4%
5-136-001	A25654 - 3	Pipe Elbow Insulation Material / 5th Floor, Room 5-136	Chrysotile 4%



Report Prepared For: Performance Environmental Services
Project Name: Alliance Health Ctr - 5000 Mississippi 39
Project Number: 2210886
Report Date: 11/11/22
Lab Number: A25654

Certificate of Laboratory Analysis

Test Method: Polarized Light Microscopy (PLM)

EPA 600/R-93/116 and/or EPA - Appendix E to Subpart E of 40 CFR Part 763;
Interim Method for the Determination of Asbestos in Bulk Insulation Samples

Project: Alliance Health Ctr - 5000 Mississippi 39
Project Number: 2210886

Prepared For

Performance Environmental Services
Jonathan Muirhead
28054 Center Oaks Court Suite B
Wixom, MI 48393
248-926-3800
labdata@perform-env.com

IMS Lab No. A25654
Date Collected: 11/10/22
Date Received: 11/11/22
Date Analyzed: 11/11/22
Date Reported: 11/11/22

Client ID Lab No.	Client Description	Sample Color(s)	Laboratory Attributes	Fibrous Components	Non-Fibrous Components	Asbestos Type / Percent
5-518-517-001 A25654 - 1	Pipe Elbow Insulation Material / 5th Fl Hallway Between Rooms 518 & 517	Gray	Heterogeneous Friable Fibrous	4% Chrysotile 5% Cellulose 30% Fiberglass	61% Matrix	Chrysotile 4%
5-130-001 A25654 - 2	Pipe Elbow Insulation Material / 5th Floor, Room 5-130	Gray	Heterogeneous Friable Fibrous	4% Chrysotile 5% Cellulose 30% Fiberglass	61% Matrix	Chrysotile 4%
5-136-001 A25654 - 3	Pipe Elbow Insulation Material / 5th Floor, Room 5-136	Gray	Heterogeneous Friable Fibrous	4% Chrysotile 5% Cellulose 30% Fiberglass	61% Matrix	Chrysotile 4%

IMS Laboratory, LLC is accredited through the National Voluntary Laboratory Accreditation Program (NVLAP). Data is provided in compliance with NVLAP policy modules and ISO 17025:2017 guidelines.



Marty Eakin 11/11/22
Marty Eakin, Asbestos Laboratory Manager



Report Prepared For: Performance Environmental Services
Project Name: Alliance Health Ctr - 5000 Mississippi 39
Project Number: 2210886
Report Date: 11/11/22
Lab Number: A25654

Warranties, Legal Disclaimers, and Limitations

Stereoscopic microscopy and polarized light microscopy coupled with dispersion staining is the analytical technique used for sample identification. The percentage of each component is visually estimated by volume. The detection limit for this method is <1% by visual estimation and 0.25% by 400 point counts or 0.1% by 1,000 point counts. The samples were analyzed as submitted by the client and may not be representative of the larger material in question. IMS Laboratory, LLC ("IMS") will discard all samples after 7 days.

Matrix interference and/or resolution limits may yield false results in certain circumstances. Samples collected via tape and/or wipe may reduce sensitivity and reliability of quantification. Suspect floor tiles containing less than 1% asbestos should be tested with SEM or TEM. Many vinyl floor tiles have been manufactured using greater than 1% asbestos. Often the asbestos was milled to a fiber size below the detection limit of polarized light microscopy. Therefore, a "No Asbestos Found" reading on vinyl floor tile does not necessarily exclude the presence of asbestos. TEM provides a more conclusive form of analysis for vinyl floor tiles.

This certificate of analysis relates only to the samples tested, as received by IMS and, to insure the integrity of the results, may only be reproduced in full. IMS is not responsible for the accuracy of the results for layered samples or samples comprising multiple materials. Unless otherwise noted in the body of this report, the condition of samples upon receipt was acceptable.

This report is generated by IMS at the request of, and for the exclusive use of, the IMS client named on this report. This report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the U.S. Government. Project Name, Project Number, Sampling Date, Material Descriptions, Sampling Locations and Volume have been provided to IMS by the client and may affect the validity of the results. This report applies only to the samples taken at the time, place and location referenced in the report and received by IMS. Please be aware that property conditions, inspection findings and laboratory results can and do change over time relative to the original sampling due to changing conditions and many other factors. IMS does not furnish, and has no responsibility for, the inspector or inspection service that performs the inspection or collects the test samples. It is the responsibility of the end-user of this report to select a properly trained professional to conduct the inspection and collect appropriate samples for analysis and interpretation. Neither IMS, nor its affiliates, subsidiaries, suppliers, employees, agents, contractors and attorneys ("IMS related parties") are able to make and do not make any determinations as to the safety or health condition of a property in this report. The client and client's customer are solely responsible for the use of, and any determinations made from, this report, and no IMS related party shall have any liability with respect to decisions or recommendations made or actions taken by either the client or the client's customer based on the report.

IMS hereby expressly disclaims any and all representations and warranties of any kind or nature, whether express, implied or statutory, related to the testing services or this report including, but not limited to, damages for loss of profit or goodwill regardless of the negligence (either sole or concurrent) of IMS and whether IMS has been informed of the possibility of such damages, arising out of or in connection with IMS's services or the delivery, use, reliance upon or interpretation of test results by client or any third party. In no event will IMS be liable for any special, indirect, incidental, punitive, or consequential damages of any kind regardless of the form of action whether in contract, tort (including negligence), strict product liability or otherwise, arising from or related to the testing services or this report.

IMS accepts no legal responsibility for the purposes for which the client uses the test results. IMS will not be held responsible for the improper selection of sampling devices even if we supply the device to the user. The user of the sampling device has the sole responsibility to select the proper sampler and sampling conditions to insure that a valid sample is taken for analysis. Additionally, neither this report nor IMS makes any express or implied warranty or guarantee regarding the inspection or sampling done by the inspector, the qualifications, training or sampling methodology used by the inspector performing the sampling and inspection reported herein, or the accuracy of any information provided to IMS serving as a basis for this report. The total liability of IMS related to or arising from this report to a client or any third party, whether under contract law, tort law, warranty or otherwise, shall be limited to direct damages not to exceed the fees actually received by IMS from the client for the report. The invalidity or unenforceability, in whole or in part, of any provision, term or condition herein shall not invalidate or otherwise affect the enforceability of the remainder of these provisions, terms and conditions. Client shall indemnify IMS and its officers, directors and employees and hold each of them harmless for any liability, expense or cost, including reasonable attorney's fees, incurred by reason of any third party claim in connection with IMS's services, the test result data or its use by client.

- End of Lab Report Number A25654 -

- 4 -

This report has been prepared by IMS Laboratory, LLC at the request of and for the exclusive use of Performance Environmental Services. Read the important terms, conditions, and limitations that apply to this report carefully.