

MISSISSIPPI ASBESTOS DEMOLITION/RENOVATION NOTIFICATION FORM

Mail notification to: MDEQ Asbestos and Lead Branch, 515 E. Amite Street, Jackson, MS 39201

| | | | | |
|---|-----------------------------|--|----------------------------|-----------|
| MDEQ Use Only: <input checked="" type="checkbox"/> Email <input type="checkbox"/> Mail <input type="checkbox"/> Hand Delivery | | Postmark (mail only) | Date Received 4/17/2025 | AI Number |
| I. Type of Notification (O=Original R=Revised C=Canceled A= Annual) <input type="radio"/> | | | | |
| II. TYPE OF OPERATION (D=Demo O= Ordered Demo R=Renovation E=Emer. Renovation) ER | | | | |
| III. FACILITY DESCRIPTION (Include building name, number and floor or room number) | | | | |
| Bldg. Name: HARRISON COUNTY COURTHOUSE | | | | |
| Address 1801 23RD AVENUE | | | | |
| City: GULFPORT | State: MS | Zip: 39502 | County: HARRISON | |
| Site Location: 1ST FLOOR | | Tel: 228-867-0136 | | |
| Building Size 69,000 SQ. FT. | # of Floors: 2 | Age in Years: 48 | | |
| Present Use: COURTHOUSE | Prior Use: COURTHOUSE | | | |
| IV. FACILITY INFORMATION (Identify owner, asbestos removal contractor, and other operator) | | | | |
| OWNER NAME: HARRISON COUNTY | | | | |
| Address: 1801 23RD AVENUE | | | | |
| City: GULFPORT | State: MS | Zip: 39502 | | |
| Contact: CHRIS ATHERTON | Tel: 228-861-3386 | | | |
| ASBESTOS REMOVAL CONTRACTOR: WILLIAM S. FOLKS, GUARANTEE ENVIRONMENTAL SERVICES, LLC | | | | |
| Address: 16248 PERKINS ROAD | | | | |
| City: BATON ROUGE | State: LA | Zip: 70810 | | |
| Contact: SHANNON RIVETT | Tel: 225-753-8682 EXT. 227 | | | |
| Certification Number: ABC-00011409 | Expiration Date: 07/18/2025 | | | |
| OTHER OPERATOR: GUARANTEE RESTORATION SERVICES, LLC | | | | |
| Address: 16248 PERKINS ROAD | | | | |
| City: BATON ROUGE | State: LA | Zip: 70810 | | |
| Contact: DARRICK SHANK | Tel: 225-753-8682 | | | |
| V. WAS SITE INSPECTED TO DETERMINE PRESENCE OF ASBESTOS? (Yes/No): YES | | | | |
| WAS ASBESTOS PRESENT? (Yes/No): YES | | Inspection Date: 4/15/25 | | |
| Inspector: DILLON PEARSON | Certification Number: | Expiration Date: | | |
| VI. SUSPECT MATERIALS SAMPLED AND PROCEDURES USED TO DETECT THE PRESENCE OF ASBESTOS MATERIAL: samples were taken of drywall, joint compound on 2nd floor and were negative. Samples of were taken of vinyl plank floor, VACT & mastic on the 1st floor and sent to eurofins lab where they used polarized light method for testing. See report analysis for details. Vinyl plank floor, VACT and mastic were all positive for asbestos. | | | | |
| VII. QUANTITY OF RACM TO BE REMOVED: 25 cu. yds. 15,035 sq. ft. of flooring & mastic | | | | |
| Pipes (LN FT): | Surface Area (SQ FT): 15035 | Volume of Facility Components (CU FT): | | |
| VIII. QUANTITY OF NONFRIABLE ASBESTOS NOT REMOVED: n/a | | | | |
| Category I: | Category II: | | | |
| IX. SCHEDULED DATES ASBESTOS REMOVAL (MM/DD/YY) Start: 4/28/25 | | Complete: 5/14/25 | | |
| X. SCHEDULED DATES DEMO/RENOVATION (MM/DD/YY) Start: | | Complete: | | |

XI. DESCRIPTION OF PLANNED DEMOLITION OR RENOVATION WORK, AND METHOD(S) TO BE USED:

utilize wet removal techniques to keep materials wet so there is no airborne release

XII. DESCRIPTION OF WORK PRACTICES AND ENGINEERING CONTROLS TO BE USED TO PREVENT EMISSIONS OF ASBESTOS AT THE DEMOLITION OR RENOVATION SITE:

Double bag asbestos, wet methods, enviromental controls utilizing HEPA filtered air scrubbers in containment area.

XIII. WASTE TRANSPORTER #1

Name: Waste Pro USA

Address: 4205 Beasley Road

City: Gautier

State: MS

Zip: 39553

Contact Person: Renee

Tel: 228-818-5393

WASTE TRANSPORTER #2

Name:

Address:

City:

State:

Zip:

Contact Person:

Tel:

XIV. WASTE DISPOSAL SITE

Name: Pecan Grove Landfill-Waste Management of MS, Inc.

Address: 9685 Firetower Road

City: Pass Christian

State: MS

Zip: 39571

Contact Person: Sam Williams

Tel: 228-475-9750

XV. IF DEMOLITION ORDERED BY A GOVERNMENT AGENCY, PLEASE IDENTIFY THE AGENCY BELOW:

Name:

Title:

Authority:

Date of Order (MM/DD/YY):

Date Ordered to Begin (MM/DD/YY):

XVI. FOR EMERGENCY RENOVATIONS:

Date and Hour of Emergency (MM/DD/YY): 04/10/25 5:00 pm

Description of the sudden unexpected event:

courthouse flooded from 2nd floor clean water source bathroom down to the 1st floor

Explanation of how the event caused unsafe conditions or would cause equipment damage or an unreasonable financial burden:

Please see 3rd page.

XVII. DESCRIPTION OF PROCEDURES TO BE FOLLOWED IN THE EVENT THAT UNEXPECTED ASBESTOS IS FOUND OR PREVIOUSLY NONFRIABLE ASBESTOS MATERIAL BECOMES CRUMBLED, PULVERIZED, OR REDUCED TO POWDER:

Stop work, verify suspect material is RACM or not, obtain additional permits if necessary

XVIII. I CERTIFY THAT AN INDIVIDUAL TRAINED IN THE PROVISIONS OF THIS REGULATION (40 CFR PART 61, SUBPART M) WILL BE ONSITE DURING THE DEMOLITION OR RENOVATION, AND EVIDENCE THAT THE REQUIRED TRAINING HAS BEEN ACCOMPLISHED BY THIS PERSON WILL BE AVAILABLE FOR INSPECTION DURING NORMAL BUSINESS HOURS.

Shannon Rivett

Type or Print Name

(Signature of Owner/Operator)

4/17/25

(Date)

XIX. I CERTIFY THAT THE ABOVE INFORMATION IS CORRECT:

Shannon Rivett

Type or Print Name

(Signature of Owner/Operator)

4/17/25

(Date)

The toilet in the 2nd floor bathroom overflowed and leaked flooding the 2nd floor down to the 1st floor on Thursday night 4/10/25 around closing time 5:00pm. We were called in and went to the courthouse to start work on Thursday night to start drying procedures and not disturbing anything that could possibly have ACM. The 1st floor houses important legal documents that abstractors must be able to get to at all times. The decision to test for ACM was made on Friday 4/11/25 and the courthouse rep said they already had testing but did not produce the paperwork. The building supervisor came out and said that they needed to do current testing. The testing company was called but it was the weekend so they would do the testing on Monday, 4/14/25 results came back Tuesday, 4/15/25. They tested the drywall and joint compound on the 2nd floor and it came back negative. They tested the 1st floor vinyl plank tile, VCT and mastic and it was positive for asbestos. The courthouse can't perform operations until all ACM is removed. All of the legal documents, furniture, equipment, etc. are being moved out currently so we can get to the floor. This is going to take a few days but we need to start this asbestos abatement immediately so we are asking for an emergency approval.

Results and sketch of 1st floor is also included



Built Environment Testing

Report for:

Chris Pearson
Pearson Environmental
130 Southpointe Dr. Ste J
Byram, MS 39272

Regarding: Eurofins Built Environment Testing Central, LLC
Project: Courthouse; 1801 23rd Avenue
EML ID: 4031244

Approved by:

Dates of Analysis:
Asbestos PLM: 04-15-2025

Business Unit Manager
Scott Ward

Service SOPs: Asbestos PLM (EPA 40CFR App E to Sub E of Part 763 & EPA METHOD 600/R-93-116, SOP EM-AS-S-1267)
NVLAP Lab Code 200525-0

All samples were received in acceptable condition unless noted in the Report Comments portion in the body of the report. The results relate only to the samples as received and tested. The results include an inherent uncertainty of measurement associated with estimating percentages by polarized light microscopy. Measurement uncertainty data for sample results with >1% asbestos concentration can be provided when requested.

Eurofins Built Environment Testing Central, LLC ("the Company"), a member of the Eurofins Built Environment Testing group of companies, shall have no liability to the client or the client's customer with respect to decisions or recommendations made, actions taken or courses of conduct implemented by either the client or the client's customer as a result of or based upon the Test Results. In no event shall the Company be liable to the client with respect to the Test Results except for the Company's own willful misconduct or gross negligence nor shall the Company be liable for incidental or consequential damages or lost profits or revenues to the fullest extent such liability may be disclaimed by law, even if the Company has been advised of the possibility of such damages, lost profits or lost revenues. In no event shall the Company's liability with respect to the Test Results exceed the amount paid to the Company by the client therefor.

Client: Pearson Environmental
 C/O: Chris Pearson
 Re: Courthouse; 1801 23rd Avenue

Date of Submittal: 04-15-2025
 Date of Receipt: 04-15-2025
 Date of Report: 04-15-2025

ASBESTOS PLM REPORT

Total Samples Submitted: 24

Total Samples Analyzed: 24

Total Samples with Layer Asbestos Content > 1%: 2

Location: 1

Lab ID-Version‡: 20073243-1

| Sample Layers | Asbestos Content |
|--|------------------------------------|
| Brown/White Drywall | ND |
| Composite Non-Asbestos Content: | 10% Cellulose < 1% Glass Fibers |
| Sample Composite Homogeneity: | Good |

Comments: No Joint Compound Present.

Location: 2

Lab ID-Version‡: 20073244-1

| Sample Layers | Asbestos Content |
|--|------------------------------------|
| Brown/White Drywall | ND |
| Composite Non-Asbestos Content: | 10% Cellulose < 1% Glass Fibers |
| Sample Composite Homogeneity: | Good |

Comments: No Joint Compound Present.

Location: 3

Lab ID-Version‡: 20073245-1

| Sample Layers | Asbestos Content |
|--|------------------------------------|
| Brown/White Drywall | ND |
| Composite Non-Asbestos Content: | 10% Cellulose < 1% Glass Fibers |
| Sample Composite Homogeneity: | Good |

Comments: No Joint Compound Present.

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. The Company reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

All components not quantified as asbestos content and non-asbestos content are considered to be non-fibrous matrix components. Matrix components may include, but are not limited to, gypsum, paint, silicate minerals, vinyl, binder, calcium carbonate, tar, and foam.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Pearson Environmental
C/O: Chris Pearson
Re: Courthouse; 1801 23rd Avenue

Date of Submittal: 04-15-2025
Date of Receipt: 04-15-2025
Date of Report: 04-15-2025

ASBESTOS PLM REPORT

Location: 4

Lab ID-Version‡: 20073246-1

| Sample Layers | Asbestos Content |
|--|------------------|
| Brown/White Drywall | ND |
| Composite Non-Asbestos Content: | 10% Cellulose |
| Sample Composite Homogeneity: | Good |

Comments: No Joint Compound Present.

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. The Company reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

All components not quantified as asbestos content and non-asbestos content are considered to be non-fibrous matrix components. Matrix components may include, but are not limited to, gypsum, paint, silicate minerals, vinyl, binder, calcium carbonate, tar, and foam.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Pearson Environmental
C/O: Chris Pearson
Re: Courthouse; 1801 23rd Avenue

Date of Submittal: 04-15-2025
Date of Receipt: 04-15-2025
Date of Report: 04-15-2025

ASBESTOS PLM REPORT

Location: 5

Lab ID-Version‡: 20073247-1

| Sample Layers | Asbestos Content |
|--|------------------|
| Brown/White Drywall | ND |
| Composite Non-Asbestos Content: | 10% Cellulose |
| Sample Composite Homogeneity: | Good |

Comments: No Joint Compound Present.

Location: 6

Lab ID-Version‡: 20073248-1

| Sample Layers | Asbestos Content |
|--|------------------------------------|
| Brown/White Drywall | ND |
| Composite Non-Asbestos Content: | 10% Cellulose < 1% Glass Fibers |
| Sample Composite Homogeneity: | Good |

Comments: No Joint Compound Present.

Location: 7

Lab ID-Version‡: 20073249-1

| Sample Layers | Asbestos Content |
|--|------------------------------------|
| White Joint Compound | ND |
| Brown/White Drywall | ND |
| Composite Non-Asbestos Content: | 10% Cellulose < 1% Glass Fibers |
| Sample Composite Homogeneity: | Good |

Location: 8

Lab ID-Version‡: 20073250-1

| Sample Layers | Asbestos Content |
|--|------------------------------------|
| White Joint Compound | ND |
| Brown/White Drywall | ND |
| Composite Non-Asbestos Content: | 10% Cellulose < 1% Glass Fibers |
| Sample Composite Homogeneity: | Good |

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. The Company reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

All components not quantified as asbestos content and non-asbestos content are considered to be non-fibrous matrix components. Matrix components may include, but are not limited to, gypsum, paint, silicate minerals, vinyl, binder, calcium carbonate, tar, and foam.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Pearson Environmental
 C/O: Chris Pearson
 Re: Courthouse; 1801 23rd Avenue

Date of Submittal: 04-15-2025
 Date of Receipt: 04-15-2025
 Date of Report: 04-15-2025

ASBESTOS PLM REPORT

Location: 9

Lab ID-Version‡: 20073251-1

| Sample Layers | Asbestos Content |
|--|------------------------------------|
| White Joint Compound | ND |
| Brown/White Drywall | ND |
| Composite Non-Asbestos Content: | 10% Cellulose < 1% Glass Fibers |
| Sample Composite Homogeneity: | Good |

Location: 10

Lab ID-Version‡: 20073252-1

| Sample Layers | Asbestos Content |
|--|------------------------------------|
| Brown/White Drywall | ND |
| Composite Non-Asbestos Content: | 10% Cellulose < 1% Glass Fibers |
| Sample Composite Homogeneity: | Good |

Comments: No Joint Compound Present.

Location: 11

Lab ID-Version‡: 20073253-1

| Sample Layers | Asbestos Content |
|--|------------------------------------|
| White Joint Compound | ND |
| Brown/White Drywall | ND |
| Composite Non-Asbestos Content: | 10% Cellulose < 1% Glass Fibers |
| Sample Composite Homogeneity: | Good |

Location: 12

Lab ID-Version‡: 20073254-1

| Sample Layers | Asbestos Content |
|--|------------------------------------|
| White Joint Compound | ND |
| Brown/White Drywall | ND |
| Composite Non-Asbestos Content: | 10% Cellulose < 1% Glass Fibers |
| Sample Composite Homogeneity: | Good |

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. The Company reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

All components not quantified as asbestos content and non-asbestos content are considered to be non-fibrous matrix components. Matrix components may include, but are not limited to, gypsum, paint, silicate minerals, vinyl, binder, calcium carbonate, tar, and foam.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Pearson Environmental
C/O: Chris Pearson
Re: Courthouse; 1801 23rd Avenue

Date of Submittal: 04-15-2025
Date of Receipt: 04-15-2025
Date of Report: 04-15-2025

ASBESTOS PLM REPORT

Location: 13

Lab ID-Version‡: 20073255-1

| Sample Layers | Asbestos Content |
|--|------------------------------------|
| Brown/White Drywall | ND |
| Composite Non-Asbestos Content: | 10% Cellulose < 1% Glass Fibers |
| Sample Composite Homogeneity: | Good |

Comments: No Joint Compound Present.

Location: 14

Lab ID-Version‡: 20073256-1

| Sample Layers | Asbestos Content |
|--|------------------------------------|
| Brown/White Drywall | ND |
| Composite Non-Asbestos Content: | 10% Cellulose < 1% Glass Fibers |
| Sample Composite Homogeneity: | Good |

Comments: No Joint Compound Present.

Location: 15

Lab ID-Version‡: 20073257-1

| Sample Layers | Asbestos Content |
|--|------------------------------------|
| White Joint Compound | ND |
| Brown/White Drywall | ND |
| Composite Non-Asbestos Content: | 10% Cellulose < 1% Glass Fibers |
| Sample Composite Homogeneity: | Good |

Location: 16

Lab ID-Version‡: 20073258-1

| Sample Layers | Asbestos Content |
|--|------------------------------------|
| Brown/White Drywall | ND |
| Composite Non-Asbestos Content: | 10% Cellulose < 1% Glass Fibers |
| Sample Composite Homogeneity: | Good |

Comments: No Joint Compound Present.

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. The Company reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

All components not quantified as asbestos content and non-asbestos content are considered to be non-fibrous matrix components. Matrix components may include, but are not limited to, gypsum, paint, silicate minerals, vinyl, binder, calcium carbonate, tar, and foam.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Pearson Environmental
C/O: Chris Pearson
Re: Courthouse; 1801 23rd Avenue

Date of Submittal: 04-15-2025
Date of Receipt: 04-15-2025
Date of Report: 04-15-2025

ASBESTOS PLM REPORT

Location: 17

Lab ID-Version‡: 20073259-1

| Sample Layers | Asbestos Content |
|--|------------------------------------|
| Brown/White Drywall | ND |
| Composite Non-Asbestos Content: | 10% Cellulose < 1% Glass Fibers |
| Sample Composite Homogeneity: | Good |

Comments: No Joint Compound Present.

Location: 18

Lab ID-Version‡: 20073260-1

| Sample Layers | Asbestos Content |
|--|------------------------------------|
| White Joint Compound | ND |
| Brown/White Drywall | ND |
| Composite Non-Asbestos Content: | 10% Cellulose < 1% Glass Fibers |
| Sample Composite Homogeneity: | Good |

Location: 19

Lab ID-Version‡: 20073261-1

| Sample Layers | Asbestos Content |
|--|------------------------------------|
| Brown/White Drywall | ND |
| Composite Non-Asbestos Content: | 10% Cellulose < 1% Glass Fibers |
| Sample Composite Homogeneity: | Good |

Comments: No Joint Compound Present.

Location: 20

Lab ID-Version‡: 20073262-1

| Sample Layers | Asbestos Content |
|--|------------------------------------|
| White Joint Compound | ND |
| Brown/White Drywall | ND |
| Composite Non-Asbestos Content: | 10% Cellulose < 1% Glass Fibers |
| Sample Composite Homogeneity: | Good |

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. The Company reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

All components not quantified as asbestos content and non-asbestos content are considered to be non-fibrous matrix components. Matrix components may include, but are not limited to, gypsum, paint, silicate minerals, vinyl, binder, calcium carbonate, tar, and foam.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Pearson Environmental
C/O: Chris Pearson
Re: Courthouse; 1801 23rd Avenue

Date of Submittal: 04-15-2025
Date of Receipt: 04-15-2025
Date of Report: 04-15-2025

ASBESTOS PLM REPORT

Location: 21

Lab ID-Version‡: 20073263-1

| Sample Layers | Asbestos Content |
|--|------------------------------------|
| Brown/White Drywall | ND |
| Composite Non-Asbestos Content: | 10% Cellulose < 1% Glass Fibers |
| Sample Composite Homogeneity: | Good |

Comments: No Joint Compound Present.

Location: 22

Lab ID-Version‡: 20073264-1

| Sample Layers | Asbestos Content |
|--------------------------------------|------------------|
| Yellow Mastic | ND |
| Beige Floor Tile | 3% Chrysotile |
| Black Mastic | 5% Chrysotile |
| Sample Composite Homogeneity: | Good |

Location: 23

Lab ID-Version‡: 20073265-1

| Sample Layers | Asbestos Content |
|--------------------------------------|------------------|
| Yellow Mastic | ND |
| White Floor Tile | 4% Chrysotile |
| Black Mastic | 5% Chrysotile |
| Sample Composite Homogeneity: | Good |

Location: 24

Lab ID-Version‡: 20073266-1

| Sample Layers | Asbestos Content |
|--|------------------------------------|
| White Joint Compound | ND |
| Brown/White Drywall | ND |
| Composite Non-Asbestos Content: | 10% Cellulose < 1% Glass Fibers |
| Sample Composite Homogeneity: | Good |

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. The Company reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

All components not quantified as asbestos content and non-asbestos content are considered to be non-fibrous matrix components. Matrix components may include, but are not limited to, gypsum, paint, silicate minerals, vinyl, binder, calcium carbonate, tar, and foam.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Eurofins Built Environment Testing Central, LLC

3113 Red Bluff Road, Pasadena, TX 77503

713-290-0223 www.eurofinsus.com/Built

Client: Pearson Environmental
C/O: Chris Pearson
Re: Courthouse; 1801 23rd Avenue

Date of Submittal: 04-15-2025

Date of Receipt: 04-15-2025

Date of Report: 04-15-2025

ASBESTOS PLM REPORT

PROJECT ANALYST AND SIGNATORY REPORT

Project Analyst



Analyst: Duane Salinas

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. The Company reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

