



## State of Mississippi



### WATER POLLUTION CONTROL PERMIT

To Operate a Wastewater Disposal System with No Discharge

#### **THIS CERTIFIES**

Robby Pickett Rental Property  
6430 Kewanee Road  
Toomsuba, MS  
Lauderdale County

has been granted permission to operate a wastewater disposal system in accordance with the limitations and conditions set forth in this permit. This permit is issued in accordance with the provisions of the Mississippi Water Pollution Control Law (Section 49-17-1 et seq., Mississippi Code of 1972), and the regulations and standards adopted and promulgated thereunder.

**Mississippi Environmental Quality Permit Board**

---

**Mississippi Department of Environmental Quality**

Issued/Modified:

Permit No. MSU224005

Expires:

Agency Interest # 86673

\*\*\* Draft Permit \*\*\*

## Table of Contents

|                             |     |
|-----------------------------|-----|
| Subject Item Inventory..... | i   |
| Facility Requirements.....  | 1   |
| General Information.....    | A-1 |
| Other Relevant Documents:   |     |

## To Operate a Wastewater Disposal System with No Discharge

Robby Pickett Rental Property

Subject Item Inventory

Permit Number:MSU224005

Activity ID No.: PER20240001

### Subject Item Inventory:

| ID      | Designation | Description        |
|---------|-------------|--------------------|
| AI86673 | MSU224005   |                    |
| RPNT1   | MSU224005   | No Discharge (SOP) |

### KEY

ACT = Activity

AREA = Area

CONT = Control Device

IA = Insignificant Activity

MAFO = Animal Feeding Operation

RPNT = Release Point

WDPT = Withdrawal Point

AI = Agency Interest

CAFO = Concentrated Animal Feeding Operation

EQPT = Equipment

IMPD = Impoundment

PCS = PCS

TRMT = Treatment

\*\*\* Draft Permit \*\*\*

## To Operate a Wastewater Disposal System with No Discharge

Robby Pickett Rental Property  
Facility Requirements  
Permit Number:MSU224005  
Activity ID No.: PER20240001

**AI0000086673 (MSU224005):**

### Narrative Requirements:

---

| Condition No. | Condition   |
|---------------|---|
| T-1           | The Office of Pollution Control must concur with plans and specifications for the installation or modification of the wastewater treatment facility and sewer collection system prior to the commencement of construction. After the completion of the project, the permittee must, through a letter signed by a professional engineer, certify to the Office of Pollution Control that the project has been constructed in accordance with submitted plans and specifications. If any changes to the initially reviewed plans and specifications are made, "as-built" drawings with a list of all changes must also be submitted. [11 Miss. Admin. Code Pt. 6, Ch. 1, Subch. 1.] |
| T-2           | The on-site disposal system must be installed in accordance with the Department of Health standards by a person licensed by the Department of Health or a registered engineer. [11 Miss. Admin. Code Pt. 6, Ch. 1, Subch. 1.]   |
| T-3           | Facility Expansion and/or Modification<br><br>Any expansion or modification resulting in increased wastewater flow and/or strength must receive prior approval of system expansion and a permit modification from the Environmental Quality Permit Board. Prior approval from OPC must be obtained before making any alterations to the approved disposal system. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(14).]   |
| T-4           | No Discharge of Wastewater to Surface Water<br><br>There shall be no discharge of wastewater to waters of the State, as defined in the Mississippi Water Pollution Control Law, 49-17-5(f), except as provided in the bypassing condition in this permit. [11 Miss. Admin. Code Pt. 6, R. 1.1.1.B.]   |
| T-5           | Bypassing<br><br>Any diversion from or bypass of the on-site disposal system is prohibited, except where unavoidable to prevent loss of life or severe property damage. The permittee shall notify the Mississippi Environmental Quality Permit Board in writing of each such diversion or bypass in advance where practicable but in any case, within 72 hours of the diversion or bypass, and shall submit to the permit Board a plan to prevent recurrence of the diversion or bypass within thirty (30) days of the incident. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(20).]   |

## To Operate a Wastewater Disposal System with No Discharge

Robby Pickett Rental Property  
Facility Requirements  
Permit Number:MSU224005  
Activity ID No.: PER20240001

Page 2 of 2

### AI0000086673 (continued):

#### Narrative Requirements:

---

| Condition No. | Condition  |
|---------------|--|
| T-6           | <p>Proper Operation, Maintenance and Replacement</p> <p>The permittee shall at all times maintain in good working order and operate as efficiently as possible all parts of the disposal system and other equipment installed or used to comply with this permit. Should part of the disposal system fail, the permittee must immediately make needed repairs and/or system modifications. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(18).]</p> |
| T-7           | <p>If the disposal system includes an aerobic mechanical plant, the plant and disposal system must be inspected once every six-(6) months by a class I certified Mississippi Wastewater Operator or by an authorized and trained representative of the mechanical plant manufacturer. Inspection reports shall be submitted to OPC in January and July of each year. [11 Miss. Admin. Code Pt. 6, Ch. 1, Subch. 1.]</p>                      |
| T-8           | <p>Septic tanks must be cleaned out when necessary, about every 3 to 5 years. The septic tank pumper must be licensed by the Department of Health. [11 Miss. Admin. Code Pt. 6, Ch. 1, Subch. 1.]</p>  |
| T-9           | <p>There shall be no vehicular traffic allowed over any part of the on-site disposal system unless that part of the system is designed and constructed to support the weight. [11 Miss. Admin. Code Pt. 6, Ch. 1, Subch. 1.]</p>   |
| T-10          | <p>Connection shall be made to a sanitary sewer system when a system is available in the area. Upon such connection, use of the on-site disposal system shall be terminated. [11 Miss. Admin. Code Pt. 6, Ch. 1, Subch. 1.]</p>  |
| T-11          | <p>Closure Requirements</p> <p>Should the permittee decide to permanently close the premises that generates the wastewater, he shall notify the Permit Board no later than 90 days prior to doing so. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(18).]</p>  |
| T-12          | <p>Transfer of Ownership or Control</p> <p>This permit is non-transferable except by Permit Board action. [11 Miss. Admin. Code Pt. 6, R. 1.1.5.C.]</p>  |

\*\*\* Draft Permit \*\*\*

## GENERAL INFORMATION

Robby Pickett Rental Property  
6430 Kewanee Road  
Toomsba, MS  
Lauderdale County

### Alternate/Historic Identifiers

| ID    | Alternate/Historic Name       | User Group                 | Start Date | End Date |
|-------|-------------------------------|----------------------------|------------|----------|
| 86673 | Robby Pickett Rental Property | Official Site Name         | 6/6/2024   |          |
|       | Branch                        | Branches Group - Municipal | 6/6/2024   |          |

**Basin:** Pascagoula River Basin

### Location Description:

\*\*\* Draft Permit \*\*\*