

MISSISSIPPI ASBESTOS DEMOLITION/RENOVATION NOTIFICATION FORM

Mail notification to: MDEQ Asbestos and Lead Branch, 515 E. Amite Street, Jackson, MS 39201

MDEQ Use Only: <input checked="" type="checkbox"/> Email <input type="checkbox"/> Mail <input type="checkbox"/> Hand Delivery		Postmark (mail only)	Date Received 02-07-2024	AI Number
I. Type of Notification (O=Original R=Revised C=Canceled A= Annual) Original				
II. TYPE OF OPERATION (D=Demo O= Ordered Demo R=Renovation E=Emer. Renovation) Demo				
III. FACILITY DESCRIPTION (Include building name, number and floor or room number)				
Bldg. Name: Old City Hall				
Address: 304 Hwy 51				
City: Ridgeland	State: MS	Zip: 39157	County: Madison	
Site Location:		Tel:		
Building Size: 15,000	# of Floors: 1	Age in Years: 35		
Present Use: unoccupied	Prior Use: City Hall			
IV. FACILITY INFORMATION (Identify owner, asbestos removal contractor, and other operator)				
OWNER NAME: City of Ridgeland				
Address: P.O. Box 217				
City: Ridgeland	State: MS	Zip: 39158		
Contact: Alan Hart	Tel: 601-668-0510			
ASBESTOS REMOVAL CONTRACTOR: Eagle Construction				
Address: 1450 Old Brandon Rd				
City: Brandon	State: MS	Zip: 39232		
Contact: Chuck Womack	Tel: 601-940-5411			
Certification Number: ABC-1799	Expiration Date: 3-3-24			
OTHER OPERATOR: Faircloth Demolition				
Address: P.O. Box 1296				
City: Clinton	State: MS	Zip: 39060		
Contact: Mark Parkman	Tel: 601-573-3762			
V. WAS SITE INSPECTED TO DETERMINE PRESENCE OF ASBESTOS? (Yes/No): Yes				
WAS ASBESTOS PRESENT? (Yes/No): Yes		Inspection Date: 1-29-24		
Inspector: Chuck Womack	Certification Number: ABI2432	Expiration Date: 12-7-24		
VI. SUSPECT MATERIALS SAMPLED AND PROCEDURES USED TO DETECT THE PRESENCE OF ASBESTOS MATERIAL: PLM - linoleum, vct, cove base, sheetrockwalls, ceiling tiles, carpet adhesive, door-window caulk, stucco, built up roofing, roof insulation, roof deck, ext. brick and mortar				
VII. QUANTITY OF RACM TO BE REMOVED: 1800 sf linoleum and 100 lf of caulking				
Pipes (LN FT):	Surface Area (SQ FT):	Volume of Facility Components (CU FT):		
VIII. QUANTITY OF NONFRIABLE ASBESTOS NOT REMOVED:				
Category I:		Category II:		
IX. SCHEDULED DATES ASBESTOS REMOVAL (MM/DD/YY) Start: 2/8/24			Complete: 2/11/24	
X. SCHEDULED DATES DEMO/RENOVATION (MM/DD/YY) Start: 2/12/24			Complete: 2/21/24	

XI. DESCRIPTION OF PLANNED DEMOLITION OR RENOVATION WORK, AND METHOD(S) TO BE USED:

demo with trackhoe

XII. DESCRIPTION OF WORK PRACTICES AND ENGINEERING CONTROLS TO BE USED TO PREVENT EMISSIONS OF ASBESTOS AT THE DEMOLITION OR RENOVATION SITE:

wet demo

XIII. WASTE TRANSPORTER #1

Name: American Disposal Service

Address: P.O. Box 1296

City: Clinton

State: MS

Zip: 39060

Contact Person: Mark Parkman

Tel: 601-573-3762

WASTE TRANSPORTER #2

Name: Eagle Construction

Address: 1450 Old Brandon Rd

City: Flowood

State: MS

Zip: 39232

Contact Person: Chuck Womack

Tel: 601-940-5411

XIV. WASTE DISPOSAL SITE

Name: Little Dixie Landfill

Faircloth Rubbish Landfill

Address: 1716 North Counry Line Rd

1312 Springridge Rd Clinton, MS 39056

City: Ridgeland

State: MS

Zip: 39157

Contact Person: Mark Parkman

Tel: 601-573-3762

XV. IF DEMOLITION ORDERED BY A GOVERNMENT AGENCY, PLEASE IDENTIFY THE AGENCY BELOW:

Name: Alan Hart

Title: Public Works Director

Authority: City of Ridgeland

Date of Order (MM/DD/YY): 1-17-24

Date Ordered to Begin (MM/DD/YY): ASAP

XVI. FOR EMERGENCY RENOVATIONS:

Date and Hour of Emergency (MM/DD/YY): 1-15-14 7:00 am

Description of the sudden unexpected event:

building was partially demolished by mistake

Explanation of how the event caused unsafe conditions or would cause equipment damage or an unreasonable financial burden:

Building partially demolished and is total loss

XVII. DESCRIPTION OF PROCEDURES TO BE FOLLOWED IN THE EVENT THAT UNEXPECTED ASBESTOS IS FOUND OR PREVIOUSLY NONFRIABLE ASBESTOS MATERIAL BECOMES CRUMBLED, PULVERIZED, OR REDUCED TO POWDER:

stop work and call asbestos contractor

XVIII. I CERTIFY THAT AN INDIVIDUAL TRAINED IN THE PROVISIONS OF THIS REGULATION (40 CFR PART 61, SUBPART M) WILL BE ONSITE DURING THE DEMOLITION OR RENOVATION, AND EVIDENCE THAT THE REQUIRED TRAINING HAS BEEN ACCOMPLISHED BY THIS PERSON WILL BE AVAILABLE FOR INSPECTION DURING NORMAL BUSINESS HOURS.

Mark Parkman

Type or Print Name

(Signature of Owner/Operator)

2/7/24

(Date)

XIX. I CERTIFY THAT THE ABOVE INFORMATION IS CORRECT:

Mark Parkman

Type or Print Name

(Signature of Owner/Operator)

2/7/24

(Date)



Environmental Hazards Services, L.L.C.
7469 Whitepine Rd
Richmond, VA 23237
Telephone: 800.347.4010

Asbestos Bulk Analysis Report

Report Number: 24-02-00194

Client: Chuck Womack
6395 Jimmy Williams Rd.
Clinton, MS 39056

Received Date: 02/01/2024

Analyzed Date: 02/05/2024

Reported Date: 02/05/2024

Project/Test Address: Old Ridgeland City Hall; 304 US 51 Ridgeland, MS 39157

Client Number:
25-6205

Fax Number:
601-924-6056

Laboratory Results

Lab Sample Number	Client Sample Number	Layer Type	Lab Gross Description	Asbestos	Other Materials
24-02-00194-001A	1	Linoleum	Brown Vinyl-Like; White Fibrous; Inhomogenous	20% Chrysotile	80% Non-Fibrous
Total Asbestos: 20%					
Chrysotile present in fibrous backing.					
24-02-00194-001B	1	Mastic	Yellow Brittle Adhesive; Homogenous	2% Chrysotile	98% Non-Fibrous
Total Asbestos: 2%					
Possible contamination from fibrous backing.					
24-02-00194-002A	2	Linoleum		Did Not Analyze (Positive Stop)	
24-02-00194-002B	2	Mastic		Did Not Analyze (Positive Stop)	
24-02-00194-003A	3	Linoleum		Did Not Analyze (Positive Stop)	
24-02-00194-003B	3	Mastic		Did Not Analyze (Positive Stop)	

Environmental Hazards Services, L.L.C

Client Number: 25-6205

Report Number: 24-02-00194

Project/Test Address: Old Ridgeland City Hall; 304 US 51
Ridgeland, MS 39157

Lab Sample Number	Client Sample Number	Layer Type	Lab Gross Description	Asbestos	Other Materials
24-02-00194-004A	4	Tile	Light Brown Vinyl-Like; Homogenous	NAD	100% Non-Fibrous
24-02-00194-004B	4	Mastic	Black Adhesive; Homogenous	NAD	100% Non-Fibrous
24-02-00194-005A	5	Tile	Light Brown Vinyl-Like; Homogenous	NAD	100% Non-Fibrous
24-02-00194-005B	5	Mastic	Black Adhesive; Homogenous	NAD	100% Non-Fibrous
24-02-00194-006A	6	Tile	Light Brown Vinyl-Like; Homogenous	NAD	100% Non-Fibrous
24-02-00194-006B	6	Mastic	Black Adhesive; Homogenous	NAD	100% Non-Fibrous
24-02-00194-007A	7	Cove Base	Light Brown Rubbery; Homogenous	NAD	100% Non-Fibrous
24-02-00194-007B	7	Mastic	Yellow Adhesive; Homogenous	NAD	100% Non-Fibrous

Environmental Hazards Services, L.L.C

Client Number: 25-6205

Report Number: 24-02-00194

Project/Test Address: Old Ridgeland City Hall; 304 US 51
Ridgeland, MS 39157

Lab Sample Number	Client Sample Number	Layer Type	Lab Gross Description	Asbestos	Other Materials
24-02-00194-007C	7	Joint Comp.	White Chalky; Homogenous	NAD	100% Non-Fibrous
24-02-00194-008A	8	Cove Base	Light Brown Rubbery; Homogenous	NAD	100% Non-Fibrous
24-02-00194-008B	8	Mastic	Yellow Adhesive; Homogenous	NAD	100% Non-Fibrous
24-02-00194-008C	8	Joint Comp.	White Chalky; Homogenous	NAD	100% Non-Fibrous
24-02-00194-009A	9	Cove Base	Light Brown Rubbery; Homogenous	NAD	100% Non-Fibrous
24-02-00194-009B	9	Mastic	Yellow Adhesive; Homogenous	NAD	100% Non-Fibrous
24-02-00194-009C	9	Joint Comp.	White Chalky; Homogenous	NAD	100% Non-Fibrous
24-02-00194-010A	10	Cove Base	Pale Yellow Rubbery; Homogenous	NAD	100% Non-Fibrous

Environmental Hazards Services, L.L.C

Client Number: 25-6205

Report Number: 24-02-00194

Project/Test Address: Old Ridgeland City Hall; 304 US 51
Ridgeland, MS 39157

Lab Sample Number	Client Sample Number	Layer Type	Lab Gross Description	Asbestos	Other Materials
24-02-00194-010B	10	Mastic	Brown Brittle; Homogenous	NAD	100% Non-Fibrous
24-02-00194-011A	11	Cove Base	Pale Yellow Rubbery; Homogenous	NAD	100% Non-Fibrous
24-02-00194-011B	11	Mastic	Brown Brittle; Homogenous	NAD	100% Non-Fibrous
24-02-00194-012A	12	Cove Base	Pale Yellow Rubbery; Homogenous	NAD	100% Non-Fibrous
24-02-00194-012B	12	Mastic	Brown Adhesive; Homogenous	NAD	100% Non-Fibrous
24-02-00194-013	13		Beige Fibrous; White Paint; Homogenous	NAD	65% Cellulose 20% Fibrous Glass 15% Non-Fibrous
24-02-00194-014	14		Beige Fibrous; White Paint; Homogenous	NAD	65% Cellulose 20% Fibrous Glass 15% Non-Fibrous
24-02-00194-015	15		Beige Fibrous; White Paint; Homogenous	NAD	65% Cellulose 20% Fibrous Glass 15% Non-Fibrous

Environmental Hazards Services, L.L.C

Client Number: 25-6205

Report Number: 24-02-00194

Project/Test Address: Old Ridgeland City Hall; 304 US 51
Ridgeland, MS 39157

Lab Sample Number	Client Sample Number	Layer Type	Lab Gross Description	Asbestos	Other Materials
24-02-00194-016	16		Tan Powdery; Brown Fibrous; White Chalky; Inhomogenous	NAD	15% Cellulose 85% Non-Fibrous
24-02-00194-017	17		Tan Powdery; Brown Fibrous; White Chalky; Inhomogenous	NAD	18% Cellulose 82% Non-Fibrous
24-02-00194-018	18		Tan Powdery; Brown Fibrous; White Chalky; Inhomogenous	NAD	15% Cellulose 85% Non-Fibrous
24-02-00194-019	19		Yellow Pliable Adhesive; Homogenous	NAD	5% Synthetic 95% Non-Fibrous
24-02-00194-020	20		Yellow Adhesive; Homogenous	NAD	2% Synthetic 98% Non-Fibrous
24-02-00194-021	21		Yellow Adhesive; Homogenous	NAD	2% Synthetic 98% Non-Fibrous
24-02-00194-022	22		Gray Soft; Homogenous	3% Chrysotile	5% Polyethylene 92% Non-Fibrous
Total Asbestos: 3%					
24-02-00194-023	23			Did Not Analyze (Positive Stop)	

Environmental Hazards Services, L.L.C

Client Number: 25-6205

Report Number: 24-02-00194

Project/Test Address: Old Ridgeland City Hall; 304 US 51
Ridgeland, MS 39157

Lab Sample Number	Client Sample Number	Layer Type	Lab Gross Description	Asbestos	Other Materials
24-02-00194-024	24			Did Not Analyze (Positive Stop)	
24-02-00194-025	25		White Granular; Gray Cementitious; White Foam; Inhomogenous	NAD	20% Fibrous Glass 80% Non-Fibrous
24-02-00194-026	26		White Granular; Gray Cementitious; White Foam; Inhomogenous	NAD	20% Fibrous Glass 80% Non-Fibrous
24-02-00194-027	27		White Granular; Gray Cementitious; White Foam; Inhomogenous	NAD	20% Fibrous Glass 80% Non-Fibrous
24-02-00194-028	28		Gray Aggregate; Black Tar-Like; Inhomogenous	NAD	15% Synthetic 85% Non-Fibrous
24-02-00194-029	29		Gray Aggregate; Black Tar-Like; Inhomogenous	NAD	15% Synthetic 85% Non-Fibrous
24-02-00194-030	30		Gray Aggregate; Black Tar-Like; Inhomogenous	NAD	15% Synthetic 85% Non-Fibrous

Environmental Hazards Services, L.L.C

Client Number: 25-6205

Report Number: 24-02-00194

Project/Test Address: Old Ridgeland City Hall; 304 US 51
Ridgeland, MS 39157

Lab Sample Number	Client Sample Number	Layer Type	Lab Gross Description	Asbestos	Other Materials
24-02-00194-031	31		Black Tar-Like; Black Fibrous; Inhomogenous	NAD	20% Cellulose 10% Fibrous Glass 10% Synthetic 60% Non-Fibrous
24-02-00194-032	32		Black Tar-Like; Black Fibrous; Inhomogenous	NAD	20% Cellulose 10% Fibrous Glass 10% Synthetic 60% Non-Fibrous
24-02-00194-033	33		Black Tar-Like; Black Fibrous; Inhomogenous	NAD	20% Cellulose 10% Fibrous Glass 10% Synthetic 60% Non-Fibrous
24-02-00194-034	34		White Foam; Homogenous	NAD	100% Non-Fibrous
24-02-00194-035	35		White Foam; Homogenous	NAD	100% Non-Fibrous
24-02-00194-036	36		White Foam; Homogenous	NAD	100% Non-Fibrous
24-02-00194-037	37		Gray Granular; Gold Platelets; Inhomogenous	Trace <1% Trem/Actin*	100% Non-Fibrous
Total Asbestos: Trace <1%					
<1% Trem/Actin series asbestos present throughout.					
24-02-00194-038	38		Gray Granular; Gold Platelets; Inhomogenous	Trace <1% Trem/Actin*	100% Non-Fibrous
Total Asbestos: Trace <1%					
<1% Trem/Actin series asbestos present throughout.					

Environmental Hazards Services, L.L.C

Client Number: 25-6205

Report Number: 24-02-00194

Project/Test Address: Old Ridgeland City Hall; 304 US 51
Ridgeland, MS 39157

Lab Sample Number	Client Sample Number	Layer Type	Lab Gross Description	Asbestos	Other Materials
24-02-00194-039	39		Gray Granular; Gold Platelets; Inhomogenous	Trace <1% Trem/Actin*	100% Non-Fibrous
Total Asbestos: Trace <1%					
<1% Trem/Actin series asbestos present throughout.					
24-02-00194-040	40		Tan Cementitious; Homogenous	NAD	100% Non-Fibrous
24-02-00194-041	41		Tan Cementitious; Homogenous	NAD	100% Non-Fibrous
24-02-00194-042	42		Tan Cementitious; Homogenous	NAD	100% Non-Fibrous
24-02-00194-043	43		Gray Cementitious; Homogenous	NAD	100% Non-Fibrous
24-02-00194-044	44		Gray Cementitious; Homogenous	NAD	100% Non-Fibrous
24-02-00194-045	45		Gray Cementitious; Homogenous	NAD	100% Non-Fibrous

Environmental Hazards Services, L.L.C

Client Number: 25-6205
Project/Test Address: Old Ridgeland City Hall; 304 US 51
Ridgeland, MS 39157

Report Number: 24-02-00194

Lab Sample Number	Client Sample Number	Layer Type	Lab Gross Description	Asbestos	Other Materials
-------------------	----------------------	------------	-----------------------	----------	-----------------

QC Sample: 96-M22012-4, 97-M22013-2

QC Blank: SRM 1866 Fiberglass

Reporting Limit: 1% Asbestos

Method: EPA Method 600/R-93/116, EPA Method 600/M4-82-020

Analyst: Kay Harris, Angel McDaniel

Reviewed By Authorized Signatory:



Tasha Eaddy
QA/QC Clerk

These results are based on a comparative visual estimate. The condition of the samples analyzed was acceptable upon receipt per laboratory protocol unless otherwise noted on this report. Each distinct component in an inhomogeneous sample was analyzed separately and reported as a composite. Results represent the analysis of samples submitted by the client. Sample location, description, area, volume, etc., was provided by the client. This report cannot be used by the client to claim product endorsement by NVLAP or any agency of the U.S. Government. This report shall not be reproduced except in full, without the written consent of the Environmental Hazards Service, L.L.C. California Certification #2319 NY ELAP #11714 NVLAP #101882-0 VELAP 460172. All information concerning sampling location, date, and time can be found on Chain-of-Custody. Environmental Hazards Services, L.L.C. does not perform any sample collection.

Environmental Hazards Services, L.L.C. recommends reanalysis by point count (for more accurate quantification) or Transmission Electron Microscopy (TEM), (for enhanced detection capabilities) for materials regulated by EPA NESHAP (National Emission Standards for Hazardous Air Pollutants) and found to contain less than ten percent (<10%) asbestos by polarized light microscopy (PLM). Both services are available for an additional fee.

400 Point Count Analysis, where noted, performed per EPA Method 600/R-93/116 with a Reporting Limit of 0.25%.

* All California samples analyzed by Polarized Light Microscopy, EPA Method 600/M4-82-020, Dec. 1982.

LEGEND: NAD = no asbestos detected

ENVIRONMENTAL HAZARDS SERVICES, LLC

Asbestos Chain of Custody Form

Page 1 of 2

Company Name		Chuck Womack		Account #		25-6205	
Company Address		P.O. Box 65		City/State/Zip		Tougaloo, MS 39174	
Phone		601-940-5411		Email		cuzusm@aol.com	
Project Name/Test Address		Old Ridgeland City Hall - 304 US 51 Ridgeland, MS 39157					
PO Number				Collected By		C. Womack	
Turn-Around Time		<input type="radio"/> 5 Day <input type="radio"/> 3 Day <input checked="" type="radio"/> 2 Day <input type="radio"/> 1 Day <input type="radio"/> Same Day / Weekend - Must Call Ahead					
<input type="checkbox"/> PLM New York Protocol		<input type="checkbox"/> PLM New Jersey Protocol		<input type="checkbox"/> PLM South Carolina Protocol			

LAB NUMBER	Client Sample ID	Homogeneous Area	Positive Stop	Collection Date & Time	BULK				AIR				COMMENTS	
					PLM	Point Count 400	Point Count 1000	TEM Bulk	PCM	TEM AHERA	NIOSH 7402	Time In Total Minutes		Flow Rate In L/Min
1	1		X	1-29-24	X									Brown linoluem
2	2		X	"	X									"
3	3		X	"	X									"
4	4		X	"	X									Tan ft & m
5	5		X	"	X									"
6	6		X	"	X									"
7	7		X	"	X									Tan cove base
8	8		X	"	X									"
9	9		X	"	X									"
10	10		X	"	X									Yellow cove base
11	11		X	"	X									"
12	12		X	"	X									"
13	13		X	"	X									Ceiling tile
14	14		X	"	X									"
15	15		X	"	X									"

Released By:	Chuck Womack	Date:	1-31-24	Time:	12:00 PM
Signature:	<i>Chuck Womack</i>				

LAB USE ONLY - BELOW THIS LINE

Received By: *DBowen*
 Signature: *DB*
 Date: 2.1.24 Time: 333 ☐ AM ☐ PM
☐ Portal Contact Added

24-02-00194



Due Date:
02/05/2024

(Monday)

AE

7469 WHITEPINE RD, RICHMOND, VA 23237 (800)-347-4010

RESULTS VIA CLIENT PORTAL AVAILABLE @ www.leadlab.com

APM *45PLM*

ENVIRONMENTAL HAZARDS SERVICES, LLC

Asbestos Chain of Custody Form

Page 2 of 2

LAB NUMBER	Client Sample ID	Homogeneous Area	Positive Stop	Collection Date & Time	BULK				AIR				COMMENTS	
					PLM	Point Count 400	Point Count 1000	TEM Bulk	PCM	TEM AHERA	NIOSH 7402	Time In Total Minutes		Flow Rate In L/Min
16	16		X	1-29-24	X									Sheetrock walls
17	17		X	"	X									"
18	18		X	"	X									"
19	19		X	"	X									Carpet glue
20	20		X	"	X									"
21	21		X	"	X									"
22	22		X	"	X									Door/window caulk
23	23		X	"	X									"
24	24		X	"	X									"
25	25		X	"	X									Stucco
26	26		X	"	X									"
27	27		X	"	X									"
28	28		X	"	X									Built-up roofing 1st
29	29		X	"	X									"
30	30		X	"	X									"
31	31		X	"	X									Built-up roofing 2nd
32	32		X	"	X									"
33	33		X	"	X									"
34	34		X	"	X									Roof insulation
35	35		X	"	X									"
36	36		X	"	X									"
37	37		X	"	X									Roofing Deck
38	38		X	"	X									"
39	39		X	"	X									"
40	40		X	"	X									Ext brick
41	41		X	"	X									"
42	42		X	"	X									"
43	43		X	"	X									Brick mortar
44	44		X	"	X									"
45	45		X	"	X									"

Received By: D Bowen

EHS Order #: 194

Signature: [Signature]

Date: 2.1.24 Time: 3:33

AM PM

