

STATE OF MISSISSIPPI AND FEDERALLY ENFORCEABLE AIR POLLUTION CONTROL

PERMIT

TO OPERATE AIR EMISSIONS EQUIPMENT AT A
SYNTHETIC MINOR SOURCE

THIS CERTIFIES THAT

MGC Terminal LLC
101 65th Avenue
Meridian, Mississippi
Lauderdale County

has been granted permission to operate air emissions equipment in accordance with emission limitations, monitoring requirements and conditions set forth herein. This permit is issued in accordance with the Federal Clean Air Act and the provisions of the Mississippi Air and Water Pollution Control Law (Section 49-17-1 et. seq., Mississippi Code of 1972), the regulations and standards adopted and promulgated thereunder, and the State Implementation Plan for operating permits for synthetic minor sources.

MISSISSIPPI ENVIRONMENTAL QUALITY PERMIT BOARD

AUTHORIZED SIGNATURE

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

Issued: January 28, 2021

Permit No.: 1460-00009

Modified: February 8, 2022, and DATE

Effective Date: As specified herein.

Expires: December 31, 2025

Draft/Proposed [8/12/2022]

Section 1.

A. GENERAL CONDITIONS

1. This permit is for air pollution control purposes only.
(Ref.: 11 Miss. Admin. Code Pt. 2, R. 2.1.D.)
2. This permit is a Federally-approved permit to operate a synthetic minor source as described in 11 Miss. Admin. Code Pt. 2, R. 2.4.D.
(Ref.: 11 Miss. Admin. Code Pt. 2, R. 2.4.D.)
3. Any activities not identified in the application are not authorized by this permit.
(Ref.: Miss. Code Ann. 49-17-29 1.b)
4. The knowing submittal of a permit application with false information may serve as the basis for the Permit Board to void the permit issued pursuant thereto or subject the applicant to penalties for constructing or operating without a valid permit.
(Ref.: 11 Miss. Admin. Code Pt. 2, R. 2.2.B(5).)
5. The issuance of a permit does not release the permittee from liability for constructing or operating air emissions equipment in violation of any applicable statute, rule, or regulation of state or federal environmental authorities.
(Ref.: 11 Miss. Admin. Code Pt. 2, R. 2.2.B(7).)
6. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit unless halting or reducing activity would create an imminent and substantial endangerment threatening the public health and safety of the lives and property of the people of this state.
(Ref.: 11 Miss. Admin. Code Pt. 2, R. 2.2.B(15)(a).)
7. The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.
(Ref.: 11 Miss. Admin. Code Pt. 2, R. 2.2.B(15)(c).)
8. The permittee shall allow the Mississippi Department of Environmental Quality Office of Pollution Control and the Mississippi Environmental Quality Permit Board and/or their authorized representatives, upon the presentation of credentials:
 - a. To enter upon the permittee's premises where an air emission source is located or in which any records are required to be kept under the terms and conditions of this permit, and
 - b. At reasonable times to have access to and copy any records required to be kept under the terms and conditions of this permit; to inspect any monitoring equipment or monitoring method required in this permit; and to sample any air emission.

(Ref.: Miss. Code Ann. 49-17-21)

9. Except for data determined to be confidential under the Mississippi Air & Water Pollution Control Law, all reports prepared in accordance with the terms of this permit shall be available for public inspection at the offices of the Mississippi Department of Environmental Quality Office of Pollution Control.

(Ref.: Miss. Code Ann. 49-17-39)

10. The provisions of this permit are severable. If any provision of this permit, or the application of any provision of this permit to any circumstances, is challenged or held invalid, the validity of the remaining permit provisions and/or portions thereof or their application to other persons or sets of circumstances, shall not be affected thereby.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 2.1.D(7).)

11. This permit does not authorize a modification as defined in Regulation 11 Miss. Admin. Code Pt. 2, Ch.2., "Permit Regulations for the Construction and/or Operation of Air Emission Equipment." A modification may require a Permit to Construct and a modification of this permit. Modification is defined as "Any physical change in or change in the method of operation of a facility which increases the actual emissions or the potential uncontrolled emissions of any air pollutant subject to regulation under the Federal Act emitted into the atmosphere by that facility or which results in the emission of any air pollutant subject to regulation under the Federal Act into the atmosphere not previously emitted. A physical change or change in the method of operation shall not include:

- a. Routine maintenance, repair, and replacement;
- b. Use of an alternative fuel or raw material by reason of an order under Sections 2(a) and (b) of the Federal Energy Supply and Environmental Coordination Act of 1974 (or any superseding legislation) or by reason of a natural gas curtailment plan pursuant to the Federal Power Act;
- c. Use of an alternative fuel by reason of an order or rule under Section 125 of the Federal Act;
- d. Use of an alternative fuel or raw material by a stationary source which:
 - (1) The source was capable of accommodating before January 6, 1975, unless such change would be prohibited under any federally enforceable permit condition which was established after January 6, 1975, pursuant to 40 CFR 52.21 or under regulations approved pursuant to 40 CFR Part 51, Subpart I, or 40 CFR 51.166; or
 - (2) The source is approved to use under any permit issued under 40 CFR 52.21 or under regulations approved pursuant to 40 CFR Part 51, Subpart I, or 40 CFR 51.166;
- e. An increase in the hours of operation or in the production rate unless such change would be prohibited under any federally enforceable permit condition which was

established after January 6, 1975, pursuant to 40 CFR 52.21 or under regulations approved pursuant to 40 CFR Part 51, Subpart I or 40 CFR 51.166; or

f. Any change in ownership of the stationary source.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 2.1.C(15).)

B. GENERAL OPERATIONAL CONDITIONS

1. Should the Executive Director of the Mississippi Department of Environmental Quality declare an Air Pollution Emergency Episode, the permittee will be required to operate in accordance with the permittee's previously approved Emissions Reduction Schedule or, in the absence of an approved schedule, with the appropriate requirements specified in Regulation, 11 Miss. Admin. Code Pt. 2, "Regulations for the Prevention of Air Pollution Emergency Episodes" for the level of emergency declared.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 2.10.)

2. Any diversion from or bypass of collection and control facilities is prohibited, except as provided for in 11 Miss. Admin. Code Pt. 2, R. 1.10., "Air Emission Regulations for the Prevention, Abatement, and Control of Air Contaminants."

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 1.10.)

3. Solids removed in the course of control of air emissions shall be disposed of in a manner such as to prevent the solids from becoming windborne and to prevent the materials from entering State waters without the proper environmental permits.

(Ref.: Miss. Code Ann. 49-17-29 1.a(i and ii))

4. Except as otherwise specified herein, the permittee shall be subject to the following provisions with respect to upsets, startups, and shutdowns.

a. Upsets

(1) For an upset defined in 11 Miss. Admin. Code Pt. 2, R. 1.2., the Commission may pursue an enforcement action for noncompliance with an emission standard or other requirement of an applicable rule, regulation, or permit. In determining whether to pursue enforcement action, and/or the appropriate enforcement action to take, the Commission may consider whether the source has demonstrated through properly signed contemporaneous operating logs or other relevant evidence the following:

(i) An upset occurred and that the source can identify the cause(s) of the upset;

(ii) The source was at the time being properly operated;

(iii) During the upset the source took all reasonable steps to minimize levels of emissions that exceeded the emission standard or other requirement of an applicable rule, regulation, or permit;

(iv) That within 5 working days of the time the upset began, the source submitted a written report to the Department describing the upset,

the steps taken to mitigate excess emissions or any other noncompliance, and the corrective actions taken and;

(v) That as soon as practicable but no later than 24 hours of becoming aware of an upset that caused an immediate adverse impact to human health or the environment beyond the source boundary or caused a general nuisance to the public, the source provided notification to the Department.

- (2) In any enforcement proceeding by the Commission, the source seeking to establish the occurrence of an upset has the burden of proof.
- (3) This provision is in addition to any upset provision contained in any applicable requirement.
- (4) These upset provisions apply only to enforcement actions by the Commission and are not intended to prohibit EPA or third party enforcement actions.

b. Startups and Shutdowns (as defined by 11 Miss. Admin. Code Pt. 2, R. 1.2.)

- (1) Startups and shutdowns are part of normal source operation. Emission limitations apply during startups and shutdowns unless source specific emission limitations or work practice standards for startups and shutdowns are defined by an applicable rule, regulation, or permit.
- (2) Where the source is unable to comply with existing emission limitations established under the State Implementation Plan (SIP) and defined in this regulation, 11 Mississippi Administrative Code, Part 2, Chapter 1, the Department will consider establishing source specific emission limitations or work practice standards for startups and shutdowns. Source specific emission limitations or work practice standards established for startups and shutdowns are subject to the requirements prescribed in 11 Miss. Admin. Code Pt. 2, R. 1.10.B(2)(a) through (e).
- (3) Where an upset as defined in Rule 1.2 occurs during startup or shutdown, see the upset requirements above.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 1.10.)

5. Compliance Testing: Regarding compliance testing:

- a. The results of any emissions sampling and analysis shall be expressed both in units consistent with the standards set forth in any Applicable Rules and Regulations or this permit and in units of mass per time.
- b. Compliance testing will be performed at the expense of the permittee.
- c. Each emission sampling and analysis report shall include but not be limited to the following:
 - (1) Detailed description of testing procedures;
 - (2) Sample calculation(s);

(3) Results; and

(4) Comparison of results to all Applicable Rules and Regulations and to emission limitations in the permit.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 2.6.B(3), (4), and (6).)

C. PERMIT RENEWAL / MODIFICATION / TRANSFER / TERMINATION

1. For renewal of this permit, the applicant shall make application not less than one-hundred eighty (180) days prior to the expiration date of the permit substantiated with current emissions data, test results or reports or other data as deemed necessary by the Mississippi Environmental Quality Permit Board. If the applicant submits a timely and complete application pursuant to this paragraph and the Permit Board, through no fault of the applicant, fails to act on the application on or before the expiration date of the existing permit, the applicant shall continue to operate the stationary source under the terms and conditions of the expired permit, which shall remain in effect until final action on the application is taken by the Permit Board. Permit expiration terminates the source's ability to operate unless a timely and complete renewal application has been submitted.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 2.8.)

2. The permittee shall furnish to the DEQ within a reasonable time any information the DEQ may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the DEQ copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee shall furnish such records to the DEQ along with a claim of confidentiality. The permittee may furnish such records directly to the Administrator along with a claim of confidentiality.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 2.2.B(15)(d).)

3. The permit and/or any part thereof may be modified, revoked, reopened, and reissued, or terminated for cause. Sufficient cause for a permit to be reopened shall exist when an air emissions stationary source becomes subject to Title V. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 2.2.B(15)(b).)

4. After notice and opportunity for a hearing, this permit may be modified, suspended, or revoked in whole or in part during its term for cause including, but not limited to:

- a. Persistent violation of any terms or conditions of this permit.
- b. Obtaining this permit by misrepresentation or failure to disclose fully all relevant facts; or
- c. A change in federal, state, or local laws or regulations that require either a temporary or permanent reduction or elimination of previously authorized air emission.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 2.2.C.)

5. This permit may only be transferred upon approval of the Mississippi Environmental Quality Permit Board.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 2.16.B.)

**SECTION 2
EMISSION POINT DESCRIPTION**

The permittee is authorized to operate air emissions equipment, as described in the following table.

Emission Point	Description
AA-001	1,780,283-gallon Gasoline Internal Floating Roof Storage Tank (liquid mounted resilient primary seal and rim mounted secondary seal). Built 1955, modified to IFR after 1977 (Ref. # MGC-NT31)
AA-002	1,035,943-gallon Gasoline Internal Floating Roof Storage Tank (liquid mounted resilient primary seal and rim mounted secondary seal) Built 1955, modified to IFR after 1977 (Ref. # MGC-NT32)
AA-003	652,546-gallon Gasoline Internal Floating Roof Storage Tank (liquid mounted resilient primary seal and rim mounted secondary seal) Built 1955, modified to IFR? after 1977 (Ref. # MGC-N-T33)
AA-004	652,546-gallon Diesel Internal Floating Roof Storage Tank Built 1955, modified to IFR after 1977 (Ref. Tank ID# MGC-N-T34)
AA-005	North Gasoline and Diesel loading rack with two bays, including piping and component leaks
AA-006	3,000 gallon-horizontal Additive tank. (Ref. # MGC-N-T91)
AA-007	3,000 gallon-horizontal Additive tank. (Ref. # MGC-N-T90)
AA-008	John Zink Vapor Combustion Unit (VCU) used to control gasoline emissions from the Emission Points AA-005 and AA-025 (Ref. # ZCT-3-8-45-X-218-X)
AA-009	314,354-gallon Ethanol Internal Floating Roof Storage Tank (vapor-mounted primary seal) Built 1941 (Ref. # MGC-S-T2)
AA-010	315,683-gallon Ethanol Internal Floating Roof Storage Tank (liquid-mounted primary seal) Built 1941 (Ref. # MGC-S-T3)
AA-011	828,605-gallon Diesel Internal Floating Roof Storage Tank (liquid-mounted primary seal) Built 1941 (Ref. # MGC-S-T6)
AA-012	1,483,480-gallon Diesel Internal Floating Roof Storage Tank (liquid-mounted primary seal) Built 1941 (Ref. # MGC-S-T7)
AA-013	1,275,942-gallon Diesel Fixed Roof Storage Tank Built 1964 (Ref. # MGC-S-T24)
AA-016	34,000-gallon Diesel Lubricity Additive Fixed Roof Storage Tank
AA-017	South Diesel loading rack with two bays, including piping and component leaks
AA-018	1,713,908-gallon Gasoline Internal Floating Roof Storage Tank (liquid mounted resilient primary seal and rim-mounted secondary seal) Built 2007 (Ref. # MGC-N-T35)
AA-019	188 hp Diesel-fired emergency generator
AA-020	188 hp Diesel-fired emergency generator
AA-021	550-gallon horizontal Red-Dye Diesel storage tank
AA-022	280-gallon horizontal Red-Dye Diesel storage tank
AA-023	4,225,125-gallon Diesel Internal Floating Roof Storage Tank (liquid mounted primary seal), Built 2017 (Ref. # MGC-S-T8)
AA-024	4,225,125-gallon Gasoline Internal Floating Roof Storage Tank (liquid mounted primary seal), Built 2017 (Ref. # MGC-S-T9)
AA-025	New Maples Gasoline and Diesel loading rack with four bays, including piping and component leaks
AA-026	90,000-gallon Butane pressurized storage tank

AA-027	22,038-gallon Reclaimed Fuel and Water Fixed Roof Storage Tank
AA-028	583 hp diesel-fired emergency generator
AA-029	583 hp-diesel fired emergency generator
AF-001	Fugitive Emissions

SECTION 3 EMISSION LIMITATIONS AND STANDARDS

Emission Point	Applicable Requirement	Condition Number(s)	Pollutant/Parameter	Limitation/Standard
Facility Wide	11 Miss. Admin. Code Pt. 2, R. 2.2.B(10).	3.1	Operational Restriction	≤ 400,000,000 gallons of gasoline/year
		3.2		≤ 600,000,000 gallons of total fuel/year
	11 Miss. Admin. Code Pt. 2, R. 1.3.A.	3.3	Opacity	≤ 40%
	11 Miss. Admin. Code Pt. 2, R. 1.3.B.	3.4		
	11 Miss. Admin. Code Pt. 2, R. 2.2.B(10).	3.5	VOC/HAP	Operate control equipment as efficiently as possible
	40 CFR 63, Subpart BBBBBB (National Emission Standards for Hazardous Air Pollutants for Source Category: Gasoline Distribution Bulk Terminals, Bulk Plants, and Pipeline Facilities) 40 CFR 63.11081(a)(1), Subpart BBBBBB	3.6	HAP	Applicability
AA-001 AA-002 AA-003 AA-018 AA-024	3.7	Design requirements		
AA-018 AA-024	40 CFR 60, Subpart Kb (Standards of Performance for Volatile Organic Liquid Storage Vessels for Which Construction, Reconstruction, or Modification Commenced after July 23, 1984)	3.8	VOC	Applicability
	40 CFR 60.110b(a), Subpart Kb 40 CFR 60.112b(a)(1), Subpart Kb	3.9		Internal floating roof specifications
AA-005 AA-008 AA-025	40 CFR 60, Subpart XX (Standards of Performance for Bulk Gasoline Terminals) 40 CFR 60.500, Subpart XX	3.10	TOC	Applicability
	40 CFR 60.502(b), Subpart XX, and 40 CFR 63.11081(i), Subpart BBBBBB	3.11		≤ 35 mg/TOC/L gasoline loaded, and other vapor collection systems and loading requirements
	40 CFR 60.502(h), Subpart XX	3.12	VOC	Design and operation requirements
	40 CFR 60.502(i), Subpart XX	3.13		Design requirements
	40 CFR 60.502(a) and (d), Subpart XX, and 40 CFR 63.11088(a), Subpart BBBBBB, Table 2	3.14	VOC/HAP	Design and operational requirements

AA-008 AA-019 AA-020 AA-028 AA-029	11 Miss. Admin. Code Pt. 2, R. 1.3.D(1)(a).	3.15	PM/PM ₁₀	≤ 0.6 lb/MMBTU
AA-008	11 Miss. Admin. Code Pt. 2, R. 1.4.A(1).	3.16	SO ₂	≤ 4.8 lb/MMBTU
AA-019 AA-020 AA-028 AA-029	40 CFR 60, Subpart IIII (Standards of Performance for Stationary Compression Ignition Internal Combustion Engines) 40 CFR 60.4200(a)(2)(i), Subpart IIII	3.17	NMHC + NO, CO & PM	Applicability
	40 CFR 60.4205(b), 60.4202(a)(2), 60.4206, and 60.4211(c), Subpart IIII	3.18		Emission Standards
	40 CFR 60.4209(a), Subpart IIII	3.19	Operating Requirements	Install a non-resettable hour meter
	40 CFR 60.4211(f), Subpart IIII	3.20		≤ 100 hrs/yr for maintenance checks and readiness testing and ≤ 50 hrs/yr for other non-emergency situations (counted toward the 100 hr total)
	40 CFR 60.4211(a), Subpart IIII	3.21		Operation and maintenance
	40 CFR 60.4207(b), Subpart IIII	3.22	Diesel	Fuel requirements
	40 CFR 63, Subpart ZZZZ (National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines) 40 CFR 63.6580, 63.6585(a), 63.6590(a)(2)(iii), and 63.6590(c)(1), Subpart ZZZZ	3.23	PM, NO _x	Applicability

- 3.1 For the entire facility, the permittee shall limit gasoline throughput to no more than 400,000,000 gallons in any consecutive 12-month period and shall limit total fuel, additives, and butane to no more than 600,000,000 gallons in a consecutive 12-month period.
(Ref.: 11 Miss. Admin. Code Pt. 2, R. 2.2.B(10).)
- 3.2 For the entire facility, the permittee is prohibited from storing reformulated or oxygenated gasoline.
(Ref.: 11 Miss. Admin. Code Pt. 2, R. 2.2.B(10).)
- 3.3 For the entire facility, the permittee shall not cause, permit, or allow the emission of smoke from a point source into the open air from any manufacturing, industrial, commercial, or waste disposal process with exceeds 40% opacity subject to the exceptions provided in (a) and (b).

- (a) Startup operations may produce emissions which exceed 40% opacity for up to fifteen minutes per startup in any one hour and not to exceed three startups per stack in any twenty four hour period.
- (b) Emissions resulting from soot blowing operations shall be permitted provided such emissions do not exceed 60% opacity and provided further that the aggregate duration of such emissions during any twenty four hour period does not exceed 10 minutes per billion BTU gross heating value of fuel in any one hour.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 1.3.A.)

- 3.4 For the entire facility, the permittee shall not cause, allow, or permit the discharge into the ambient air from any point source or emissions, any air contaminant of such opacity as to obscure an observer's view to a degree in excess of 40% opacity, equivalent to that provided in Condition 3.3.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 1.3.B.)

- 3.5 For the entire facility, the permittee shall operate air emissions equipment as efficiently as possible to provide the maximum reduction of air contaminants.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 2.2.B(10).)

- 3.6 For the entire facility, the permittee is subject to and shall comply with the applicable requirements of the National Emissions Standards for Hazardous Air Pollutants for Source Category: Gasoline Distribution Bulk Terminals, Bulk Plants, and Pipeline Facilities (40 CFR 63, Subpart BBBB) and the General Provisions (40 CFR 63, Subpart A). For the purposes of this subpart, the facility is considered a bulk gasoline terminal. The permittee shall be in compliance with all applicable standards of this subpart three years from permit issuance.

(Ref.: 40 CFR 63.11081(a)(1), Subpart BBBB)

- 3.7 For Emission Points AA-001, AA-002, AA-003, AA-018, and AA-024, the permittee shall equip each internal floating roof gasoline storage tank according to the requirements in Condition 3.9 excluding the secondary seal requirements in 40 CFR 60.112b(a)(1)(ii)(B) and the requirements in 40 CFR 60.112b(a)(1)(iv) through (ix). If the storage vessels equipped with internal floating roofs do not meet the previously specified requirements, the storage vessels shall be in compliance at the first degassing and cleaning activity three years after permit issuance or ten years after permit issuance, whichever comes first.

(Ref.: 40 CFR 63.11087(a), (b), and Table 1(2)(b), Subpart BBBB)

- 3.8 For Emission Points AA-018 and AA-024, the permittee is subject to and shall comply with the applicable requirements of the Standards of Performance for Volatile Organic Liquid Storage Vessels for Which Construction, Reconstruction, or Modification Commenced after July 23, 1984, (40 CFR 60, Subpart Kb) and the General Provisions (40 CFR 60, Subpart A). Gasoline storage tanks subject to and in compliance with the control requirements of 40 CFR 60, Subpart Kb, are deemed in compliance with the requirements of 40 CFR 63, Subpart BBBB, as stated in 40 CFR 63.11087(f), Subpart BBBB.

(Ref.: 40 CFR 60.110b(a), Subpart Kb)

- 3.9 For Emission Points AA-018 and AA-024, storage vessels with a design capacity greater than or equal to 151 m³ containing a volatile organic liquid (VOL) that, as stored, has a maximum true vapor pressure equal to or greater than 5.2 kPa but less than 76.6 kPa, shall equip the storage vessels with a fixed roof in combination with an internal floating roof meeting the following specifications:
- (a) The internal floating roof shall rest or float on the liquid surface (but not necessarily in complete contact with it) inside a storage vessel that has a fixed roof. The internal floating roof shall be floating on the liquid surface at all times, except during initial fill and during those intervals when the storage vessel is completely emptied or subsequently emptied and refilled. When the roof is resting on the leg supports, the process of filling, emptying, or refilling shall be continuous and shall be accomplished as rapidly as possible.
 - (b) Each internal floating roof shall be equipped with one of the following closure devices between the wall of the storage vessel and the edge of the internal floating roof:
 - (1) A foam- or liquid-filled seal mounted in contact with the liquid (liquid-mounted seal). A liquid-mounted seal means a foam- or liquid-filled seal mounted in contact with the liquid between the wall of the storage vessel and the floating roof continuously around the circumference of the tank.
 - (2) Two seals mounted one above the other so that each forms a continuous closure that completely covers the space between the wall of the storage vessel and the edge of the internal floating roof. The lower seal may be vapor-mounted, but both shall be continuous.
 - (3) A mechanical shoe seal, which is a metal sheet held vertically against the wall of the storage vessel by springs or weighted levers and is connected by braces to the floating roof. A flexible coated fabric (envelope) spans the annular space between the metal sheet and the floating roof.
 - (c) Each opening in a noncontact internal floating roof except for automatic bleeder vents (vacuum breaker vents) and the rim space vents is to provide a projection below the liquid surface.
 - (d) Each opening in the internal floating roof except for leg sleeves, automatic bleeder vents, rim space vents, column wells, ladder wells, sample wells, and stub drains is to be equipped with a cover or lid which is to be maintained in a closed position at all times (i.e., no visible gap) except when the device is in actual use. The cover or lid shall be equipped with a gasket. Covers on each access hatch and automatic gauge float well shall be bolted except when they are in use.
 - (e) Automatic bleeder vents shall be equipped with a gasket and are to be closed at all times when the roof is floating except when the roof is being floated off or is being landed on the roof leg supports.

- (f) Rim space vents shall be equipped with a gasket and are to be set to open only when the internal floating roof is not floating or at the manufacturer's recommended setting.
- (g) Each penetration of the internal floating roof for the purpose of sampling shall be a sample well. The sample well shall have a slit fabric cover that covers at least 90 percent of the opening.
- (h) Each penetration of the internal floating roof that allows for passage of a column supporting the fixed roof shall have a flexible fabric sleeve seal or a gasketed sliding cover.
- (i) Each penetration of the internal floating roof that allows for passage of a ladder shall have a gasketed sliding cover.

(Ref.: 40 CFR 60.112b(a)(1), Subpart Kb)

- 3.10 For Emission Points AA-005, AA-008, and AA-025, the permittee is subject to and shall comply with the applicable requirements of the Standards of Performance for Bulk Gasoline Terminals (40 CFR 60, Subpart XX) and the General Provisions (40 CFR 60, Subpart A). The affected facility to which the provisions of this subpart apply is the total of all loading racks at a bulk gasoline terminal which deliver liquid product into gasoline tank trucks.

(Ref.: 40 CFR 60.500, Subpart XX)

- 3.11 For Emission Points AA-005, AA-008, and AA-025, the Total Organic Compounds shall be limited to 35 mg of TOC/liter of gasoline loaded, as determined by EPA Reference Methods 25A or 25B, Appendix A and the test methods and procedures specified in 40 CFR 60.503 and 63.11092(a)(i).

(Ref.: 40 CFR 60.502(b), Subpart XX, and 40 CFR 63.11081(i), Subpart BBBBBB)

- 3.12 For Emission Points AA-005, AA-008, and AA-025, the vapor collection and liquid loading equipment shall be designed and operated to prevent gauge pressure in the delivery tank from exceeding 4,500 pascals (450 mm of water) during product loading. This level is not to be exceeded when measure by the procedures specified in 40 CFR 60.503(d).

(Ref.: 40 CFR 60.502(h), Subpart XX)

- 3.13 For Emission Points AA-005, AA-008, and AA-025, no pressure-vacuum vent in the bulk gasoline terminal's vapor collection system shall begin to open at a system pressure less than 4,500 pascals (450 mm of water).

(Ref.: 40 CFR 60.502(i), Subpart XX)

- 3.14 For Emission Points AA-005, AA-008, and AA-025, the permittee shall:

- (a) Equip each loading rack with a vapor collection system designed to collect the TOC vapors displaced from cargo tanks during product loading; and
- (b) Reduce emissions of TOC to less than or equal to 80 mg/l of gasoline loaded into gasoline cargo tanks at the loading rack; and

- (c) Design and operated the vapor collection system to prevent any TOC vapors collected at one loading rack from passing to another loading rack; and
- (d) Limit the loading of gasoline into gasoline cargo tanks that are vapor tight using the procedures specified in 40 CFR 60.502(e) through (j).

The permittee is limited to 35 mg TOC/liter of gasoline loaded into gasoline cargo tanks from the loading rack (Condition 3.11 of this permit). The loading rack is also subject to 80 mg TOC per liter of gasoline loaded (Table 2 of 40 CFR 63, Subpart BBBB). By demonstrating compliance with the more stringent NSPS Subpart XX limit of 35 mg TOC/liter of gasoline loaded into gasoline cargo tanks from the loading rack the permittee will also demonstrate compliance with the NESHAP Subpart BBBB limit.

(Ref.: 40 CFR 60.502(a) and (d), Subpart XX and 40 CFR 63.11088(a), 40 CFR 63 Subpart BBBB, Table 2)

- 3.15 For Emission Points AA-008, AA-019, AA-020, AA-028, and AA-029, the maximum permissible emission of ash and/or PM from fossil fuel burning installations of less than 10 million BTU per hour heat input shall not exceed 0.6 pounds per million BTU per hour heat input.

(Ref.: 11 Miss. Admin. Code Pt. 2, R.1.3.D(1)(a).)

- 3.16 For Emission Points AA-008, the permittee shall not discharge sulfur oxides from any fuel burning installation in which the fuel is burned primarily to produce heat or power by indirect heat transfer in excess of 4.8 pounds (measured as sulfur dioxide (SO₂)) per million BTU heat input.

(Ref.: 11 Miss. Admin. Code Pt. 2, R.1.4.A(1).)

- 3.17 For Emission Points AA-019, AA-020, AA-028, and AA-029, the permittee is subject to and shall comply with the applicable requirements of the Standards of Performance for Stationary Compression Ignition Internal Combustion Engines (40 CFR 60, Subpart III) and General Provisions (40 CFR 60, Subpart A).

(Ref.: 40 CFR 60.4200(a)(2)(i), Subpart III)

- 3.18 For Emission Points AA-019, AA-020, AA-028, and AA-029, the permittee shall comply with the emission standards for new non-road CI engines in 40 CFR 60.4202, Subpart III, for all pollutants, for the same model year and maximum engine power as the emergency CI ICE. The CI ICE shall meet the Tier 2 or Tier 3 emission standards for new nonroad CI engines for the same rated power as described in 40 CFR 1039, Appendix I, for all pollutants and the smoke standards as specified in 40 CFR 1039.105. The permittee must operate and maintain stationary CI ICE that achieve the emission standards as required in 40 CFR 60.4205, Subpart III, over the entire life of the engine. The permittee shall comply with these emission standards by purchasing an engine certified to the emission standards of 40 CFR 60.4205(b), Subpart III. The engine shall be installed and configured according to the manufacturer's emission-related specifications.

(Ref.: 40 CFR 60.4202(a)(2), 60.4205(b), 60.4206, and 60.4211(c), Subpart III)

3.19 For Emission Points AA-019, AA-020, AA-028, and AA-029, the permittee shall install and maintain a non-resettable hour meter.

(Ref.: 40 CFR 60.4209(a), Subpart IIII)

3.20 For Emission Points AA-019, AA-020, AA-028, and AA-029, the permittee shall operate the emergency stationary RICE according to the paragraphs below. In order for the engine to be considered an emergency stationary RICE, any operation other than emergency operation, maintenance and testing, emergency demand response, and operation in non-emergency situations for 50 hours per year, as described below, is prohibited. If the permittee does not operate the engine according to the paragraphs below, the engine will not be considered an emergency engine under 40 CFR 63, Subpart ZZZZ, or 40 CFR 60, Subpart IIII, and must meet all requirements for non-emergency engines.

- (a) There is no time limit on the use of emergency stationary RICE in emergency situations.
- (b) The permittee may operate the emergency stationary RICE for any combination of the purposes specified in 40 CFR 63.6640(f)(2)(i) through (iii), Subpart ZZZZ, or 40 CFR 60.4211(f)(2)(i) through (iii), Subpart IIII, for a maximum of 100 hours per calendar year. Any operation for non-emergency situations as allowed by paragraphs (c) counts as part of the 100 hours per calendar year allowed by this paragraph.
- (c) Emergency stationary RICE located at major sources of HAP may be operated for up to 50 hours per calendar year in non-emergency situations. The 50 hours of operation in non-emergency situations are counted as part of the 100 hours per calendar year for maintenance and testing and emergency demand response provided in paragraph (b) of this condition. The 50 hours per year for non-emergency situations cannot be used for peak shaving or non-emergency demand response, or to generate income for a facility to supply power to an electric grid or otherwise supply power as part of a financial arrangement with another entity.

(Ref.: 40 CFR 60.4211(f), Subpart IIII)

3.21 For Emission Points AA-019, AA-020, AA-028, and AA-029, the permittee shall comply with the following:

- (a) Operate and maintain the stationary CI internal combustion engine and control device according to the manufacturer's emission-related written instruction;
- (b) Change only those emission-related settings that are permitted by the manufacturer; and
- (c) Meet the requirements of 40 CFR 1068, as they apply.

(Ref.: 40 CFR 60.4211(a), Subpart IIII)

3.22 For Emission Points AA-019, AA-020, AA-028, and AA-029, the permittee shall use diesel fuel that meets the requirements of 40 CFR 1090.305 for nonroad diesel fuel.

(Ref.: 40 CFR 60.4207(b), Subpart IIII)

3.23 For Emission Points AA-019, AA-020, AA-028, and AA-029, the permittee is subject to and shall comply with the applicable requirements of the National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (40 CFR 63, Subpart *ZZZZ*) and General Provisions (40 CFR 63, Subpart A. These emission points shall meet the requirements of this subpart by meeting the requirements of 40 CFR 60, Subpart III.

(Ref.: 40 CFR 63.6580, 63.6585(a), 63.6590(a)(2)(iii), and 63.6590(c)(1), Subpart *ZZZZ*)

**SECTION 4
WORK PRACTICES**

Emission Point	Applicable Requirement	Condition Number(s)	Pollutant/Parameter	Work Practice
Facility Wide	40 CFR 63, Subpart BBBBBB (National Emission Standards for Hazardous Air Pollutants for Source Category: Gasoline Distribution Bulk Terminals, Bulk Plants, and Pipeline Facilities)	4.1	HAP	Operate and maintain any affected source in a manner consistent with safety and good air pollution control practices
	40 CFR 63.11085(a), Subpart BBBBBB			
AA-005 AA-008 AA-025	40 CFR 63.11092(d), Subpart BBBBBB	4.2	VOC	Operational requirement
	40 CFR 60, Subpart XX (Standards of Performance for Bulk Gasoline Terminals)	4.3		Loading procedures
	40 CFR 60.502(e)(1) through (5), Subpart XX	4.4		Compatible collection equipment requirement
	40 CFR 60.502(f), Subpart XX	4.5		Ensure vapor collection connections

4.1 For the entire facility, the permittee shall, at all times, operate and maintain in a manner consistent with safety and good air pollution control practices for minimizing emissions. Determination of whether such operation and maintenance procedures are being used will be based on information available to the DEQ, which may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source.

(Ref.: 40 CFR 63.11085(a), Subpart BBBBBB)

4.2 For Emission Points AA-005, AA-008, and AA-025, the permittee shall operate the vapor processing system in a manner not to exceed or go below, as appropriate, the operating parameter required in **Condition 5.11**. Operation of the vapor processing system in a manner exceeding or going below the operating parameter value, as appropriate, shall constitute a violation of the emission standard in **Condition 3.11**. However, malfunctions discovered by the monitoring and inspections required in **Condition 5.11** shall not constitute a violation of the emissions standard if corrective actions described in the monitoring and inspection plan are followed. Also, the permittee shall ensure the steps listed in 40 CFR 63.11092(d)(4)(i) through (v) are followed.

(Ref.: 40 CFR 63.11092(d), Subpart BBBBBB)

4.3 For Emission Points AA-005, AA-008, and AA-025, loadings of liquid product into gasoline tank trucks shall be limited to vapor-tight gasoline tank trucks using the following procedures:

(a) The permittee shall obtain the vapor tightness documentation meeting the requirements in **Condition 5.8** for each gasoline tank truck which is to be loaded.

- (b) The permittee shall document the tank identification number of each gasoline tank truck loaded per loading event
- (c) The permittee shall cross-check each tank identification number with the file of tank vapor tightness documentation within 2 weeks after the corresponding tank is loaded unless either (1) or (2) below is maintained. If either the quarterly or semiannual cross-check (c)(1) or (2) of this condition reveals that these conditions were not maintained, the source shall return to biweekly monitoring until such time as these conditions are again met.
 - (1) If less than an average of one gasoline tank truck per month over the last 26 weeks is loaded without vapor tightness documentation, then the documentation cross-check shall be performed each quarter; or
 - (2) If less than an average of one gasoline tank truck per month over the last 52 weeks is loaded without vapor tightness documentation, then the documentation cross-check shall be performed semiannually.
- (d) The permittee shall notify the owner or operator of each non-vapor-tight gasoline tank truck loaded at the affected facility within 1 week of the documentation cross-check required in (c) above
- (e) The permittee shall take steps assuring that the non-vapor-tight gasoline tank truck will not be reloaded at the affected facility until vapor tightness documentation for that tank is obtained.

(Ref.: 40 CFR 60.502(e)(1)-(5), Subpart XX)

- 4.4 For Emission Points AA-005, AA-008, and AA-025, the permittee shall act to assure that loadings of gasoline tank trucks at the affected facility are made only into tanks equipped with vapor collection equipment that is compatible with the terminal's vapor collection system.

(Ref.: 40 CFR 60.502(f), Subpart XX)

- 4.5 For Emission Points AA-005, AA-008, and AA-025, the permittee shall act to assure that the terminal's and the tank truck's vapor collection systems are connected during each loading of a gasoline tank truck. Examples of actions to accomplish this include training drivers in the hookup procedures and posting visible reminder signs at the affected loading racks.

(Ref.: 40 CFR 60.502(g), Subpart XX)

**SECTION 5
MONITORING AND RECORDKEEPING REQUIREMENTS**

Emission Point	Applicable Requirement	Condition Number(s)	Pollutant/Parameter	Monitoring/Recordkeeping Requirement
Facility Wide	11 Miss. Admin. Code Pt. 2, R. 2.9.	5.1	Recordkeeping	Maintain records for a minimum of five (5) years.
	11 Miss. Admin. Code Pt. 2, R. 2.2.B(11).	5.2	Fuel Throughput	Monitor and record monthly facility throughput
	40 CFR 63, Subpart BBBBBB (National Emission Standards for Hazardous Air Pollutants for Source Category: Gasoline Distribution Bulk Terminals, Bulk Plants, and Pipeline Facilities) 40 CFR 63.11094(f) and (g), Subpart BBBBBB	5.3	HAP	Recordkeeping
AA-001 AA-002 AA-003	40 CFR 63.11087(c), Subpart BBBBBB	5.4		Inspection requirements
	40 CFR 63.11087(e) and 63.11094(a), Subpart BBBBBB	5.5		Recordkeeping
AA-005 AA-008 AA-025	11 Miss. Admin. Code Pt. 2, R. 2.2.B(11). 40 CFR 63.11092, Subpart BBBBBB 40 CFR 60, Subpart XX (Standards of Performance for Bulk Gasoline Terminals) 40 CFR 60.503, Subpart XX	5.6	TOC	Stack test requirement
	40 CFR 60.502(j), Subpart XX	5.7		Monthly inspections
	40 CFR 60.505(a), (b), and (e), Subpart XX 40 CFR 63.11088(f), 63.11094(b) and (c), Subpart BBBBBB	5.8		Recordkeeping
	40 CFR 60.505(c), Subpart XX	5.9		
	40 CFR 60.505(d), Subpart XX	5.10		
	40 CFR 63.11092(b)(1)(iii), Subpart BBBBBB	5.11		Monitoring
	AA-018 AA-024	40 CFR 60, Subpart Kb (Standards of Performance for Volatile Organic Liquid Storage Vessels for Which Construction, Reconstruction, or Modification Commenced after July 23, 1984) 40 CFR 60.113b(a), Subpart Kb		5.12
	40 CFR 60.115b(a), Subpart Kb	5.13	Recordkeeping	
	40 CFR 60.116b(a), Subpart Kb	5.14		

AA-001 AA-002 AA-003 AA-004 AA-009 AA-010 AA-011 AA-012 AA-013 AA-018 AA-023 AA-024	40 CFR 60.116b(c), Subpart Kb 11 Miss. Admin. Code Pt. 2, R. 2.2.B(11).	5.15	VOC	Recordkeeping
AA-019 AA-020 AA-028 AA-029	11 Miss. Admin. Code Pt. 2, R. 2.2.B(11).	5.16	NMHC + NO _x , CO, and PM	Maintain engine certification testing
	11 Miss. Admin. Code Pt. 2, R. 2.2.B(11). 40 CFR 60, Subpart III (Standards of Performance for Stationary Compression Ignition Internal Combustion Engines) 40 CFR 60.4214(b), Subpart III	5.17	Operation and Maintenance	Maintain records of hours in emergency and non-emergency use, recordkeeping reason for use. Maintain hours of operation on a monthly and consecutive 12-month basis.
	40 CFR 63.11089(a) through (d), Subpart BBBBBB	5.18	HAP	Inspection requirement
40 CFR 63.11089(g) and 63.11094(d), Subpart BBBBBB	5.19	Recordkeeping		
40 CFR 63.11089(g) and 63.11094(e), Subpart BBBBBB	5.20			

5.1 For the entire facility, the permittee shall retain all required records, monitoring data, supporting information and reports for a period of at least five (5) years from the date of the monitoring sample, measurement, report, or application. Support information includes all calibration and maintenance records, all original strip-chart recordings or other data for continuous monitoring instrumentation, and copies of all reports required by this permit. Copies of such records shall be submitted to MDEQ as required by Applicable Rules and Regulations or this permit upon request.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 2.9.)

5.2 For the entire facility, the permittee shall maintain records of the total throughput of each product (gasoline, additive, diesel, ethanol, and off-spec) on a monthly basis and each consecutive 12-month period on a rolling basis.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 2.2.B(11).)

5.3 For the entire facility, the permittee shall:

- (a) Keep an up-to-date, readily accessible record of the continuous monitoring data required under **Condition 5.1**1. This record shall indicate the time intervals during which loadings of gasoline cargo tanks have occurred or, alternatively, shall record the operating parameter data only during such loadings. The date and time of day shall also be indicated at reasonable intervals on this record.

- (b) Keep an up-to-date, readily accessible copy of the monitoring and inspection plan required under **Condition 5.11**.
- (c) Keep an up-to-date, readily accessible record of the occurrence and duration of each malfunction of operation (i.e. process equipment) or the air pollution control and monitoring equipment and all system malfunctions, as specified in **Condition 5.11**.
- (d) Records of actions taken during periods of malfunction to minimize emissions in accordance with **Condition 4.1** including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation.

(Ref.: 40 CFR 63.11094(f) through 6 (g), Subpart BBBBBB)

- 5.4 For Emission Points AA-001, AA-002, and AA-003, the permittee shall demonstrate compliance with **Condition 3.7** by performing the visual and degassed inspections of the floating roof system according to the requirements of **Condition 5.12**.

(Ref.: 40 CFR 63.11087(c), Subpart BBBBBB)

- 5.5 For Emission Points AA-001, AA-002, and AA-003, the permittee shall keep records as specified in **Condition 5.13**, except these records shall be kept for at least five (5) years.

(Ref.: 40 CFR 63.11087(e) and 40 CFR 63.11094(a), Subpart BBBBBB)

- 5.6 For Emission Points AA-005, AA-008, and AA-025, the permittee shall demonstrate compliance with the emission limit in **Condition 3.11** by stack testing in accordance with EPA Reference Method 25A or 25B and the test methods and procedures specified in 40 CFR 60.503 and 40 CFR 63.11092(a)(i). A stack test shall be conducted every five years with subsequent tests being performed within 61 months of the previous test.

The test shall be six hours in duration during which at least 300,000 liters of gasoline shall be loaded. If this is not possible, the test may be continued the same day until 300,000 liter of gasoline is loaded or the test may be resumed the next day with another complete 6-hour period. In the latter case, the 300,000 liter criterion need not be met. However, as much as possible, testing should be conducted during the 6-hour period in which the highest throughput normally occurs.

The permittee shall submit a written test protocol at least sixty (60) days prior to the intended test date(s) to ensure that all test methods and procedures are acceptable to the DEQ. Also, the permittee shall notify the DEQ in writing at least ten (10) days prior to the test so that an observer may be afforded the opportunity to witness the test.

(Ref: 11 Miss. Admin. Code Pt. 2, Ch. 2. 2.2.B(11)., 40 CFR 60.503, Subpart XX and 40 CFR 63.11092, Subpart BBBBBB)

- 5.7 For Emission Points AA-005, AA-008, and AA-025, the vapor collection system, the vapor processing system, and each loading rack handling gasoline shall be inspected each calendar month during the loading of gasoline tank trucks for total organic compounds liquid or vapor leaks. For purposes of this paragraph, detection methods incorporating

sight, sound, or smell are acceptable. Each detection of a leak shall be recorded, and the source of the leak repaired within 15 calendar days after it is detected.

(Ref.: 40 CFR 60.502(j), Subpart XX)

5.8 For Emission Points AA-005, AA-008, and AA-025, the permittee shall keep records of the test results for each gasoline cargo tank loading at the facility available for inspection according to the following:

- (a) Records of the annual tank truck tightness certification testing performed under 40 CFR 60.505(b), Subpart XX, and 63.11092(f)(1), Subpart BBBB.
- (b) The documentation file shall be kept up-to-date for each gasoline cargo tank loading at the facility. The documentation of each test shall include, as a minimum, the information in (1) through (8) below:
 - (1) Name of test (e.g. Annual Certification Test- Method 27)
 - (2) Cargo tank owner's name and address
 - (3) Cargo tank identification number
 - (4) Test location and date
 - (5) Tester name and signature
 - (6) Witnessing inspector, if any: Name, signature, and affiliation.
 - (7) Vapor tightness repair: Nature of repair work and when performed in relation to vapor tightness testing
 - (8) Test results: Test pressure; pressure or vacuum change, mm of water; time period of test; number of leaks found with instrument; and leak definition.
- (c) As an alternative to keeping records of each gasoline cargo tank test at the terminal, as required in (a) and (b) above, the permittee may comply with either of the following:
 - (1) Keep an instantly available electronic copy of each record available at the terminal. The copy of each record shall be an exact duplicate image of the original paper record with certifying signatures. DEQ shall be notified in writing that the terminal is in compliance with this alternative; or
 - (2) For facilities that use a terminal automation system to prevent gasoline cargo tanks that do not have valid cargo tank vapor tightness documentation from loading (e.g., via a card lock-out system), a copy of the documentation is made available (e.g., via facsimile) for inspection during the course of a site visit, or within a mutually agreeable time frame.

The copy of each record shall be an exact duplicate image of the original paper record with certifying signatures. DEQ shall be notified in writing that the terminal is in compliance with this alternative.

(Ref.: 40 CFR 60.505(a-b), 40 CFR 60.505(e), Subpart XX and 40 CFR 63.11088(f), 40 CFR 63.11094(b-c), Subpart BBBB)

- 5.9 For Emission Points AA-005, AA-008, and AA-025, a record of each monthly leak inspection shall be kept on file at the terminal for at least two (2) years. Inspection records shall include, as a minimum, the following information:
- (a) Date of inspection.
 - (b) Findings (may indicate no leaks discovered; or location, nature, and severity of each leak)
 - (c) Leak determination method.
 - (d) Corrective action (date each leak repaired; reasons for any repair interval in excess of fifteen (15) days).
 - (e) Inspector name and signature.
- (Ref.: 40 CFR 60.505(c), Subpart XX)
- 5.10 For Emission Points AA-005, AA-008, and AA-025, the permittee shall keep documentation of all notifications required by **Condition 4.3(d)** on file at the terminal for at least two (2) years.
- (Ref.: 40 CFR 60.505(d), Subpart XX)
- 5.11 For Emission Points AA-005, AA-008, and AA-025, where a thermal oxidation system other than a flare is used and as an alternative to paragraph (b)(1)(iii)(A) of 40 CFR 63.11092, the permittee shall meet the requirements below:
- (a) The presence of a thermal oxidation system pilot flame shall be monitored using a heat-sensing device, such as an ultraviolet beam sensor or a thermocouple, installed in proximity of the pilot light, to indicate the presence of a flame. The heat-sensing device shall send a positive parameter value to indicate that the pilot flame is on, or a negative parameter value to indicate that the pilot flame is off.
 - (b) Develop, submit to the Administrator, and maintain onsite a monitoring and inspection plan that describes the owner or operator's approach for meeting the requirements below:
 - (1) The thermal oxidation system shall be equipped to automatically prevent gasoline loading operations from beginning at any time that the pilot flame is absent.
 - (2) The owner or operator shall verify, during each day of operation of the loading rack, the proper operation of the assist-air blower and the vapor line valve. Verification shall be through visual observation, or through an automated alarm or shutdown system that monitors system operation. A manual or electronic record of the start and end of a shutdown event may be used.
 - (3) The owner or operator shall perform semi-annual preventive maintenance inspections of the thermal oxidation system, including the automated alarm or shutdown system for those units so equipped, according to the recommendations of the manufacturer of the system.

- (4) The monitoring plan shall specify conditions that would be considered malfunctions of the thermal oxidation system during the inspections or automated monitoring performed under paragraphs (2) and (3) above, describe specific corrective actions that will be taken to correct any malfunction, and define what the owner or operator would consider to be a timely repair for each potential malfunction.
- (5) The owner or operator shall document any system malfunction, as defined in the monitoring and inspection plan, and any activation of the automated alarm or shutdown system with a written entry into a logbook or other permanent form of record. Such record shall also include a description of the corrective action taken and whether such corrective actions were taken in a timely manner, as defined in the monitoring and inspection plan, as well as an estimate of the amount of gasoline loaded during the period of the malfunction.

(Ref.: 40 CFR 63.11092(b)(1)(iii), Subpart BBBBBB)

5.12 For Emission Points AA-018 and AA-024, storage vessels equipped with an internal floating roof, the permittee shall:

- (a) Visually inspect the internal floating roof, the primary seal, and the secondary seal (if one is in service), prior to filling the storage vessel with VOL. If there are holes, tears, or other openings in the primary seal, the secondary seal, or the seal fabric or defects in the internal floating roof, or both, the owner or operator shall repair the items before filling the storage vessel.
- (b) For vessels equipped with a liquid-mounted or mechanical shoe primary seal, visually inspect the internal floating roof and the primary seal or the secondary seal (if one is in service) through manholes and roof hatches on the fixed roof at least once every 12 months after initial fill. If the internal floating roof is not resting on the surface of the VOL inside the storage vessel, or there is liquid accumulated on the roof, or the seal is detached, or there are holes or tears in the seal fabric, the owner or operator shall repair the items or empty and remove the storage vessel from service within 45 days. If a failure that is detected during inspections required in this paragraph cannot be repaired within 45 days and if the vessel cannot be emptied within 45 days, a 30-day extension may be requested in the inspection report required by **Condition 6.12**. Such a request for an extension shall document that alternate storage capacity is unavailable and specify a schedule of actions the company will take that will assure that the control equipment will be repaired or the vessel will be emptied as soon as possible.
- (c) Visually inspect the internal floating roof, the primary seal, the secondary seal (if one is in service), gaskets, slotted membranes and sleeve seals (if any) each time the storage vessel is emptied and degassed. If the internal floating roof has defects, the primary seal has holes, tears, or other openings in the seal or the seal fabric, or the secondary seal has holes, tears, or other openings in the seal or the seal fabric, or the gaskets no longer close off the liquid surfaces from the atmosphere, or the slotted membrane has more than 10 percent open area, the

owner or operator shall repair the items as necessary so that none of the conditions specified in this paragraph exist before refilling the storage vessel with VOL. In no event shall inspections conducted in accordance with this provision occur at intervals greater than 10 years in the case of vessels conducting the annual visual inspection and at intervals no greater than 5 years in the case of vessels as specified in (b) above.

(Ref.: 40 CFR 60.113b(a), Subpart Kb)

- 5.13 For Emission Points AA-018 and AA-024, the permittee shall keep copies of all records required by 40 CFR 60 Subpart Kb except for the records required in **Condition 5.14**, for at least two years.

(Ref.: 40 CFR 60.115b(a), Subpart Kb)

- 5.14 For Emission Points AA-018 and AA-024, the permittee shall keep readily accessible records showing the dimension of the storage vessel and an analysis showing the capacity of the storage vessel for the life of the vessel.

(Ref.: 40 CFR 60.116b(b) and (g), Subpart Kb)

- 5.15 For Emissions Points AA-001, AA-002, AA-003, AA-004, AA-009, AA-010, AA-011, AA-012, AA-013, AA-018, AA-023 and AA-024, the permittee shall maintain a record of the volatile organic liquid (VOL) stored, the period of storage, and the maximum true vapor pressure of that VOL during the respective storage period.

(Ref.: 11 Miss. Admin. Code Pt. 2, Ch. 2. 2.2.B(11). and 40 CFR 60.116b(c), Subpart Kb)

- 5.16 For Emission Points AA-019, AA-020, AA-028, and AA-029, the permittee shall maintain engine certification testing demonstrating compliance with the applicable emission standards for each engine. This information shall be available for review by the DEQ at any time.

(Ref: 11 Miss. Admin. Code Pt. 2, R. 2.2.2.B(11).)

- 5.17 For Emission Points AA-019, AA-020, AA-028, and AA-029, emergency CI ICE, the permittee shall keep records of the operation of the engine in emergency and non-emergency use recorded through the non-resettable hour meter. The permittee shall record the hours of operation of the engine and the reason the engine was in operation during that time. The permittee shall monitor and keep records of the hours of operation of each unit on a monthly and consecutive 12-month basis

(Ref: 11 Miss. Admin. Code Pt. 2, R. 2.2.2.B(11). and 40 CFR 60.4214(b), Subpart III)

- 5.18 For Emission Point AF-000, the permittee is subject to and shall comply with the following equipment leak inspection requirements:

- (a) Perform a monthly leak inspection of all equipment in gasoline service, as defined in 40 CFR 63.11100. For this inspection, detection methods incorporating sight, sound, and smell are acceptable.

- (b) A logbook shall be used and shall be signed by the permittee at the completion of each inspection. Each detection of a liquid or vapor leak shall be recorded in the logbook. A section of the logbook shall contain a list, summary description, or diagram(s) showing the location of all equipment in gasoline service at the facility.
- (c) When a leak is detected, an initial attempt at repair shall be made as soon as practicable, but no later than five (5) calendar days after the leak is detected. Repair or replacement of leaking equipment shall be completed within fifteen (15) calendar days after detection of each leak.
- (d) Delay of repair of leaking equipment will be allowed if the repair is not feasible within 15 days. The permittee shall provide in the semiannual report specified in **Condition 6.6** the reason(s) why the repair was not feasible and the date each repair was completed.

(Ref.: 40 CFR 63.11089(a)-(d), Subpart BBBBBB)

- 5.19 For Emission Point AA-000, the permittee shall prepare and maintain a record describing the types, identification numbers, and locations of all equipment in gasoline service. If the permittee elects to implement an instrument program under 40 CFR 63.11089, the record shall contain a full description of the program.

(Ref.: 40 CFR 63.11089(g) and 40 CFR 63.11094(d), Subpart BBBBBB)

- 5.20 For Emission Point AA-000, the permittee shall record in the log book for each leak that is detected the information specified in the list below:

- (a) The equipment type and identification number.
- (b) The nature of the leak (i.e., vapor or liquid) and the method of detection (i.e., sight, sound, or smell).
- (c) The date the leak was detected and the date of each attempt to repair the leak.
- (d) Repair methods applied in each attempt to repair the leak.
- (e) "Repair delayed" and the reason for the delay if the leak is not repaired within 15 calendar days after discovery of the leak.
- (f) The expected date of successful repair of the leak if the leak is not repaired within 15 days.
- (g) The date of successful repair of the leak.

(Ref.: 40 CFR 63.11089(g) and 40 CFR 63.11094(e), Subpart BBBBBB)

SECTION 6 REPORTING REQUIREMENTS

Emission Point	Applicable Requirement	Condition Number(s)	Reporting Requirement
Facility Wide	11 Miss. Admin. Code Pt. 2, R. 2.2.B(11).	6.1	Report permit deviations within five (5) working days.
	11 Miss. Admin. Code Pt. 2, R. 2.2.B(11). 40 CFR 63, Subpart BBBBBB (National Emission Standards for Hazardous Air Pollutants for Source Category: Gasoline Distribution Bulk Terminals, Bulk Plants, and Pipeline Facilities)	6.2	Submit certified semiannual monitoring report.
	11 Miss. Admin. Code Pt. 2, R. 2.2.B(11).	6.3	All documents submitted to MDEQ shall be certified by a Responsible Official.
		6.4	Annual roof landing report
AA-001 AA-002 AA-003 AA-005 AA-008 AA-025 AF-001	40 CFR 63.11087(e), 63.11088(f), 63.11095(a), (d), and (b) Subpart BBBBBB	6.5	Semiannual report requirements
		6.6	
	40 CFR 63.11093(a), Subpart BBBBBB	6.7	Initial notifications
	40 CFR 63.11093(b), Subpart BBBBBB	6.8	Notification of compliance status
AA-008	40 CFR 63.11093(c), Subpart BBBBBB	6.9	Notification of performance test
	11 Miss. Admin. Code Pt. 2, R. 2.2.B(11).	6.10	Submit stack test results within 60 days
AA-001 AA-002 AA-003 AA-018 AA-024	40 CFR 60, Subpart Kb (Standards of Performance for Volatile Organic Liquid Storage Vessels for Which Construction, Reconstruction, or Modification Commenced after July 23, 1984)	6.11	Reporting requirement
	40 CFR 60.113b(a)(5), Subpart Kb 40 CFR 63.11092(e)(1), Subpart BBBBBB		
AA-018 AA-024	40 CFR 60.115b(a)(3) and (4), Subpart Kb	6.12	

6.1 Except as otherwise specified herein, the permittee shall report all deviations from permit requirements, including those attributable to upsets, the probable cause of such deviations, and any corrective actions or preventive measures taken. Said report shall be made within five (5) working days of the time the deviation began.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 2.2.B(11).)

6.2 Except as otherwise specified herein, the permittee shall submit a certified semiannual synthetic minor monitoring report postmarked no later than 31st of January or the 31st of

July for the preceding semi-annual reporting period. Semiannual reporting periods will be from January 1st through June 30th and from July 1st through December 31st. This report shall address any required monitoring specified in the permit. All instances of deviations from permit requirements must be clearly identified in the report. Where no monitoring data is required to be reported and/or there are no deviations to report, the report shall contain the appropriate negative declaration.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 2.2.B(11).)

- 6.3 Any document required by this permit to be submitted to the MDEQ shall contain a certification signed by a responsible official stating that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate and complete.

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 2.2.B(11).)

- 6.4 For the entire facility, the permittee shall submit an annual report of the number of roof landings conducted throughout the previous twelve (12) month period for each tank. This report shall be submitted by January 31st of each year. The report shall include the date, the duration (in hours) of each landing, and the reason for the roof landing (i.e., cleaning, degassing, product change out, etc.),

(Ref.: 11 Miss. Admin. Code Pt. 2, R. 2.2.B(11).)

- 6.5 For Emission Points AA-001, AA-002, AA-003, AA-005, AA-008, AA-025, and AF-001, the permittee shall submit the following information with **Condition 6.2**:

- (a) For loading racks, each loading of a gasoline cargo tank for which vapor tightness documentation had not been previously obtained by the facility.
- (b) For equipment leak inspections, the number of equipment leaks not repaired within 15 days after detection.
- (c) The number, duration, and a brief description of each type of malfunction which occurred during the reporting period and which caused or may have caused any applicable emission limitation to be exceeded; a description of actions taken during the malfunction to minimize emissions in accordance with 40 CFR 63.11085(a); and actions taken to correct the malfunction.

(Ref.: 40 CFR 63.11087(e), 40 CFR 63.11088(f), 40 CFR 63.11095(a), (d) and (b), Subpart BBBBBB)

- 6.6 For Emission Points AA-001, AA-002, AA-003, AA-005, AA-008, AA-025, and AF-001, the permittee shall submit an excess emissions report along with the semiannual compliance report required in **Condition 6.5**. Excess emissions events and the information to be included in the excess emissions report are specified in paragraphs (a) through (e) below:

- (a) Each exceedance or failure to maintain, as appropriate, the monitored operating parameter value determined in accordance with **Condition 5.11**. The report shall include the monitoring data for the days on which exceedances or failures to maintain have occurred, and a description and timing of the steps taken to repair

or perform maintenance on the vapor collection and processing systems or the CMS.

- (b) Each instance in which malfunctions discovered during the monitoring and inspections required by **Condition 5.11(b)** were not resolved according to the necessary corrective actions described in the monitoring and inspection plan. The report shall include a description of the malfunction and the timing of the steps taken to correct the malfunction.
- (c) For each occurrence of an equipment leak for which no repair attempt was made within five (5) days or for which repair was not completed within 15 days after detection:
 - (1) The date on which the leak was detected;
 - (2) The date of each attempt to repair the leak;
 - (3) The reasons for the delay of repair; and
 - (4) The date of successful repair.
- (d) Each instance of a non-vapor-tight gasoline cargo tank loading at the facility in which the owner or operator failed to take steps to assure that such cargo tank would not be reloaded at the facility before vapor tightness documentation for that cargo tank was obtained.
- (e) Each reloading of a non-vapor-tight gasoline cargo tank at the facility before vapor tightness documentation for that cargo tank is obtained by the facility in accordance with 40 CFR 63.11094(b).

(Ref.: 40 CFR 63.11087(e), 40 CFR 63.11088(f), and 40 CFR 63.11095(b), Subpart BBBB)B

- 6.7 For Emission Points AA-001, AA-002, AA-003, AA-005, AA-008, AA-025 and AF-001, the permittee shall submit an Initial Notification as specified in 40 CFR 63.9(b) within 120 days after permit issuance. If the permittee is in compliance with the requirements of 40 CFR 63, Subpart BBBB)B at the time of the Initial Notification is due, the Notification of Compliance Status required in Condition 6.8 may be submitted in lieu of the Initial Notification.

(Ref.: 40 CFR 63.11087(f) and 40 CFR 63.11093(a) and Table 3, Subpart BBBB)B

- 6.8 For Emission Points A-001, AA-002, AA-003, AA-005, AA-008, AA-025 and AF-001, the permittee shall submit a Notification of Compliance Status as specified in 40 CFR 63.9(h).

(Ref.: 40 CFR 63.11093(b) and Table 3, Subpart BBBB)B

- 6.9 For Emission Point AA-008, the permittee shall submit a Notification of Performance Test as specified in 40 CFR 63.9(e) with the written test protocol at least 60 days prior to initiating testing required in **Condition 5.6** to ensure that all test methods and procedures are acceptable to the DEQ. Also, the permittee shall notify the DEQ in writing at least ten

(10) days prior to the test so that an observer may be afforded the opportunity to witness the test.

(Ref.: 40 CFR 63.11093(c), Subpart BBBB)B

- 6.10 For Emission Point AA-008, the permittee shall submit results of the stack test required in **Condition 5.6** to DEQ within 60 days of the test.

(Ref.: 11 Miss. Admin. Code Pt. 2, R.2.2B(11).)

- 6.11 For Emission Points AA-001, AA-002, AA-003, AA-018 and AA-024, the permittee shall notify DEQ in writing at least 30 days prior to the filling or refilling of each storage vessel for which an inspection is required by **Conditions 5.4 and 5.12**, to afford DEQ the opportunity to have an observer present. If the inspection required by **Condition 5.12(c)** is not planned and the owner or operator could not have known about the inspection 30 days in advance or refilling the tank, the owner or operator shall notify DEQ at least seven (7) days prior to the refilling of the storage vessel. Notification shall be made by telephone immediately followed by written documentation demonstrating why the inspection was unplanned. Alternatively, this notification including the written documentation may be made in writing and sent by express mail so that it is received by DEQ at least seven (7) days prior to the refilling.

(Ref.: 40 CFR 60.113b(a)(5), Subpart Kb and 40 CFR 63.11092(e)(1), Subpart BBBB)B

- 6.12 For Emission Points AA-018 AA-024, if any of the conditions described in **Conditions 5.13** are detected during the annual visual inspection required in **Condition 5.12**, a report shall be furnished to DEQ within 30 days of the inspection. Each report shall identify the storage vessel, the nature of the defects, and the date the storage vessel was emptied or the nature of and date the repair was made. After each inspection required by **Condition 5.12** that finds holes or tears in the seal or seal fabric, or defects in the internal floating roof, or other control equipment defects listed in 40 CFR 60.113b(a)(3)(ii), a report shall be furnished to DEQ within 30 days of the inspection. The report shall identify the storage vessel and the reason it did not meet the specifications of 40 CFR 61.112b(a)(1) or 40 CFR 60.113b(a)(3) and list each repair made.

(Ref.: 40 CFR 60.115b(a)(3-4), Subpart Kb)