

# STATE OF MISSISSIPPI WATER POLLUTION CONTROL PERMIT

TO DISCHARGE WASTEWATER IN ACCORDANCE WITH THE  
NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM

## **THIS CERTIFIES THAT**

International Paper Company  
Columbus Mill  
4335 Carson Road  
Columbus, Mississippi  
Lowndes County

has been granted permission to discharge wastewater into

Outfall 001 – Tennessee-Tombigbee Waterway

Outfall 002 – an unnamed tributary of Cedar Creek

in accordance with effluent limitations, monitoring requirements and other conditions set forth in Parts I, II, and III hereof. This permit is issued in accordance with the provisions of the Mississippi Water Pollution Control Law (Section 49-17-1 et seq., Mississippi Code of 1972), and the regulations and standards adopted and promulgated thereunder, and under authority granted pursuant to Section 402(b) of the Federal Water Pollution Control Act.

**MISSISSIPPI ENVIRONMENTAL QUALITY PERMIT BOARD**



**AUTHORIZED SIGNATURE**

**MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY**

**Issued: June 4, 2018**

**Permit No. MS0036412**

**Expires: May 31, 2023**

**PART I****A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS**

1. During the period beginning **June 4, 2018**, and lasting until **May 31, 2023**, the permittee is authorized to discharge from outfall(s) serial number(s) **001 (Treated Process Wastewater, Treated Non-Process Wastewater, and Treated Sanitary Wastewater from Kraft Pulp Mill)**.

Such discharges shall be limited and monitored by the permittee as specified below:

PARAMETER	DISCHARGE LIMITATIONS				MONITORING REQUIREMENTS	
	kg/day (lbs/day)	kg/day (lbs/day)	Other Units (Specify)		Measurement Frequency	Sample Type
	Monthly Avg.	Daily Max.	Monthly Avg.	Daily Max.		
Flow-M <sup>3</sup> /Day (MGD)	N/A	N/A	Report	Report	Continuous	Recorder
Total Suspended Solids	13,368(29,450)	25,610(56,420)	Report	Report	5 Days/Week	24-Hr. Composite
Biochemical Oxygen Demand (5-Day)	7,739(17,050)	**	Report	Report	5 Days/Week	24-Hr. Composite
Adsorbable Organic Halides	780(1,718)	1190(2,622)	8.21 mg/L	12.5 mg/L	Twice/Year	24-Hr. Composite

PARAMETER	DISCHARGE LIMITATIONS				MONITORING REQUIREMENTS	
	kg/day (lbs/day)	kg/day (lbs/day)	Other Units (Specify)		Measurement Frequency	Sample Type
	Quarterly Avg.	Quarterly Max.	Quarterly Avg.	Quarterly Max.		
Total Rec. Aluminum	228(503)	376(828)	4.60 mg/L	7.58 mg/L	Once/Month	24-Hr. Composite

PARAMETER	DISCHARGE LIMITATIONS				MONITORING REQUIREMENTS	
	kg/day (lbs/day)	kg/day (lbs/day)	Other Units (Specify)		Measurement Frequency	Sample Type
	Yearly Avg.	Yearly Max.	Yearly Avg.	Yearly Max.		
2,3,7,8-TCDD	Report	1.0 x 10 <sup>-6</sup> (2.3 x 10 <sup>-6</sup> )	Report	21 pg/L	Once/Year	24-Hr. Composite

2. The pH shall not be less than **6.0** standard units nor greater than **9.0** standard units and shall be monitored **continuously**.
3. There shall be no discharge of floating solids or visible foam in other than trace amounts.
4. The discharge shall not cause the occurrence of a visible sheen on the surface of the receiving waters.
5. Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location(s): **the nearest accessible point after final treatment but prior to actual discharge or mixing with the receiving waters**.
6. **Test Method 1650, with minimum detection level of 20 ug/L, or a more recently approved EPA test method, shall be used when testing for Adsorbable Organic Halides (AOX).**

7. For AOX, the permittee shall comply with the Sampling Guidance for Cluster Rule Parameters found in Section C3 of the National Council for Air and Stream Improvement (NCASI) document, dated April 1998, or the most recent edition.
  8. For 2,3,7,8-TCDD, the test method referenced in Part III, Section E, Item 2, found on page 26 of 32 of this permit, or a more recently approved EPA test method, shall be used when testing.
  9. Please see page 25 of 32 for Toxicity Monitoring Conditions for Outfall 001.
  10. Chronic WET monitoring shall be performed once per six months for the life of the permit in accordance with Part III, Section F of this permit. If the IC<sub>25</sub> of any test is less than 10.8%, then the effluent will be considered unacceptably chronically toxic, and this will constitute a violation of this permit.
- \*\* The daily discharge shall not exceed those values allowed in Table 1, pages 11 and 12 of 32 of this permit. The monthly average loading cannot exceed 17,050 lbs/day. The daily discharge for any one day cannot exceed the indicated value in the table. Flow readings shall be taken in-stream. Temperature readings shall be taken at the mill's raw water intake. Flow and Temperature readings shall be taken in concurrence with the required BOD<sub>5</sub> monitoring and shall be recorded in a log book or another approved manner. River water withdrawal amounts by the permittee must be included in determining the existing flow of the Tennessee-Tombigbee Waterway for purposes of BOD<sub>5</sub> compliance.

**PART I**

**A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS**

1. During the period beginning **June 4, 2018**, and lasting until **May 31, 2023**, the permittee is authorized to discharge from outfall(s) serial number(s) **002 (Non-process Wastewater and Storm Water)**.

Such discharges shall be limited and monitored by the permittee as specified below:

PARAMETER	DISCHARGE LIMITATIONS				MONITORING REQUIREMENTS	
	kg/day (lbs/day)	kg/day (lbs/day)	Other Units (Specify)		Measurement Frequency	Sample Type
	Monthly Avg.	Daily Max.	Monthly Avg.	Daily Max.		
Flow-M <sup>3</sup> /Day (MGD)	N/A	N/A	Report	Report	Once/Month	Instantaneous
Total Suspended Solids	N/A	N/A	Report	Report	Once/Month	Grab

PARAMETER	DISCHARGE LIMITATIONS				MONITORING REQUIREMENTS	
	kg/day (lbs/day)	kg/day (lbs/day)	Other Units (Specify)		Measurement Frequency	Sample Type
	Yearly Avg.	Yearly Max.	Yearly Avg.	Yearly Max.		
Oil & Grease	N/A	N/A	Report	Report	Once/Year	Grab

2. The pH shall not be less than **6.0** standard units nor greater than **9.0** standard units and shall be monitored **once per month with a**

**grab sample of the effluent.**

3. There shall be no discharge of floating solids or visible foam in other than trace amounts.
4. The discharge shall not cause the occurrence of a visible sheen on the surface of the receiving waters.
5. Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location(s): **the nearest accessible point after final treatment but prior to actual discharge or mixing with the receiving waters.**

**PART I****A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS**

1. During the period beginning **June 4, 2018**, and lasting until **May 31, 2023**, the permittee is authorized to discharge from outfall(s) serial number(s) **003 (Internal Outfall – Process Wastewater from Bleaching Plant Only)**.

Such discharges shall be limited and monitored by the permittee as specified below:

PARAMETER	DISCHARGE LIMITATIONS				MONITORING REQUIREMENTS	
	kg/day (lbs/day)	kg/day (lbs/day)	Other Units (Specify)		Measurement Frequency	Sample Type*
	Monthly Avg.	Daily Max.	Monthly Avg.	Daily Max.		
Flow-M <sup>3</sup> /Day (MGD)	N/A	N/A	Report	Report	Continuous	Totalizer
2,3,7,8-TCDD	Report	<2.5 x 10 <sup>-7</sup> (5.5 x 10 <sup>-7</sup> )	Report	<0.000010 ug/L	Twice/Year	24-Hr. Composite
2,3,7,8-TCDF	Report	7.8 x 10 <sup>-7</sup> (1.7 x 10 <sup>-6</sup> )	Report	0.0000319 ug/L	Twice/Year	24-Hr. Composite
Trichlorosyringol	Report	<0.062(0.14)	Report	<2.5 ug/L	Twice/Year	24-Hr. Composite
3,4,5-trichlorocatechol	Report	<0.13(0.28)	Report	<5.0 ug/L	Twice/Year	24-Hr. Composite
3,4,6-trichlorocatechol	Report	<0.13(0.28)	Report	<5.0 ug/L	Twice/Year	24-Hr. Composite
3,4,5-trichloroguaiacol	Report	<0.062(0.14)	Report	<2.5 ug/L	Twice/Year	24-Hr. Composite

PARAMETER	DISCHARGE LIMITATIONS				MONITORING REQUIREMENTS	
	kg/day (lbs/day)	kg/day (lbs/day)	Other Units (Specify)		Measurement Frequency	Sample Type*
	Monthly Avg.	Daily Max.	Monthly Avg.	Daily Max.		
3,4,6-trichloroguaiacol	Report	<0.062(0.14)	Report	<2.5 ug/L	Twice/Year	24-Hr. Composite
4,5,6-trichloroguaiacol	Report	<0.062(0.14)	Report	<2.5 ug/L	Twice/Year	24-Hr. Composite
2,4,5-trichlorophenol	Report	<0.062(0.14)	Report	<2.5 ug/L	Twice/Year	24-Hr. Composite
2,4,6-trichlorophenol	Report	<0.062(0.14)	Report	<2.5 ug/L	Twice/Year	24-Hr. Composite
Tetrachlorocatechol	Report	<0.13(0.28)	Report	<5.0 ug/L	Twice/Year	24-Hr. Composite
Tetrachloroguaiacol	Report	<0.13(0.28)	Report	<5.0 ug/L	Twice/Year	24-Hr. Composite
2,3,4,6-tetrachlorophenol	Report	<0.062(0.14)	Report	<2.5 ug/L	Twice/Year	24-Hr. Composite
Pentachlorophenol	Report	<0.13(0.28)	Report	<5.0 ug/L	Twice/Year	24-Hr. Composite
Chloroform	5.2(11.4)	8.66(19.1)	0.128 mg/L	0.215 mg/L	24-Hr. Composite (See Item 5)	

2. Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location(s): Stage 1-D100, Stage 2-E<sub>o</sub>, Stage 3-D1, and Stage 4-D2. See diagram and description on Page 32 of 32 of this permit.

3. The following methods with the listed minimum detection levels shall be used:

<u>Parameter</u>	<u>Method</u>	<u>Minimum Level</u>
2,3,7,8-TCDD	1613	10 pg/L
2,3,7,8-TCDF	1613	10 pg/L
Trichlorosyringol	1653	2.5 ug/L
3,4,5-trichlorocatechol	1653	5.0 ug/L
3,4,6-trichlorocatechol	1653	5.0 ug/L
3,4,5-trichloroguaiacol	1653	2.5 ug/L
3,4,6-trichloroguaiacol	1653	2.5 ug/L
4,5,6-trichloroguaiacol	1653	2.5 ug/L
2,4,5-trichlorophenol	1653	2.5 ug/L
2,4,6-trichlorophenol	1653	2.5 ug/L
Tetrachlorocatechol	1653	5.0 ug/L
Tetrachloroguaiacol	1653	5.0 ug/L
2,3,4,6-tetrachlorophenol	1653	2.5 ug/L
Pentachlorophenol	1653	5.0 ug/L

4. For Outfall 003, the permittee shall comply with the Sampling Guidance for Cluster Rule Parameters found in Section C3 of the National Council for Air and Stream Improvement (NCASI) document, dated April 1998, or the most recent edition.
5. In lieu of monitoring, the permittee has applied for the Chloroform certification alternative found in 40 CFR Part 430. The permittee shall comply with all requirements of the Chloroform certification alternative found in 40 CFR Part 430 and shall certify at the time of DMR submittal the following:
- The chlorine containing compounds used for bleaching are unchanged from those identified under 40 CFR 430.02(f)(2)(iii);
  - The following process and operating conditions maintained on the fiber line during the reporting period have not exceeded the maximum value recorded for each such condition during the collection of the samples used to make the demonstration required under paragraphs 40 CFR 430.02(f)(2)(i) or (f)(3)(i): (1) The pH of the first chlorine dioxide bleaching stage; (2) The chlorine (Cl<sub>2</sub>) content of chlorine dioxide (ClO<sub>2</sub>) used on the bleach line; (3) The kappa factor of the first chlorine dioxide bleaching stage; and (4) The total bleach line chlorine dioxide application rate.

- \* **24-Hr. Composite samples (grab samples taken every 4 hours and composited based on effluent flow) shall consist of 24-Hr. flow proportioned composite samples from Stages 1 through Stages 4. See Page 32 of 32 for flow diagram and description. D100, D1, and D2 stage effluent samples will be composited for the acid sewer composite sample based on 24-hr average flows for each of the stages. Eo stage effluent samples will be composited for the alkaline sewer composite sample.**





**B. SCHEDULE OF COMPLIANCE**

1. The permittee shall achieve compliance with the effluent limitations specified for discharge in accordance with the following schedule:

**Upon permit issuance, the permittee shall have completed their once every five year review and re-evaluation of the Best Management Practices (BMP) Plan as established and required by 40 CFR Part 430.03. Within 30 days after permit issuance, the permittee shall submit written documentation of compliance with this requirement to the Mississippi Environmental Quality Permit Board.**

2. Within 14 days after either an interim or final date of compliance specified in PART IB.1., the permittee shall provide the Permit Board with written notice of his compliance or noncompliance with the requirements or conditions specified to be completed by that date.

**Not Applicable.**

**C. DEFINITIONS**

1. "Monthly average" means the average of "daily discharges" over a calendar month, calculated as the sum of all "daily discharges" measured during a calendar month divided by the number of "daily discharges" measured during the month. The monthly average for fecal coliform bacteria is the geometric mean of "daily discharges" measured during the calendar month. In computing the geometric mean for fecal coliform bacteria, the value one (1) shall be substituted for sample results of zero. (Ref.: 11 Miss. Admin. Code Pt. 2, R. 1.1.1.A(44).)
2. "Daily discharge" means the "discharge of a pollutant" measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling. For pollutants with limitations expressed in units of mass, the "daily discharge" is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurements, the "daily average" is calculated as the average measurement of the discharge of the pollutant over the day. (Ref.: 11 Miss. Admin. Code Pt. 2, R. 1.1.1.A(15).)
3. "Daily maximum" means the highest "daily discharge" over a calendar month. (Ref.: 11 Miss. Admin. Code Pt. 2, R. 1.1.1.A(16).)
4. "Toxic pollutants" include, but are not limited to: (a) any toxic substance listed in Section 307(a)(1) of the Clean Water Act (CWA), any chemical listed in Section 313(c) of the Superfund Amendments and Reauthorization Act of 1986; and (b) any substance (that is not also a conventional or nonconventional pollutant) for which EPA or the State has published an acute or chronic toxicity criterion. (Ref.: 11 Miss. Admin. Code Pt. 2, R. 1.1.1.A(71).)

5. "Hazardous substances" are defined in 40 CFR 116.4. (Ref.: 40 CFR 116.4)
6. "Submitted" means the document is postmarked on or before the applicable deadline, except as otherwise specified. (Ref.: 11 Miss. Admin. Code Pt. 6, R. 1.1.1.A (67).)

## **D. MONITORING AND REPORTING**

### 1. Representative Sampling

Samples and measurements taken as required herein shall be representative of the volume and nature of the monitored wastewater. (Ref.: 11 Miss. Admin. Code Pt. 2, R. 1.1.4.A(28)(e).)

### 2. Reporting

- a) Monitoring results obtained during the previous reporting period shall be summarized and reported on a Discharge Monitoring Report (DMR). DMR data must be submitted electronically using the MDEQ NetDMR system NO LATER THAN THE 28TH DAY OF THE MONTH FOLLOWING THE COMPLETED REPORTING PERIOD.

DMRs and all other reports required herein, shall be signed in accordance with 11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(15)(c)(1). of the Mississippi Wastewater

- b) Regulations. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(15)c(1)., 40 CFR 122.21(1)(4)(i)]If the results for a given sample analysis are such that any parameter (other than fecal coliform) is not detected at or above the minimum level for the test method used, a value of zero will be used for that sample in calculating an arithmetic mean value for the parameter. If the resulting calculated arithmetic mean value for that reporting period is zero, the permittee shall report "NODI = B" on the DMR. For fecal coliform, a value of 1.0 shall be used in calculating the geometric mean. If the resulting fecal coliform mean value is 1.0, the permittee shall report "NODI = B" on the DMR. For each quantitative sample value that is not detectable, the test method used and the minimum level for that method for that parameter shall be attached to and submitted with the DMR. The permittee shall then be considered in compliance with the appropriate effluent limitation and/or reporting requirement.
- c) If the permittee monitors any pollutant as prescribed in the permit more frequently than required by the permit using test procedures approved under 40 CFR Part 136 or, in the case of sludge use or disposal, approved under 40 CFR Part 136 unless otherwise specified in 40 CFR Part 503, or as specified in the permit, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR or sludge reporting form specified by the Permit Board.
- d) Calculations for all limitations which require averaging of measurements shall utilize an arithmetic mean unless otherwise specified by the Permit Board in the permit. (Ref.: 11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(15)(c)(1).)

3. Test Procedures

Test procedures for the analysis of pollutants shall conform to regulations published pursuant to Section 304(h) of the Federal Water Pollution Control Act, as amended or alternative procedures approved and/or promulgated by EPA. For those parameters listed in Exhibit D of the Mississippi Wastewater Permit Regulations, the permittee shall use approved methods with minimum quantification levels as sensitive as those found in Exhibit D of the regulations. (Ref.: 11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(30).

4. Recording of Results

For each measurement or sample taken pursuant to the requirements of this permit, the permittee shall maintain records of all information obtained from such monitoring including:

- a) The exact place, date, and time of sampling;
- b) The dates the analyses were performed;
- c) The person(s) who performed the analyses;
- d) The analytical techniques, procedures or methods used; and
- e) The results of all required analyses. (Ref.: 11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(29)(a).)

5. Records Retention

All records and results of monitoring activities required by this permit, including calibration and maintenance records, shall be retained by the permittee for a minimum of three (3) years, unless otherwise required or extended by the Permit Board, copies of which shall be furnished to the Department upon request. (Ref.: 11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(29)(a).)

6. Falsifying Reports

Any permittee who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required by the Permit Board to be maintained as a condition in a permit, or who alters or falsifies the results obtained by such devices or methods and/or any written report required by or in response to a permit condition, shall be deemed to have violated a permit condition and shall be subject to the penalties provided for a violation of a permit condition pursuant to Section 49-17-43 of the Code. (Ref.: 11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(29)(d).)

## PART II

### A. MANAGEMENT REQUIREMENTS

#### 1. Facility Expansion and/or Modification

Any facility expansion, production increases, process modifications, changes in discharge volume or location or other changes in operations or conditions of the permittee which may result in a new or increased discharge of waste, shall be reported to the Permit Board by submission of a new application for a permit pursuant to Section II.A. of the Mississippi Wastewater Regulations, or if the discharge does not violate effluent limitations specified in the permit, by submitting to the Permit Board a notice of a new or increased discharge. (Ref.: 11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(14).)

#### 2. Duty to Comply 40 CFR 122.41(a)

The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the Clean Water Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or denial of a permit renewal application. (Ref.: 11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(2).)

#### 3. Noncompliance Notification

##### a) Twenty-Four Hour Reporting

- (1) The permittee shall report any noncompliance which may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the permittee becomes aware of the circumstances. A written submission shall also be provided within 5 days of the time the permittee becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and/or prevent recurrence of the noncompliance.
- (2) The following shall be included as information which must be reported within 24 hours under this paragraph.
  - i. Any unanticipated bypass which exceeds any effluent limitation in the permit.
  - ii. Any upset which exceeds any effluent limitation in the permit.
  - iii. Violation of a maximum daily discharge limitation for any of the pollutants listed by the Permit Board in the permit to be reported within 24 hours.

- iv. The Executive Director may waive the written report on a case-by-case basis for reports under paragraph a. of this section if the oral report has been received within 24 hours.

All reports required by this condition which are submitted after December 20, 2020, shall be submitted by the permittee electronically as instructed by MDEQ. [11 Miss.Admin. Code Pt. 6, R. 1.1.4.A(29)(e.), 40 CFR 122.41.(1)(6)]

b) Other Noncompliance

The permittee shall report all instances of noncompliance not reported under paragraph (a)., at the time monitoring reports are submitted or within 30 days from the end of the month in which the noncompliance occurs. The reports shall contain the information listed in paragraph (a).

All reports required by this condition which are submitted after December 20, 2020, shall be submitted by the permittee electronically as instructed by MDEQ. [11 Miss.Admin. Code Pt. 6, R. 1.1.4.A(29)(e.), 40 CFR 122.41.(1)(6)]

c) Other Information

Where the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Permit Board, it shall promptly submit such facts or information. (Ref.: 11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(29)(e).)

4. Proper Operation, Maintenance and Replacement

The permittee shall at all times properly operate, maintain, and when necessary, promptly replace all facilities and systems of collection, treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance includes adequate laboratory controls and appropriate quality assurance procedures. Proper replacement includes maintaining an adequate inventory of replacement equipment and parts for prompt replacement when necessary to maintain continuous collection and treatment of wastewater. This provision requires the operation of back-up or auxiliary facilities or similar systems that are installed by a permittee only when the operation is necessary to achieve compliance with the conditions of the permit. (Ref.: 11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(18).)

5. Duty to Mitigate

The permittee shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of the permit that has a reasonable likelihood of adversely affecting human health or the environment. (Ref.: 11 Miss. Admin. Code Pt.

6, R. 1.1.4.A(19).)

6. Bypassing

The permittee shall comply with the terms and conditions regarding bypass found in 40 CFR 122.41(m). (Ref.: 40 CFR 122.41(m))

All reports required by this condition which are submitted after December 20, 2020, shall be submitted by the permittee electronically as instructed by MDEQ. [40 CFR 122.41(m)(3)(i, ii)]

7. Upsets

Permittee shall meet the conditions of 40 CFR 122.41(n) regarding "Upsets" and as follows:

- a) Definition. "Upset" means an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.
- b) Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology based permit effluent limitations if the requirements of paragraph c) of this section are met. Any determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, shall not constitute final administrative action subject to judicial review.
- c) Conditions necessary for demonstration of upset. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed contemporaneous operating logs, or other relevant evidence that:
  - (1) An upset occurred and that the permittee can identify the cause(s) of the upset;
  - (2) The permitted facility was at the time being properly operated; and
  - (3) The permittee submitted notice of the upset as required in 40 CFR 122.41(L)(6)(ii)(B)(24-hour notice of noncompliance).
  - (4) The permittee complied with any remedial measures required under 40 CFR 122.41(d) (Duty to Mitigate).
- d) Burden of proof. In any enforcement proceeding the permittee seeking to establish the occurrence of an upset has the burden of proof. (Ref.: 11 Miss. Admin. Code

Pt. 6, R. 1.1.4.A(27).)

8. Removed Substances

Solids, sludges, filter backwash, or other residuals removed in the course of treatment or control of wastewater shall be disposed of in a manner such as to prevent such materials from entering State waters and in a manner consistent with the Mississippi Solid Waste Disposal Act, the Federal Resource Conservation and Recovery Act, and the Mississippi Water Pollution Control Act. (Ref.: 11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(21).)

9. Power Failures

If electric power is required, in order to maintain compliance with the conditions and prohibitions of the permit, the permittee shall either:

- a) Provide an alternative power source to operate the wastewater control facilities; or, if such alternative power source is not in existence, and no date for its implementation appears in the permit,

Halt, reduce, or otherwise control production and/or all wastewater flows upon reduction, loss, or failure of the primary source of power to the wastewater control facilities. (Ref.: 11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(22).)

**B. RESPONSIBILITIES**

1. Inspection and Entry

The permittee shall allow any authorized Commission representative to enter the permittee's premises at any reasonable time, to have access to and copy any applicable records, to inspect process facilities, treatment works, monitoring methods or equipment or to take samples, as authorized by Section 49-17-21 of the Code. In the event of investigation during an emergency response action, a reasonable time shall be any time of the day or night. Follow-up investigations subsequent to the conclusion of the emergency event shall be conducted at reasonable times. (Ref.: 11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(17).)

2. Transfer of Ownership or Control

This permit is not transferable to any person except after proper notice and approval by the Permit Board. In the event of any change in control or ownership of facilities from which the authorized discharges emanate, the permittee shall notify the Mississippi Environmental Quality Permit Board at least thirty (30) days in advance of the proposed transfer date. The notice should include a written agreement between the existing and new permittees containing a specific date for the transfer of permit responsibility, coverage, and liability. (Ref.: 11 Miss. Admin. Code Pt. 6, R. 1.1.5.C.)

3. Signatory Requirements 40 CFR 122.41(k)

All applications, reports, or information submitted to the Permit Board shall be signed and certified.

- a) All permit applications shall be signed as follows:
  - (1) For a corporation: by a responsible corporate officer. For the purpose of this Section, a responsible corporate officer means: (1) a president, secretary, treasurer or vice president of the corporation in charge of a principal business function, or any other person who performs similar policy - or decision-making function for the corporation, or (2) the manager of one or more manufacturing, production, or operating facilities employing more than 250 persons or having gross annual sales or expenditures exceeding 25 million (in second quarter 1980 dollars), if authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures.
  - (2) For a partnership or sole proprietorship: by a general partner or the proprietor, respectively; or
  - (3) For a municipality, State, Federal, or other public agency: by either a principal executive officer or ranking elected official.
- b) All reports required by the permit and other information requested by the Permit Board shall be signed by a person described above or by a duly authorized representative of that person. A person is a duly authorized representative only if:
  - (1) The authorization is made in writing by a person described above;
  - (2) The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity, such as the position of plant manager, operator of a well or a well field, superintendent, position having overall responsibility for environmental matters for the company. (A duly authorized representative may thus be either a named individual or any individual occupying a named position.); and
  - (3) The written authorization is submitted to the Permit Board.
- c) Changes to authorization. If an authorization under paragraph b) of this section is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of paragraph b) of this section must be submitted to the Permit Board prior to or together with any reports, information, or applications.
- d) Certification. Any person signing a document under paragraphs a) or b) of this section shall make the following certification:

"I certify under penalty of law that this document and all attachments were prepared

under the direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations." (Ref.: 11 Miss. Admin. Code Pt. 6, R. 1.1.2.C.)

4. Availability of Records

Except for data determined to be confidential under the Mississippi Water Pollution Control Law, all reports prepared in accordance with the terms of this permit shall be available for public inspection at the office of the Mississippi Department of Environmental Quality Office of Pollution Control. (Ref.: 11 Miss. Admin. Code Pt. 6, R. 1.1.3.E.)

5. Duty to Provide Information

The permittee shall furnish to the Permit Board within a reasonable time any relevant information which the Permit Board may request to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit, or to determine compliance with the permit. (Ref.: 11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(16).)

6. Toxic Pollutants

The permittee shall comply with any toxic effluent standard or prohibition (including any schedule of compliance specified in such effluent standard or prohibition) established under Section 307(a) of the Federal Water Pollution Control Act. (Ref.: 11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(26).)

7. Toxic Pollutants Notification Requirements

The permittee shall comply with the applicable provisions of 40 CFR 122.42. (Ref.: 11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(26).)

8. Civil and Criminal Liability

- a) Any person who violates a term, condition or schedule of compliance contained within this permit or the Mississippi Water Pollution Control Law is subject to the actions defined by law.
- b) Except as provided in permit conditions on "Bypassing" and "Upsets" (PART IIA.6 and 7), nothing in this permit shall be construed to relieve the permittee from civil or criminal penalties for noncompliance.
- c) It shall not be the defense of the permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. (Ref.: 11 Miss. Admin. Code Pt. 6,

R. 1.1.4.A(24).)

9. Oil and Hazardous Substance Liability

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties to which the permittee is or may be subject to under Section 311 of the Federal Water Pollution Control Act and applicable provisions under Mississippi Law pertaining to transportation, storage, treatment, or spillage of oil or hazardous substances. (Ref.: 11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(23).)

10. Property Rights

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State, or local laws or regulations. (Ref.: 11 Miss. Admin. Code Pt. 6, R. 1.1.5.E.)

11. Severability

The provisions of this permit are severable. If any provision of this permit, or the application of any provision of this permit to any circumstances, is challenged or held invalid, the validity of the remaining permit provisions and/or portions thereof or their application to other persons or sets of circumstances, shall not be affected thereby. (Ref.: 11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(25).)

12. Expiration of Permit

At least 180 days prior to the expiration date of this permit pursuant to the State law and regulation, the permittee who wishes to continue to operate under this permit shall submit an application to the Permit Board for reissuance. The Permit Board may grant permission to submit an application later than this, but no later than the expiration date of the permit. (Ref.: 11 Miss. Admin. Code Pt. 6, R. 1.1.4.B(1).)

13. Protection of Confidential Information

- a) Pursuant to Miss. Code Ann. '49-17-39 and 40 CFR 123.41, the Permit Board shall make available to the public all information contained on any form and all public comments on such information. Effluent data and information concerning air or water quality shall also be made available to the public. Information that is determined by the Commission to be trade secrets shall not be disclosed to the public without prior consent of the source of such information. When a claim of confidentiality is made by a person in accordance with the provisions of Miss. Code Ann. '49-17-39, a recommendation on the questions of confidentiality shall be made by the Commission and forwarded to the Regional Administrator (or his/her designee) of EPA for his concurrence in such determination of confidentiality.
- b) A copy of a State, UIC, or NPDES permit application, public notice, fact sheet, draft

permit and other forms relating thereto, including written public comment and other reports, files and information relating to the application not classified as confidential information by the Commission pursuant to PART IIB.13.a), shall be available for public inspection and copying during normal business hours at the office of the Department in Jackson, Mississippi.

- c) Upon determination by the Commission that information submitted by a permit applicant is entitled to protection against disclosure as trade secrets, the information shall be so labeled and otherwise handled as confidential. Copies of the information and a notice of the Commission's action shall be forwarded to the Regional Administrator (or his/her designee). In making its determination of entitlement to protection as a trade secret, the Commission shall follow the procedure set forth in Miss. Code Ann. ' 49-17-39. In the event the Commission denies the claim of confidentiality, the applicant shall have, upon notification thereof, the right to appeal the Commission's determination in the same manner provided for other orders of the Commission. No disclosure, except to EPA, shall be allowed until any appeal from the determination of the Commission is completed. (Ref.: 11 Miss. Admin. Code Pt. 6, R. 1.1.3.F.)

#### 14. Spill Prevention and Best Management Plans

Any permittee which has above ground bulk storage capacity, of more than 1320 gallons or any single container with a capacity greater than 660 gallons, of materials and/or liquids (including but not limited to, all raw, finished and/or waste material) with chronic or acute potential for pollution impact on waters of the State and not subject to Mississippi Hazardous Waste Management Regulations or 40 CFR 112 (Oil Pollution Prevention) regulations shall provide secondary containment as found in 40 CFR 112 or equivalent protective measures such as trenches or waterways which would conduct any tank releases to a permitted treatment system or sufficient equalization or treatment capacity needed to prevent chronic/acute pollution impact. (Ref.: 11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(12)(a).)

### PART III

#### A. REOPENER CLAUSE

This permit shall be modified, or alternately, revoked and reissued, to comply with any applicable effluent standard, limitation or storm water regulation issued or approved under Section 301(b)(2)(C), and (D), 304(b)(2), 307(a)(2) and 402(p) of the Federal Water Pollution Control Act if the effluent standard, limitation or regulation so issued or approved:

1. Contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
2. Controls any pollutant not limited in the permit.
3. **The permit shall be reopened and modified if the Mississippi Department of Environmental Quality establishes a Water Quality Limit for color or if the color of the Tennessee-Tombigbee Waterway downstream of the effluent mixing zone shows a significant adverse aesthetic impact.**
4. **The permit shall be reopened to allow modifications of the final dioxin limits in the event of possible revision of the dioxin carcinogenic potency factor and/or other such developments.**
5. **The permit shall be reopened and modified if the Environmental Protection Agency promulgates an effluent limit guideline for Chemical Oxygen Demand.**

(Ref.: 11 Miss. Admin. Code Pt. 6, R. 1.1.4.F(1).)

#### B. CLOSURE REQUIREMENTS

Should the permittee decide to permanently close and abandon the premises upon which it operates, it shall provide a Closure Plan to the Permit Board no later than 90 days prior to doing so. This Closure Plan shall address how and when all manufactured products, by-products, raw materials, stored chemicals, and solid and liquid waste and residues will be removed from the premises or permanently disposed of on site such that no potential environmental hazard to the waters of the State will be presented. Closure plan(s) submitted to and approved by Mississippi Department of Environmental Quality for compliance with other environmental regulations will satisfy the closure requirements for those items specifically addressed in the closure plan(s) as long as the closure does not present a potential for environmental hazard to waters of the State. (Ref.: 11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(11).)

#### C. REQUIREMENTS REGARDING COOLING AND BOILER WATER ADDITIVES

Notification shall be made to the permitting authority in writing not later than sixty (60) days prior to initiating the addition of any chemical product to the cooling water and/or boiler water which is subject to discharge, other than those previously approved and/or used. Such

notification should include, but not be limited to:

1. Name and composition of the proposed additive,
2. Proposed discharge concentration,
3. Dosage addition rates,
4. Frequency of use,
5. EPA registration, if applicable, and
6. Aquatic species toxicological data.

Written approval must be received from the permitting authority prior to initiating use.

#### **D. TOXICITY MONITORING CONDITIONS FOR OUTFALL 001**

**For Outfall 001, the permittee shall monitor for Total Recoverable Zinc, Total Recoverable Mercury (II), Total Recoverable Cadmium, and Total Recoverable Cyanide twice per month for six months with a 24-Hour composite sample of the effluent beginning the month following the effective issuance date of the permit. All monitoring results shall be submitted to the Mississippi Environmental Quality Permit Board under separate cover from the DMR submittal no later than the 28th day of the month following the completed collection of all 48 samples. The permit may be re-opened after receipt of this data and application of procedures set forth in the water quality based effluent limitations chapter of the "State of Mississippi Wastewater Regulations". Samples for these parameters shall be analyzed using an EPA approved method with at least the following minimum quantitation level (MQL).**

<u>Parameter</u>	<u>MQL (ppb)</u>
Total Recoverable Zinc	10
Total Recoverable Mercury (II)	0.5
Total Recoverable Cadmium	0.5
Total Recoverable Cyanide	10

#### **E. OTHER STANDARD CONDITIONS**

##### **1. Instream Monitoring**

- a. **The permittee shall implement the revised monitoring plan submitted on April 27, 2005, for the discharge into the Tennessee-Tombigbee Waterway during periods of low river flow. The monitoring plan allows for measurement of dissolved oxygen, pH, temperature, conductivity, and color both upstream and downstream of the discharge. This data shall be reported monthly under separate cover from the Discharge Monitoring Reports.**
- b. **The permittee shall take all steps necessary to assure that its effluent discharge does not result in the Alabama portion of the Tennessee-Tombigbee Waterway having dissolved oxygen levels, at the five-foot**

depth, below 5 mg/l as determined by the permittee's computer model, or field surveys by the permittee, the Mississippi Department of Environmental Quality, or the Alabama Department of Environmental Management. If the dissolved oxygen level measured in the river upstream of the effluent discharge is less than 5 mg/l, the permittee shall not cause the dissolved oxygen level of the river to decrease below the upstream level.

## 2. Dioxin Monitoring Conditions

In addition to the effluent limitations specified in Part I of this permit, the permittee is required to monitor once per year with a 24-hour composite sample for all chloro-dibenzo dioxins and furans listed in Table 2, at the following locations:

- a. Sludge from Kraft Mill Facility
- b. Final Effluent (from Outfall 001)

The method of analysis for each sample shall be the appropriate method of analysis specified in Analytical Procedures and Quality Assurance for Multimedia Analysis of Polychlorinated Dibenzo-para-dioxins and Polychlorinated Dibenzofurans by High-Resolution Gas Chromatography/High-Resolution Mass Spectrometry, EPA, 1990, (EPA Method 8290), or Tetra- through Octa- Chlorinated Dioxins and Furans by Isotope Dilution HRGC/HRMS, EPA, 1994, (EPA Method 1613, Revision B), or another equivalent analytical protocol approved by EPA. For each sampling period, the limit of detection shall be reported for each sample analyzed.

If an analysis for a given sample results in a measurement of "less than the limit of detection" or below 10 ppq, a value of zero will be used for that sample in calculating an average arithmetic effluent value for that parameter. For the effluent from Outfall 001 only, monitoring results for the previous year for chloro-dibenzo dioxins and furans in Table 2 and toxicity testing results shall be submitted. Monitoring results shall be submitted as a separate report from the discharge monitoring reports and by the 28th day of the month following the completed reporting period. The limit of detection shall be reported for each analysis and be included in the report.

These samples shall be analyzed and reported for all isomers of chloro-dibenzo dioxins and furans in Table 2 and also reported as toxicity equivalents (TEQ) based on the relative toxic equivalence factors listed below:

**TABLE 2**  
**CDD/CDF ISOMERS OF MOST TOXIC CONCERN**

<b>CHLORO-DIBENZO DIOXIN</b>		<b>CHLORO-DIBENZOFURAN</b>	
<b>Isomer</b>	<b>TEF<sup>a</sup></b>	<b>Isomer</b>	<b>TEF<sup>a</sup></b>
<b>2,3,7,8-TCDD</b>	<b>1</b>	<b>2,3,7,8-TCDF</b>	<b>0.1</b>
<b>1,2,3,7,8-PeCDD</b>	<b>1</b>	<b>1,2,3,7,8-PeCDF</b> <b>2,3,4,7,8-PeCDF</b>	<b>0.03</b> <b>0.3</b>
<b>1,2,3,4,7,8-HxCDD</b>	<b>0.1</b>	<b>1,2,3,4,7,8-HxCDF</b>	<b>0.1</b>
<b>1,2,3,7,8,9-HxCDD</b>	<b>0.1</b>	<b>1,2,3,7,8,9-HxCDF</b>	<b>0.1</b>
<b>1,2,3,6,7,8-HxCDD</b>	<b>0.1</b>	<b>1,2,3,6,7,8-HxCDF</b> <b>2,3,4,6,7,8-HxCDF</b>	<b>0.1</b> <b>0.1</b>
<b>1,2,3,4,6,7,8-HpCDD</b>	<b>0.01</b>	<b>1,2,3,4,6,7,8-HpCDF</b> <b>1,2,3,4,7,8,9-HpCDF</b>	<b>0.01</b> <b>0.01</b>
<b>OCDD</b>	<b>0.0003</b>	<b>OCDF</b>	<b>0.0003</b>

<sup>a</sup>TEF = Toxic Equivalence Factor = Relative Toxicity Assigned.

**3. Uncontaminated Storm Water Discharge**

The permittee is allowed to discharge uncontaminated storm water from the holding ponds through the outfall structure to the Tennessee-Tombigbee Waterway.

**4. Best Management Practices (BMP) Plan 40 CFR 430.03**

The permittee shall continue to comply with all Best Management Practices requirements for spent pulping liquor, soap, and turpentine management, spill prevention, and control as established in 40 CFR 430.03.

## F. CHRONIC BIOASSAY REQUIREMENTS

The Water Quality Standards of Mississippi require that waters be free from substances attributable to municipal, industrial, agricultural, or other discharges in concentrations or combinations that are toxic or harmful to humans, animals, or aquatic life (State of Mississippi, Water Quality Criteria for Intrastate and Coastal Waters, Section II.4., Minimum Conditions Applicable to All Waters (current edition). In accordance with such requirements, an NPDES permit holder is authorized to discharge from outfall(s) 001 only in accordance with the following conditions:

1. The permittee shall submit any existing toxicity data for review by the Mississippi Office of Pollution Control within 30 days of the effective date of this permit.
2. The permittee shall perform 7-day chronic, static renewal, definitive (a control and five effluent concentrations) WET tests in accordance with Short-Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms, (EPA/600/4-89/001) or Short-Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Marine and Estuarine Organisms, (EPA/600/4-87/028) or the most recent edition\*.
  - a. Dilution water used for these tests shall consist of reagent grade water, defined as distilled or deionized water that does not contain substances which are toxic to the test organisms. For freshwater tests, dilution water shall consist of reagent grade chemicals or mineral water combined to make moderately hard dilution water according to Short-Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms (EPA/600/4-89/001) or most recent edition\*. For estuarine testing, dilution water shall consist of synthetic seawater or hyper-saline brine combined to achieve a salinity of 20 parts per thousand according to Short-Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Marine and Estuarine Organisms (EPA/600/4-87/028) or most recent edition\*. These dilution waters will be deemed acceptable if the control organisms in the toxicity tests meet the minimum EPA criteria for chronic tests.
  - b. If the Mississippi Office of Pollution Control determines the receiving waters are freshwater, the permittee shall conduct a Ceriodaphnia dubia Survival and Reproduction Test, and a

**Pimephales promelas Larval Survival and Growth Test** on serial dilutions of effluent to determine if the discharge from outfall(s) 001 is chronically toxic. Such testing will determine if the water affects the survival, growth, and reproduction of the test organisms. Static renewal tests will be conducted on three 24-hour composite samples of effluent. The first of these composite samples will be used to set up the tests and for the day 1 and day 2 renewals, the second of these composite samples will be used to renew the tests on days 3 and 4, and the third composite sample will be used to renew the tests on days 5 and 6. Not more than 36 hours will elapse between sampling and the first use of any of the composite samples. The chronic test(s) shall be considered valid only if the acceptability criteria referenced in **Short-Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms**, (EPA/600/4-89/001) or most recent edition\*, are met. All data shall be statistically analyzed according to the referenced manual.

- c. If the Mississippi Office of Pollution Control determines that the receiving water is estuarine, the permittee shall conduct a **Menidia beryllina Larval Survival and Growth Test** and a **Americamysis Survival, Growth, and Fecundity Test** on serial dilutions of effluent to determine if the discharge from outfall(s) 001 is chronically toxic. Such testing will determine if the water affects the survival, growth, and fecundity of the test organisms. Static renewal tests will be conducted on three 24-hour composite samples of effluent. The first of these composite samples will be used to set up the tests and for the day 1 and day 2 renewals, the second of these composite samples will be used to renew the tests on days 3 and 4, and the third composite sample will be used to renew the tests on days 5 and 6. Not more than 36 hours will elapse between sampling and the first use of any of the composite samples. The chronic test(s) shall be considered valid only if the acceptability criteria referenced in **Short-Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Marine and Estuarine Organisms**, (EPA/600/4-87/028) or most recent edition\*, are met. All test data shall be statistically analyzed according to the referenced manual.
- d. A standard reference toxicant quality assurance test (chronic) shall be conducted concurrently with the effluent tests using

both species used in the toxicity tests. Alternatively, if a lab conducts monthly QA/QC reference toxicant tests with both species as part of their SOP, these results may be submitted in lieu of the above mentioned concurrent tests results. In either case, the reference toxicant test results must be submitted with the final report as well as on the Mississippi Office of Pollution Control NPDES Whole Effluent Toxicity Testing Report Form.

- \*\*3.** These chronic toxicity tests shall be initiated within 90 days of the date of issuance of the permit to evaluate wastewater toxicity. Such chronic toxicity tests shall be conducted once per quarter for a period of one year following the effective date of the permit. After the first year of monitoring, provided the IC<sub>25</sub> is greater than or equal to 10.8%, the frequency of monitoring will be reduced to once per six months for the life of the permit. Sampling shall be timed to cover the seasonal extremes of the year (hot-dry and cold-wet).
4. If any one chronic toxicity test indicates the IC<sub>25</sub> is less than 10.8%, the provisions in Section 6 below shall apply, and the permittee shall conduct another chronic toxicity test(s) with the organism(s) that failed. This follow-up test must be completed within 30 days following completion of the failed test. Final chronic toxicity test results shall be in report form as outlined in Methods for Measuring the Acute Toxicity of Effluents to Freshwater and Marine Organisms, Fourth Edition, (EPA-600/4-90/027) or most recent edition\*. The permittee must also submit a completed Mississippi Office of Pollution Control NPDES Whole Effluent Toxicity Testing Report Form.
5. In the event the permittee passes the additional WET test, the permittee shall resume testing in accordance with the testing schedule set forth in the permit. In the event the permittee fails the second WET test, the permittee shall submit a Toxicity Reduction Evaluation Plan (TREP) within 45 days following completion of the follow-up test in order to reduce the toxicity of the effluent to safe<sup>1</sup> levels<sup>2</sup>. The first phase of the TREP will include increased monitoring to characterize the toxicity of the effluent.
6. If the IC<sub>25</sub> of any test is less than 10.8%, then the effluent will be considered unacceptably chronically toxic, and this will constitute a violation of Part I of this permit.

<sup>1</sup>Safe levels will be determined by Title 11, Part 6, Chapter 2.


<sup>2</sup>In large rivers, lakes, and estuaries the permittee must provide a schematic map showing isopleths of waste concentrations.

In addition to the specific conditions of this permit, the permittee shall comply with all applicable conditions of 40 CFR 122.7 and 40 CFR 122.61 (06-03-93).

**\*Contact the Mississippi Office of Pollution Control Laboratory for information on most recent edition(s) of methods manual.**

**\*\* Chronic WET monitoring shall be performed once per six months for the life of the permit as specified in Part I. of this permit.**

## Bleach Plant – Outfall 003 Flow Totalizer



**Stage 1 (D100)** – flow is read from flowmeter number 2.

**Stage 2 (Eo)** – flow is calculated by subtracting internal reuse flows from flowmeter number 1.

**Stage 3 (D1)** – D1 flow is calculated by subtracting the flows from flowmeters 5, 6, 7, and 9 from flowmeter number 3.

**Stage 4 (D2)** – D2 flow is calculated by subtracting the flow from flowmeter 8 from the flow from flowmeter number 4.

June 2012