



## State of Mississippi



### WATER POLLUTION CONTROL PERMIT

To Operate a Wastewater Disposal System with No Discharge

#### **THIS CERTIFIES**

Rancho Los Fuentes  
16182 Highway 26 West  
Lucedale, MS  
George County

has been granted permission to operate a wastewater disposal system in accordance with the limitations and conditions set forth in this permit. This permit is issued in accordance with the provisions of the Mississippi Water Pollution Control Law (Section 49-17-1 et seq., Mississippi Code of 1972), and the regulations and standards adopted and promulgated thereunder.

**Mississippi Environmental Quality Permit Board**

A handwritten signature in blue ink that reads "Krystal Rudolph".

---

**Mississippi Department of Environmental Quality**

**Issued/Modified:** August 3, 2023

**Expires:** July 31, 2028

**Permit No.**

**MSU010013**

**Agency Interest #** 16577

# Table of Contents

Subject Item Inventory.....	i
Facility Requirements.....	1
General Information.....	A-1
Other Relevant Documents:	

# To Operate a Wastewater Disposal System with No Discharge

Rancho Los Fuentes

Subject Item Inventory

Permit Number: MSU010013

Activity ID No.: PER20230001

## Subject Item Inventory:

ID	Designation	Description
AI16577	MSU010013	Restaurant
RPNT2	MSU010013	No Discharge

### KEY

ACT = Activity

AREA = Area

CAFO = Concentrated Animal Feeding Operation

EQPT = Equipment

IMPD = Impoundment

RPNT = Release Point

WDPT = Withdrawal Point

AI = Agency Interest

CONT = Control Device

IA = Insignificant Activity

MAFO = Animal Feeding Operation

PCS = PCS

TRMT = Treatment

# To Operate a Wastewater Disposal System with No Discharge

Rancho Los Fuentes

Facility Requirements

Permit Number: MSU010013

Activity ID No.:PER20230001

Page 1 of 2

**AI0000016577 (MSU010013) Restaurant:**

## Narrative Requirements:

---

Condition No.	Condition
T-1	The discharge from this facility shall cease and connection made to a regional sewer system when the sewer system is available in the area. At that time the discharge from the treatment system shall be terminated. [11 Miss. Admin. Code Pt. 6, Ch. 1, Subch. 1.]
T-2	The Office of Pollution Control (OPC) must concur with required engineering plans and specifications for the on-site disposal system prior to the commencement of construction. [11 Miss. Admin. Code Pt. 6, Ch. 1, Subch. 1.]
T-3	The on-site disposal system must be installed in accordance with the Department of Health standards by a person licensed by the Department of Health or a registered engineer. [11 Miss. Admin. Code Pt. 6, Ch. 1, Subch. 1.]
T-4	If the disposal system includes an aerobic mechanical plant, the plant and disposal system must be inspected once every six-(6) months by a certified Mississippi Wastewater Operator or by an authorized and trained representative of the mechanical plant manufacturer. Inspection reports shall be submitted to OPC in January and July of each year. [11 Miss. Admin. Code Pt. 6, Ch. 1, Subch. 1.]
T-5	Septic tanks must be cleaned out when necessary, about every 3 to 5 years. The septic tank pumper must be licensed by the Department of Health. [11 Miss. Admin. Code Pt. 6, Ch. 1, Subch. 1.]
T-6	There shall be no vehicular traffic allowed over any part of the on-site disposal system unless that part of the system is designed and constructed to support the weight. [11 Miss. Admin. Code Pt. 6, Ch. 1, Subch. 1.]
T-7	Connection shall be made to a sanitary sewer system when a system is available in the area. Upon such connection, use of the on-site disposal system shall be terminated. [11 Miss. Admin. Code Pt. 6, Ch. 1, Subch. 1.]
T-8	No Discharge of Wastewater to Surface Water  There shall be no discharge of wastewater to waters of the State, as defined in the Mississippi Water Pollution Control Law, 49-17-5(f), except as provided in the bypassing condition in this permit. [11 Miss. Admin. Code Pt. 6, R. 1.1.1.B.]
T-9	Closure Requirements  Should the permittee decide to permanently close the premises that generates the wastewater, he shall notify the Permit Board no later than 90 days prior to doing so. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(11).]

## To Operate a Wastewater Disposal System with No Discharge

Rancho Los Fuentes

Facility Requirements

Permit Number: MSU010013

Activity ID No.:PER20230001

Page 2 of 2

### AI0000016577 (MSU010013) Restaurant:

#### Narrative Requirements:

---

Condition No.	Condition
T-10	<p>Facility Expansion and/or Modification</p> <p>Any expansion or modification resulting in increased wastewater flow and/or strength must receive prior approval of system expansion and a permit modification from the Environmental Quality Permit Board. Prior approval from OPC must be obtained before making any alterations to the approved disposal system. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(14).]</p>
T-11	<p>Proper Operation, Maintenance and Replacement</p> <p>The permittee shall at all times maintain in good working order and operate as efficiently as possible all parts of the disposal system and other equipment installed or used to comply with this permit. Should part of the disposal system fail, the permittee must immediately make needed repairs and/or system modifications. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(18).]</p>
T-12	<p>Bypassing</p> <p>Any diversion from or bypass of the on-site disposal system is prohibited, except where unavoidable to prevent loss of life or severe property damage. The permittee shall notify the Mississippi Environmental Quality Permit Board in writing of each such diversion or bypass in advance where practicable but in any case, within 72 hours of the diversion or bypass, and shall submit to the permit Board a plan to prevent recurrence of the diversion or bypass within thirty (30) days of the incident. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(20).]</p>
T-13	<p>Transfer of Ownership or Control</p> <p>This permit is non-transferable except by Permit Board action. [11 Miss. Admin. Code Pt. 6, R. 1.1.5.C.]</p>

## GENERAL INFORMATION

Rancho Los Fuentes  
16182 Highway 26 West  
Lucedale, MS  
George County

### Alternate/Historic Identifiers

ID	Alternate/Historic Name	User Group	Start Date	End Date
16577	Aunt Beck's Family Restaurant	Historic Site Name	10/12/2001	03/02/2014
MSU010013	Aunt Beck's Family Restaurant	Water - SOP	01/30/2002	10/16/2006
MSU010013	Aunt Becks Family Restaurant	Water - SOP	10/16/2006	09/30/2011
16577	Rancho Los Fuentes	Official Site Name	03/03/2014	
MSU010013	Rancho Los Fuentes	Water - SOP	07/18/2014	01/23/2019
	Branch	Branches Group - Water	07/18/2017	
MSU010013	Rancho Los Fuentes	Water - SOP	01/23/2019	12/31/2023

**Basin:** Pascagoula River Basin

**Location Description:** PG - Plant Entrance (General) collected by dheadrick on 02/15/0011