



## State of Mississippi



### WATER POLLUTION CONTROL PERMIT

To Operate a Wastewater Disposal System with No Discharge

#### **THIS CERTIFIES**

Carriage Parke Homeowners Association, Carriage Parke Subdivision  
Lamplighter Lane  
Purvis, MS  
Lamar County

has been granted permission to operate a wastewater disposal system in accordance with the limitations and conditions set forth in this permit. This permit is issued in accordance with the provisions of the Mississippi Water Pollution Control Law (Section 49-17-1 et seq., Mississippi Code of 1972), and the regulations and standards adopted and promulgated thereunder.

**Mississippi Environmental Quality Permit Board**

A blue ink signature, likely of the board member, written over a white rectangular background.

---

**Mississippi Department of Environmental Quality**

Issued/Modified: July 15, 2025

Expires: June 30, 2030

Permit No. MSU050102

Agency Interest # 23140

**Table of Contents**

Subject Item Inventory.....i

Facility Requirements.....1

General Information.....A-1

Other Relevant Documents:

    Domestic WW Disposal System SOP Application

## To Operate a Wastewater Disposal System with No Discharge

Carriage Parke Homeowners Association, Carriage Parke Subdivision

Subject Item Inventory

Permit Number:MSU050102

Activity ID No.: PER20250001

### Subject Item Inventory:

ID	Designation	Description
AI23140		
RPNT1	MSU050102	No Discharge Facility

### Receiving Stream Relationships:

Subject Item	Relationship	Receiving Stream
AI 23140	Discharges Into	Sandy Run

#### KEY

ACT = Activity

AREA = Area

CONT = Control Device

IA = Insignificant Activity

MAFO = Animal Feeding Operation

RPNT = Release Point

WDPT = Withdrawal Point

AI = Agency Interest

CAFO = Concentrated Animal Feeding Operation

EQPT = Equipment

IMPD = Impoundment

PCS = PCS

TRMT = Treatment

## To Operate a Wastewater Disposal System with No Discharge

Carriage Parke Homeowners Association, Carriage Parke Subdivision

Facility Requirements

Permit Number:MSU050102

Activity ID No.: PER20250001

Page 1 of 2

**AI0000023140:**

### Narrative Requirements:

Condition No.	Condition
T-1	The Office of Pollution Control (OPC) must concur with required engineering plans and specifications for the on-site disposal system prior to the commencement of construction. [11 Miss. Admin. Code Pt. 6, Ch. 1, Subch. 1.]
T-2	The on-site disposal system must be installed in accordance with the Department of Health standards by a person licensed by the Department of Health or a registered engineer. [11 Miss. Admin. Code Pt. 6, Ch. 1, Subch. 1.]
T-3	<p>Facility Expansion and/or Modification</p> <p>Any expansion or modification resulting in increased wastewater flow and/or strength must receive prior approval of system expansion and a permit modification from the Environmental Quality Permit Board. Prior approval from OPC must be obtained before making any alterations to the approved disposal system. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(14).]</p>
T-4	<p>No Discharge of Wastewater to Surface Water</p> <p>There shall be no discharge of wastewater to waters of the State, as defined in the Mississippi Water Pollution Control Law, 49-17-5(f), except as provided in the bypassing condition in this permit. [11 Miss. Admin. Code Pt. 6, R. 1.1.1.B.]</p>
T-5	<p>Bypassing</p> <p>Any diversion from or bypass of the on-site disposal system is prohibited, except where unavoidable to prevent loss of life or severe property damage. The permittee shall notify the Mississippi Environmental Quality Permit Board in writing of each such diversion or bypass in advance where practicable but in any case, within 72 hours of the diversion or bypass, and shall submit to the permit Board a plan to prevent recurrence of the diversion or bypass within thirty (30) days of the incident. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(20).]</p>
T-6	<p>Proper Operation, Maintenance and Replacement</p> <p>The permittee shall at all times maintain in good working order and operate as efficiently as possible all parts of the disposal system and other equipment installed or used to comply with this permit. Should part of the disposal system fail, the permittee must immediately make needed repairs and/or system modifications. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(18).]</p>

## To Operate a Wastewater Disposal System with No Discharge

Carriage Parke Homeowners Association, Carriage Parke Subdivision

Facility Requirements

Permit Number:MSU050102

Activity ID No.: PER20250001

Page 2 of 2

### AI0000023140 (continued):

#### Narrative Requirements:

Condition No.	Condition
T-7	If the disposal system includes an aerobic mechanical plant, the plant and disposal system must be inspected once every six-(6) months by a certified Mississippi Wastewater Operator or by an authorized and trained representative of the mechanical plant manufacturer. Inspection reports shall be submitted to OPC in January and July of each year. [11 Miss. Admin. Code Pt. 6, Ch. 1, Subch. 1.]
T-8	Septic tanks must be cleaned out when necessary, about every 3 to 5 years. The septic tank pumper must be licensed by the Department of Health. [11 Miss. Admin. Code Pt. 6, Ch. 1, Subch. 1.]
T-9	There shall be no vehicular traffic allowed over any part of the on-site disposal system unless that part of the system is designed and constructed to support the weight. [11 Miss. Admin. Code Pt. 6, Ch. 1, Subch. 1.]
T-10	Connection shall be made to a sanitary sewer system when a system is available in the area. Upon such connection, use of the on-site disposal system shall be terminated. [11 Miss. Admin. Code Pt. 6, Ch. 1, Subch. 1.]
T-11	Closure Requirements  Should the permittee decide to permanently close the premises that generates the wastewater, he shall notify the Permit Board no later than 90 days prior to doing so. [11 Miss. Admin. Code Pt. 6, R. 1.1.4.A(18).]
T-12	Transfer of Ownership or Control  This permit is non-transferable except by Permit Board action. [11 Miss. Admin. Code Pt. 6, R. 1.1.5.C.]

## GENERAL INFORMATION

Carriage Parke Homeowners Association, Carriage Parke Subdivision  
Lamplighter Lane  
Purvis, MS  
Lamar County

### Alternate/Historic Identifiers

ID	Alternate/Historic Name	User Group	Start Date	End Date
23140	Carriage Parke Homeowners Association	Official Site Name	3/31/2014	
MSU050102	Carriage Park Subdivision	Water - SOP	5/24/2006	4/30/2011
MSR103818	Carriage Park Subdivision	GP-Construction	5/22/2006	5/31/2010
23140	Carriage Parke Subdivision	Historic Site Name	9/23/2005	6/3/2011
MSU050102	Carriage Utilities LLC, Carriage Park Subdivision	Water - SOP	8/1/2011	3/31/2014
23140	Great Southern National Bank, Carriage Utilities LLC, Carriage Park Subdivision	Historic Site Name	6/3/2011	3/31/2014
MSU050102	Carriage Parke Homeowners Association, Carriage Park Subdivision	Water - SOP	3/31/2014	7/18/2016
MSR106715	D. R. Horton, Inc. - Huntsville, DHR	GP-Construction	9/17/2014	6/30/2016
MSU050102	Carriage Parke Homeowners Association, Carriage Park Subdivision	Water - SOP	7/18/2016	1/12/2021
	Branch	Branches Group - Stormwater-401	7/18/2017	
	Branch	Branches Group - Municipal	8/15/2017	
MSU050102	Carriage Parke Homeowners Association, Carriage Park Subdivision	Water - SOP	1/12/2021	12/31/2025

**Basin:** Pascagoula River Basin

**Location Description:**PG - Plant Entrance (General) collected by dheadrick on 04/08/0010

## **GENERAL INFORMATION**

**General Facility Description:** Carriage Park Subdivision

**Relevant Documents:** Domestic WW Disposal System SOP Application