

MAP

MISSISSIPPI ASBESTOS DEMOLITION/RENOVATION NOTIFICATION FORM

Mail notification to: MDEQ Asbestos and Lead Branch, 515 E. Amite Street, Jackson, MS 39201

MDEQ Use Only: <input type="checkbox"/> Email <input type="checkbox"/> Mail <input checked="" type="checkbox"/> Hand Delivery		Postmark (mail only)	Date Received 3-8-2023	AI Number
I. Type of Notification (O=Original R=Revised C=Canceled A= Annual): 0				
II. TYPE OF OPERATION (D=Demo O= Ordered Demo R=Renovation E=Emer. Renovation): Demo				
III. FACILITY DESCRIPTION (Include building name, number and floor or room number):				
Bldg. Name: Jackson Hinds Comprehensive Health Center				
Address: 2775 Medger Evers Blvd.				
City: Jackson		State: MS	Zip:	
Site Location: Same as above		Tel:		
Building Size: 6865 sq. ft		# of Floors: 1	Age in Years: 50 plus	
Present Use: Vacant		Prior Use: Clinic		
IV. FACILITY INFORMATION (Identify owner, asbestos removal contractor, and other operator)				
OWNER NAME: Jackson Hinds Comprehensive Health Clinic				
Address: 3502 West Northside Dr.				
City: Jackson		State: MS	Zip: 39213	
Contact: Chandra Mayes		Tel: 601) 364-5182		
ASBESTOS REMOVAL CONTRACTOR: Bestway Abatement				
Address: P.O. Box 88				
City: Edwards		State: MS	Zip: 39064	
Contact: Aaron Lee		Tel: 601) 383-3237		
Certification Number: ABI-00002924		Expiration Date: 10/18/2023		
OTHER OPERATOR: Fisher Construction Inc.				
Address: P.O. Box 16592				
City: Jackson		State: MS	Zip: 39236	
Contact: Renae Fisher		Tel: 601) 665-3813		
V. WAS SITE INSPECTED TO DETERMINE PRESENCE OF ASBESTOS? (Yes/No): Yes				
WAS ASBESTOS PRESENT? (Yes/No): Yes		Inspection Date: 2/22/2023		
Inspector: Aaron Lee		Certification Number: ABI-00007853	Expiration Date: 10/17/2023	
VI. SUSPECT MATERIALS SAMPLED AND PROCEDURES USED TO DETECT THE PRESENCE OF ASBESTOS MATERIAL:				
Felt - drywall - textured ceiling - floor tile - carpet - wall paper				
EPA 600/R-93/116 Polarized Light Microscopy				
VII. QUANTITY OF RACM TO BE REMOVED:				
Pipes (LN FT):	Surface Area (SQ FT): 6865		Volume of Facility Components (CU FT):	
VIII. QUANTITY OF NONFRIABLE ASBESTOS NOT REMOVED:				
Category I:		Category II:		
IX. SCHEDULED DATES ASBESTOS REMOVAL (MM/DD/YY) Start: 3/23/2023		Complete: 4/15/2023		
X. SCHEDULED DATES DEMO/RENOVATION (MM/DD/YY) Start: 4/10/2023		Complete: 5/26/2023		

RECEIVED

MAR 08 2023

DEPT. OF ENVIRONMENTAL QUALITY

XI. DESCRIPTION OF PLANNED DEMOLITION OR RENOVATION WORK, AND METHOD(S) TO BE USED:

Parking Lot

XII. DESCRIPTION OF WORK PRACTICES AND ENGINEERING CONTROLS TO BE USED TO PREVENT EMISSIONS OF ASBESTOS AT THE DEMOLITION OR RENOVATION SITE:

Negative Air Machine - wet method

XIII. WASTE TRANSPORTER #1

Name: Bestway Abatement

Address: P.O. Box 88

City: Edwards

State: MS

Zip: 39066

Contact Person: Aaron Lee

Tel: 601 383-3237

WASTE TRANSPORTER #2

Name: Fisher Construction Inc

Address: P.O. Box 16592

City: Jackson

State: MS

Zip: 39236

Contact Person: Renee Fisher

Tel: 601 665-3813

XIV. WASTE DISPOSAL SITE

Name: Little Dixie Landfill

Address: 1716 N County Line Rd.

City: Ridgeland

State: MS

Zip:

Contact Person:

Tel:

XV. IF DEMOLITION ORDERED BY A GOVERNMENT AGENCY, PLEASE IDENTIFY THE AGENCY BELOW:

Name: Title:

Authority: N/A

Date of Order (MM/DD/YY):

Date Ordered to Begin (MM/DD/YY):

XVI. FOR EMERGENCY RENOVATIONS:

Date and Hour of Emergency (MM/DD/YY):

Description of the sudden unexpected event:

Explanation of how the event caused unsafe conditions or would cause equipment damage or an unreasonable financial burden:

XVII. DESCRIPTION OF PROCEDURES TO BE FOLLOWED IN THE EVENT THAT UNEXPECTED ASBESTOS IS FOUND OR PREVIOUSLY NONFRIABLE ASBESTOS MATERIAL BECOMES CRUMBLLED, PULVERIZED, OR REDUCED TO POWDER:

Stop and call DEQ

XVIII. I CERTIFY THAT AN INDIVIDUAL TRAINED IN THE PROVISIONS OF THIS REGULATION (40 CFR PART 61, SUBPART M) WILL BE ONSITE DURING THE DEMOLITION OR RENOVATION, AND EVIDENCE THAT THE REQUIRED TRAINING HAS BEEN ACCOMPLISHED BY THIS PERSON WILL BE AVAILABLE FOR INSPECTION DURING NORMAL BUSINESS HOURS.

Aaron Lee

Type or Print Name

Aaron Lee

(Signature of Owner/Operator)

3/7/2023

(Date)

XIX. I CERTIFY THAT THE ABOVE INFORMATION IS CORRECT:

Aaron Lee

Type or Print Name

Aaron Lee

(Signature of Owner/Operator)

3/7/2023

(Date)



EMSL Analytical, Inc.

18369 Petroleum Drive Baton Rouge, LA 70809

Tel/Fax: (225) 755-1920 / (225) 755-1989

http://www.EMSL.com / batonrougelab@emsl.com

EMSL Order: 252301010

Customer ID: BEST66

Customer PO:

Project ID:

Attention: Aaron Lee

Bestway Abatement

222 Vicksburg Road

PO Box 88

Edwards, MS 39066

Project: JHCHC 2775 Medger Evers Blvd.

Phone: (601) 383-3237

Fax: (601) 630-4241

Received Date: 02/27/2023 4:57 PM

Analysis Date: 03/03/2023

Collected Date:

Test Report: Asbestos Analysis of Bulk Materials via AHERA Method 40CFR 763 Subpart E Appendix E supplemented with EPA 600/R-93/116 using Polarized Light Microscopy

Sample	Description	Appearance	Non-Asbestos		Asbestos % Type
			% Fibrous	% Non-Fibrous	
JH100 252301010-0001	Felt	Black Fibrous Homogeneous	40% Cellulose 5% Glass	55% Non-fibrous (Other)	None Detected
JH101-Texture 252301010-0002	drywall	Tan Non-Fibrous Homogeneous		98% Non-fibrous (Other)	2% Chrysotile
JH101-Drywall 252301010-0002A	drywall	Tan Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
JH102 252301010-0003	Textured Ceiling	Tan Non-Fibrous Homogeneous		97% Non-fibrous (Other)	3% Chrysotile
JH103-Floor Tile 1 252301010-0004	hallway - floor tile	Tan Non-Fibrous Homogeneous		98% Non-fibrous (Other)	2% Chrysotile
JH103-Floor Tile 2 252301010-0004A	hallway - floor tile	Tan Non-Fibrous Homogeneous		97% Non-fibrous (Other)	3% Chrysotile
JH103-Mastic 252301010-0004B	hallway - floor tile	Black Non-Fibrous Homogeneous		94% Non-fibrous (Other)	6% Chrysotile
JH104-Carpet 252301010-0005	hallway - Carpet	Tan/Blue Fibrous Homogeneous	90% Synthetic	10% Non-fibrous (Other)	None Detected
JH104-Glue 252301010-0005A	hallway - Carpet	Yellow Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
JH105 252301010-0006	hallway - Wallpaper	Tan Fibrous Homogeneous	80% Cellulose	20% Non-fibrous (Other)	None Detected
JH106-Floor Tile 252301010-0007	Storage rm - floor tile	Tan Non-Fibrous Homogeneous		97% Non-fibrous (Other)	3% Chrysotile
JH106-Mastic 252301010-0007A	Storage rm - floor tile	Black Non-Fibrous Homogeneous		92% Non-fibrous (Other)	8% Chrysotile
JH107-Floor Tile 252301010-0008	east end Storage rm - floor tile	Tan Non-Fibrous Homogeneous		97% Non-fibrous (Other)	3% Chrysotile
JH107-Mastic 252301010-0008A	east end Storage rm - floor tile	Black Non-Fibrous Homogeneous		92% Non-fibrous (Other)	8% Chrysotile
JH108-Floor Tile 252301010-0009	East end Women bathrm - floor tile	Gray Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
JH108-Adhesive 252301010-0009A	East end Women bathrm - floor tile	Yellow Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected

Initial report from: 03/03/2023 12:51:02



EMSL Analytical, Inc.

18369 Petroleum Drive Baton Rouge, LA 70809

Tel/Fax: (225) 755-1920 / (225) 755-1989

http://www.EMSL.com / batonrougelab@emsl.com

EMSL Order: 252301010

Customer ID: BEST66

Customer PO:

Project ID:

Test Report: Asbestos Analysis of Bulk Materials via AHERA Method 40CFR 763 Subpart E Appendix E supplemented with EPA 600/R-93/116 using Polarized Light Microscopy

Sample	Description	Appearance	Non-Asbestos		Asbestos
			% Fibrous	% Non-Fibrous	% Type
JH109	drywall	Gray Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
252301010-0010					
JH110	Front exterior Window - Caulking	White Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
252301010-0011					

Analyst(s)

Haley Young (18)

Martiana Beach, Laboratory Manager
or Other Approved Signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. The above analyses were performed in general compliance with Appendix E to Subpart E of 40 CFR (previously EPA 600/M4-82-020 "Interim Method") but augmented with procedures outlined in the 1993 ("final") version of the method. This report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST or any agency of the federal government. Non-friable organically bound materials present a problem matrix and therefore EMSL recommends gravimetric reduction prior to analysis. Unless requested by the client, building materials manufactured with multiple layers (i.e. linoleum, wallboard, etc.) are reported as a single sample. Estimation of uncertainty is available on request.

Samples analyzed by EMSL Analytical, Inc. Baton Rouge, LA NVLAP Lab Code 200375-0, LELAP 01950, TX 300238

Initial report from: 03/03/2023 12:51:02