

DEF



MISSISSIPPI ASBESTOS DEMOLITION/RENOVATION NOTIFICATION FORM

Mail notification to: MDEQ Asbestos and Lead Branch, 515 E. Amite Street, Jackson, MS 39201

MDEQ Use Only: <input type="checkbox"/> Email <input type="checkbox"/> Mail <input checked="" type="checkbox"/> Hand Delivery		Postmark (mail only)	Date Received 9.28.2023	AI Number
I. Type of Notification (O=Original R=Revised C=Canceled A= Annual) R				
II. TYPE OF OPERATION (D=Demo O= Ordered Demo R=Renovation E=Emer. Renovation): D				
III. FACILITY DESCRIPTION (Include building name, number and floor or room number):				
Bldg. Name: Residential House				
Address: 303 MITCHELL AVE				
City: JACKSON		State: MS	Zip: 39216	
Site Location: Same as above			Tel:	
Building Size: 1159		# of Floors: 1	Age in Years: 81	
Present Use:		Prior Use:		
IV. FACILITY INFORMATION (Identify owner, asbestos removal contractor, and other operator)				
OWNER NAME: CALLOWAY ROBERT A				
Address: 303 MITCHELL AVE				
City: JACKSON		State: MS	Zip: 39216	
Contact: City of Jackson			Tel: 601-960-1054 or 601-960-2470	
ASBESTOS REMOVAL CONTRACTOR: Anderson Environmental				
Address: 870 Foley Street				
City: Jackson		State: MS	Zip: 39202	
Contact: Daryl Anderson			Tel: 601-354-4400	
Certification Number:			Expiration Date:	
OTHER OPERATOR: Xquisite Lawncare LLC				
Address: 210 Meadowbrook Rd, Suite 102				
City: Jackson		State: MS	Zip: 39206	
Contact: Steven Jones			Tel: 769-226-9237	
V. WAS SITE INSPECTED TO DETERMINE PRESENCE OF ASBESTOS? (Yes/No): YES				
WAS ASBESTOS PRESENT? (Yes/No): YES			Inspection Date: 11/17/2022	
Inspector: SAMANTHA GRAVES		Certification Number: ABI-00009825	Expiration Date: 11/17/2022	
VI. SUSPECT MATERIALS SAMPLED AND PROCEDURES USED TO DETECT THE PRESENCE OF ASBESTOS MATERIAL:				
EPA 600/R-93-/116 BULK POLARIZED LIGHT MICROSCOPY (EAS) SIDING, SIDING FELT, WALL SHEETROCK, BURNED DEBRIS, CEILING INSULATION,				
VII. QUANTITY OF RACM TO BE REMOVED:				
Pipes (LN FT):	Surface Area (SQ FT): 1159		Volume of Facility Components (CU FT):	
VIII. QUANTITY OF NONFRIABLE ASBESTOS NOT REMOVED:				
Category I:		Category II:		
IX. SCHEDULED DATES ASBESTOS REMOVAL (MM/DD/YY) Start: 10/11/2023			Complete: 10/13/2023	
X. SCHEDULED DATES DEMO/RENOVATION (MM/DD/YY) Start: 10/14/2023			Complete: 10/23/2023	

RECEIVED

SEP 28 2023

XI. DESCRIPTION OF PLANNED DEMOLITION OR RENOVATION WORK, AND METHOD(S) TO BE USED:		
abatement and demo of abandoned house		
XII. DESCRIPTION OF WORK PRACTICES AND ENGINEERING CONTROLS TO BE USED TO PREVENT EMISSIONS OF ASBESTOS AT THE DEMOLITION OR RENOVATION SITE:		
Area barricaded using asbestos signs and danger tape; removed using WET method and ACM and poly		
XIII. WASTE TRANSPORTER #1		
Name: Xquisite Lawncare LLC		
Address: 210 Meadowbrook Rd, Suite 102		
City: Jackson	State: MS	Zip: 39206
Contact Person: Steven Jones		Tel: 769-226-9237
WASTE TRANSPORTER #2		
Name: SAME		
Address:		
City:	State:	Zip:
Contact Person:		Tel:
XIV. WASTE DISPOSAL SITE		
Name: Allied Waste Little Dixie Landfill		
Address: 1718 N Countyline Rd		
City: Ridgeland	State: MS	Zip: 39157
Contact Person:		Tel: 601-982-9488
XV. IF DEMOLITION ORDERED BY A GOVERNMENT AGENCY, PLEASE IDENTIFY THE AGENCY BELOW:		
Name: Samantha Graves		Title: Manager
Authority: City of Jackson		
Date of Order (MM/DD/YY): 8/23/23		Date Ordered to Begin (MM/DD/YY):
XVI. FOR EMERGENCY RENOVATIONS:		
Date and Hour of Emergency (MM/DD/YY):		
Description of the sudden unexpected event:		
Explanation of how the event caused unsafe conditions or would cause equipment damage or an unreasonable financial burden: structure is a menace to the public safety and welfare of the community; poses danger to school children at bus stop & prostitution and drug haven		
XVII. DESCRIPTION OF PROCEDURES TO BE FOLLOWED IN THE EVENT THAT UNEXPECTED ASBESTOS IS FOUND OR PREVIOUSLY NONFRIABLE ASBESTOS MATERIAL BECOMES CRUMBLED, PULVERIZED, OR REDUCED TO POWDER:		
Halt all work and notify proper authorities.		
XVIII. I CERTIFY THAT AN INDIVIDUAL TRAINED IN THE PROVISIONS OF THIS REGULATION (40 CFR PART 61, SUBPART M) WILL BE ONSITE DURING THE DEMOLITION OR RENOVATION, AND EVIDENCE THAT THE REQUIRED TRAINING HAS BEEN ACCOMPLISHED BY THIS PERSON WILL BE AVAILABLE FOR INSPECTION DURING NORMAL BUSINESS HOURS.		
Steven Jones		09/27/2023
Type or Print Name	(Signature of Owner/Operator)	(Date)
XIX. I CERTIFY THAT THE ABOVE INFORMATION IS CORRECT:		
Steven Jones		09/27/2023
Type or Print Name	(Signature of Owner/Operator)	(Date)



Environmental
Analytical
Services, LLC

13201 Northwest Freeway, Suite 520
Houston, Texas 77040
phone 713-343-4017 | fax 713-934-9942
www.easlabs.com | facebook.com/easlabs | info@easlabs.com

**Test: EPA 600/R-93/116
Polarized Light Microscopy**

Client Information:

City of Jackson

200 S President St

Jackson, MS 39201

Phone: 601-960-1054

E-Mail: sgraves@city.jackson.ms.us

Project:

303 Mitchell Ave

CE-21-78

EAS Job: 22120505

Attn: Samantha Grave

Date Analyzed: 12/06/2022 11:30 AM

Date Received: 12/05/2022 09:00 AM

TAT Requested: 1 Day

Microscope: PLM Olympus BH-2

Sample # Lab ID #	Layer	Sample Description	Asbestos Detected (Yes/No)	Asbestos Mineral Percent	Non-Asbestos Fibers	Non-Fibrous Material
1 22120505.01	A	Gray Fibrous Transite Siding Homogeneous	YES	Chrysotile 40%		Binders 60%
2 22120505.02	A	Black Fibrous Felt Homogeneous	NO	None Detected	Cellulose 70%	Bitumen 30%
3 22120505.03	A	White Drywall Homogeneous	NO	None Detected	Cellulose 5%	Binders 95%
3 22120505.03	B	Brown Fibrous Paper Backing Homogeneous	NO	None Detected	Cellulose 100%	
4 22120505.04	A	Black Burned Debris Homogeneous	NO	None Detected	Fiberglass 5%	Other Non-Fibrous 95%

NVLAP Lab Code: 200784-0

TDSHS License No. 300373

LDEQ LELAP Certificate No: 04161, Agency Interest No. 149571

Notes:

Some samples (floor tiles, surfacing, etc.) may contain fibers too small to be detectable by PLM. TEM Chatfield analysis of bulk material is recommended in this case. All asbestos percentages are based on calibrated visual estimates traceable to NIST standards for regulated asbestos types. Analysts' percentages fall within a range of acceptable percentages, depending on the actual concentration of asbestos. This test report relates only to the items tested. This report must not be used to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the Federal Government. This report may not be reproduced except in full without permission from Environmental Analytical Services.

These results are submitted pursuant to EAS' current terms of sale, including the company's standard warranty and limitation of liability provisions and no responsibility or liability is assumed for the manner in which the results are used or interpreted. Unless notified in writing to return the samples covered by this report, EAS will store the samples for a period of ninety (90) days before discarding. Percent ranges reported are estimates and not absolute percent range values.

Analyzed By: *Terry Brindley*
Terry Brindley

Approved Signatory: *Terry Brindley*
Terry Brindley



Environmental
Analytical
Services, LLC

13201 Northwest Freeway, Suite 520
Houston, Texas 77040
phone 713-343-4017 | fax 713-934-9942
www.easlabs.com | facebook.com/easlabs | info@easlabs.com

**Test: EPA 600/R-93/116
Polarized Light Microscopy**

Client Information:

City of Jackson

200 S President St

Jackson, MS 39201

Phone: 601-960-1054

E-Mail: sgraves@city.jackson.ms.us

Project:

303 Mitchell Ave

CE-21-78

EAS Job: 22120505

Attn: Samantha Grave

Date Analyzed: 12/06/2022 11:25 AM

Date Received: 12/05/2022 09:00 AM

TAT Requested: 1 Day

Microscope: PLM Olympus BH-2

Sample # Lab ID #	Layer	Sample Description	Asbestos Detected (Yes/No)	Asbestos Mineral Percent	Non-Asbestos Fibers	Non-Fibrous Material
5 22120505.05	A	Yellow Fibrous Insulation Homogeneous	NO	None Detected	Fiberglass 100%	
6 22120505.06	A	Black Burned Debris Homogeneous	NO	None Detected	Cellulose 3% Fiberglass 2%	Other Non-Fibrous 95%

NVLAP Lab Code: 200784-0

TDSHS License No. 300373

LDEQ LELAP Certificate No: 04161, Agency Interest No. 149571

Notes:

Some samples (floor tiles, surfacing, etc.) may contain fibers too small to be detectable by PLM. TEM Chatfield analysis of bulk material is recommended in this case. All asbestos percentages are based on calibrated visual estimates traceable to NIST standards for regulated asbestos types. Analysts' percentages fall within a range of acceptable percentages, depending on the actual concentration of asbestos. This test report relates only to the items tested. This report must not be used to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the Federal Government. This report may not be reproduced except in full without permission from Environmental Analytical Services.

These results are submitted pursuant to EAS' current terms of sale, including the company's standard warranty and limitation of liability provisions and no responsibility or liability is assumed for the manner in which the results are used or interpreted. Unless notified in writing to return the samples covered by this report, EAS will store the samples for a period of ninety (90) days before discarding. Percent ranges reported are estimates and not absolute percent range values.

Analyzed By: *Terry Brindley*
Terry Brindley

Approved Signatory: *Terry Brindley*
Terry Brindley



Hinds County

MISSISSIPPI
FOUNDED 1821 • POPULATION 248,643

HindsCountyMs.com
[Database](#)
[Back](#)
[Print Page](#)

Landroll Detail

Parcel Number	Map Reference Number	
51-67	580.00 1 19.00	View Map Property Taxes Gis Map
Subdivision No.	Homestead Exemption Account Numbers	
58		
Assessed Owner	Assessed Values	
CALLOWAY ROBERT A	Land Value	2,516
303 MITCHELL AVE	Improvement Value	3,434
JACKSON MS 39216	Total	5,950
Location	Appraised Values	
303 MITCHELL AVE	Land Value	16,770
	Improvement Value	22,890
	Total	39,660
Legal Description	Building Info.	
LOT 7 BLK A ASYLUM HGTS LESS 45 FT S/S	Type	RETL
	Base Area	1,008
	Adjusted Area	1,159
	Year Built	1942
Acreage Info.		Deed Info.
Cultivated Acres	0.00	Book & Page
Uncultivated Acres	0.00	Date
		7232-4285
		03/21/2019

[Back](#) [Search](#)

Wednesday, August 23, 2023 [Contact Webmaster](#) [Phone Numbers](#) [Map to our Office](#)
 Copyright © 2023 Hinds County Board of Supervisors All rights reserved.

MISSISSIPPI